

JOB NO.: TCS00864/16

CEDD SERVICE CONTRACT NO. NTE/07/2016 ENVIRONMENTAL TEAM FOR DEVELOPMENT OF ANDERSON ROAD QUARRY SITE – SITE FORMATION AND ASSOCIATED INFRASTRUCTURE WORKS

MONTHLY ENVIRONMENTAL MONITORING AND AUDIT Report (February 2022)

PREPARED FOR CIVIL ENGINEERING AND DEVELOPMENT DEPARTMENT (CEDD)

DateReference No.Prepared ByCertified By21 March 2022TCS00864/16/600/R0535v2MMAMMA

Nicola Hon (Environmental Consultant) Tam Tak Wing (Environmental Team Leader)

Version	Date	Remarks
1	11 March 2022	First Submission
2	21 March 2022	Amended against IEC's comment



EXECUTIVE SUMMARY

- ES01 Action-United Environmental Services & Consulting (AUES) has been awarded the Civil Engineering and Development Department (CEDD) Service Contract No. NTE/07/2016 Environmental Team for Development of Anderson Road Quarry Site Site Formation and Associated Infrastructure Works (hereinafter called "the Service Contract") on 15 December 2016. The commencement date of the Service Contract is from December 2016 and the Contract Period is 70 months.
- ES02 The Services under the Service Contract is to provide environmental monitoring and audit (EM&A) services for the Works Contracts pursuant to the requirement of Environmental Team (ET) under the EM&A manual to ensure that the environmental performance of the Works Contracts comply with the requirement specified in the EM&A Manual and EIA Report of Development of Anderson Road Quarry and other relevant statutory requirements.
- ES03 To facilitate the project management and implementation, the Service Contract has been divided to three CEDD contracts including Contract NE/2016/01 (Contract 1), Contract NE/2016/05 (Contract 2) and Contract NE/2017/03 (Contract 3). As advised by the Resident Engineer (RE), the commencement date of Contract 1 was 21 December 2016 and the major construction works has been commenced on 12 April 2017. The commencement date of Contract 2 was 31 March 2017 and the major construction activities have been commenced on 2 May 2017. Furthermore, Contract 3 was commenced on 31 May 2018 and the major construction activities works was commenced in November 2018. The EM&A programme under the Project was commenced on 12 April 2017 pursuant to the requirement under the EM&A manual. In addition, variation order for extend service scope to E5, E6, E7 and C10 under Contract ED/2019/02 (Contract 5) was issued by AECOM. The commencement date of Contract 5 was on 30 March 2021. Moreover, variation order for extend service under Contract ED/2020/02 (Contract 4) was issued by AECOM. The commencement date of Contract 4 was on 27 September 2021.
- ES04 This is the **59th** monthly EM&A report presenting the monitoring results and inspection findings for the period from **1 to 28 February 2022** (hereinafter 'the Reporting Period').

ENVIRONMENTAL MONITORING AND AUDIT ACTIVITIES

ES05 Environmental monitoring activities under the EM&A programme in the Reporting Period are summarized in the following table.

Fnvironmontal	Environmental Monitoring	Reporting Period		
Aspect	Parameters / Inspection	Number of Active Monitoring Locations	Total Occasions	
Air Quality	1-hour TSP	6	108	
All Quality	24-hour TSP	4	20	
Construction Noise	L _{eq(30min)} Daytime for Contract NE/2016/01	7	22	
	L _{eq(30min)} Daytime for Contract NE/2017/03	3	12	

BREACH OF ACTION AND LIMIT (A/L) LEVELS

ES06 No exceedance of air quality was recorded in the Reporting Period. For construction noise monitoring, no Limit Level exceedance was recorded and no noise complaint (which triggered Action Level) was received in the reporting period. The environmental exceedance, NOE issued and investigation of exceedance are summarized in the following table.

Environmentel	Monitoring	Action	T imit	Event & Action			
Aspect	Parameters	Level	Limit Level	NOE Issued	Investigation	Corrective Actions	
	1-hour TSP	0	0	0	NA	NA	
Air Quanty	24-hour TSP	0	0	0	NA	NA	



vionuny	Environmental Wontonitoring	g & Auunt Report (Februar)	y 2022)

Environmentel	Monitoring	Action	I imit	Event & Action		
Aspect	Parameters	Level	Limit Level	NOE Issued	Investigation	Corrective Actions
Construction Noise	L _{eq(30min)} Daytime	0	0	0	NA	NA

ENVIRONMENTAL COMPLAINT

ES07 In the reporting period, no environmental complaint was received.

NOTIFICATION OF SUMMONS AND SUCCESSFUL PROSECUTIONS

ES08 No environmental summons or successful prosecutions for the Project were recorded in the Reporting Period.

REPORTING CHANGE

ES09 There is no reporting change in the Reporting Period.

SITE INSPECTION

- ES10 In this Reporting Period, joint site inspections to evaluate the site environmental performance for *Contract 1* were carried out by the RE, ET and Contractor on 10, 15 and 22 February 2022 in which IEC joined the site inspection with SSEMC on 10 February 2022. No non-compliance was noted during the site inspection.
- ES11 In this Reporting Period, joint site inspections to evaluate the site environmental performance for *Contract 2* were carried out by the RE, ET and Contractor on 9, 16 and 25 February 2022 in which IEC joined the site inspection on 25 February 2022. No non-compliance was noted during the site inspection.
- ES12 In this Reporting Period, joint site inspections to evaluate the site environmental performance for *Contract 3* were carried out by the RE, ET and Contractor on 4, 11, 18 and 25 February 2022 in which IEC joined the site inspection with SSEMC on 25 February 2022. No non-compliance was noted during the site inspection.
- ES13 In this Reporting Period, joint site inspections to evaluate the site environmental performance for *Contract 4* were carried out by the RE, ET and Contractor on 9, 16 and 24 February 2022 in which IEC joined the site inspection with SSEMC on 24 February 2022. No non-compliance was noted during the site inspection.
- ES14 In this Reporting Period, joint site inspections to evaluate the site environmental performance for *Contract 5* were carried out by the RE, ET and Contractor on 10, 17 and 21 February 2022 in which IEC joined the site inspection with SSEMC on 21 February 2022. No non-compliance was noted during the site inspection.

FUTURE KEY ISSUES

- ES15 During dry season, the Contractors should fully implement air quality mitigation measures to reduce construction dust emission as far as practicable. Furthermore, since construction site is highly visible to the resident at nearby estates, noise mitigation measures such as using of quiet plants should be implemented in accordance with the EM&A requirement.
- ES16 Since construction site is highly visible to the resident at nearby estates, the Contractors should pay special attention on potential environmental impact generated by the site activities and adhere implement adequate air quality and noise mitigation measures as far as practicable to reduce the impact to the public.



- ES17 Construction noise is one of the key environmental issues during construction work of the Project. Noise mitigation measures such as using quiet plants and noise barriers shall be implemented where practicable according to the EM&A manual.
- ES18 In addition, the Contractors should ensure all effluent discharge shall be fulfilled the Technical Memorandum of Effluent Discharged into Drainage and Sewerage Systems, inland and Coastal Waters criteria or relevant discharge license requirement.



Table of Contents

1.	INTRODUCTION	1
	1.1 PROJECT BACKGROUND	1
	1.2 REPORT STRUCTURE	1
2.	PROJECT ORGANIZATION AND CONSTRUCTION PROGRESS	3
	2.1 CONSTRUCTION CONTRACT PACKAGING	3
	2.2 PROJECT ORGANIZATION	4
	2.3 CONSTRUCTION PROGRESS	4
3.	SUMMARY OF IMPACT MONITORING REOUIREMENTS	13
	3.1 GENERAL	13
	3.2 MONITORING PARAMETERS	13
	3.3 MONITORING LOCATIONS	13
	3.4 MONITORING FREQUENCY AND PERIOD	15
	3.5 MONITORING EQUIPMENT	16
	3.6 MONITORING METHODOLOGY	16
	3.7 DERIVATION OF ACTION/LIMIT (A/L) LEVELS	18
	3.8 DATA MANAGEMENT AND DATA QA/QC CONTROL	19
4.	AIR QUALITY MONITORING	21
	4.1 GENERAL	21
	4.2 RESULTS OF AIR QUALITY MONITORING	21
5.	CONSTRUCTION NOISE MONITORING	23
	5.1 GENERAL	23
	5.2 NOISE MONITORING RESULTS IN REPORTING MONTH	23
6.	WASTE MANAGEMENT	25
	6.1 GENERAL WASTE MANAGEMENT	25
	6.2 RECORDS OF WASTE QUANTITIES	25
7.	SITE INSPECTION	27
	7.1 REOUIREMENTS	27
	7.2 FINDINGS / DEFICIENCIES DURING THE REPORTING MONTH	27
8.	ENVIRONMENTAL COMPLAINT AND NON-COMPLIANCE	30
0.	8.1 Environmental Complaint. Summons and Prosecution	30 30
0	IMDI EMENITATION STATUS OF MITIC ATION MEASUDES	27
9.	9.1 Genedat Requidements	32
	9.1 OENERAL REQUIREMENTS 0.2 TENTATIVE CONSTRUCTION ACTIVITIES IN THE COMING MONTH	32
	9.3 KEV ISSUES FOR THE COMING MONTH	32
4.0		
10.	CONCLUSIONS AND RECOMMENDATIONS	37
	10.1 CUNCLUSIONS 10.2 DECOMMENDATIONS	31 27
		37



LIST OF TABLES

TABLE 2-1	STATUS OF ENVIRONMENTAL LICENSES AND PERMITS OF THE CONTRACT 1
TABLE 2-2	STATUS OF ENVIRONMENTAL LICENSES AND PERMITS OF THE CONTRACT 2
TABLE 2-3	STATUS OF ENVIRONMENTAL LICENSES AND PERMITS OF THE CONTRACT 3
TABLE 2-4	STATUS OF ENVIRONMENTAL LICENSES AND PERMITS OF THE CONTRACT 4
TABLE 2-5	STATUS OF ENVIRONMENTAL LICENSES AND PERMITS OF THE CONTRACT 5
TABLE 3-1	SUMMARY OF EM&A REQUIREMENTS
TABLE 3-2	IMPACT MONITORING STATIONS - AIR QUALITY
TABLE 3-3	IMPACT MONITORING STATIONS - CONSTRUCTION NOISE
TABLE 3-4	ADDITIONAL IMPACT MONITORING STATIONS – CONSTRUCTION NOISE
TABLE 3-5	AIR QUALITY MONITORING EQUIPMENT
TABLE 3-6	CONSTRUCTION NOISE MONITORING EQUIPMENT
TABLE 3-7	ACTION AND LIMIT LEVELS FOR AIR QUALITY MONITORING
TABLE 3-8	ACTION AND LIMIT LEVELS FOR CONSTRUCTION NOISE
TABLE 4-1	SUMMARY OF 24-HOUR AND 1-HOUR TSP MONITORING RESULTS (AMS-1)
TABLE 4-2	SUMMARY OF 24-HOUR AND 1-HOUR TSP MONITORING RESULTS (AMS-2)
TABLE 4-3	SUMMARY OF 24-HOUR AND 1-HOUR TSP MONITORING RESULTS (AMS-3)
TABLE 4-4	SUMMARY OF 24-HOUR AND 1-HOUR TSP MONITORING RESULTS (AMS-5)
TABLE 4-5	SUMMARY OF 24-HOUR AND 1-HOUR TSP MONITORING RESULTS (AMS-6)
TABLE 4-6	SUMMARY OF 24-HOUR AND 1-HOUR TSP MONITORING RESULTS (AMS-7)
TABLE 5-1	SUMMARY OF CONSTRUCTION NOISE MONITORING RESULTS
TABLE 5-1a	SUMMARY OF CONSTRUCTION NOISE MONITORING RESULTS
TABLE 5-2	SUMMARY OF CONSTRUCTION NOISE MONITORING RESULTS
TABLE 6-1	SUMMARY OF QUANTITIES OF INERT C&D MATERIALS
TABLE 6-2	SUMMARY OF QUANTITIES OF C&D WASTES
TABLE 7-1	SITE OBSERVATIONS OF CONTRACT 1
TABLE 7-2	SITE OBSERVATIONS OF CONTRACT 2
TABLE 7-3	SITE OBSERVATIONS OF CONTRACT 3
TABLE 7-4	SITE OBSERVATIONS OF CONTRACT 4
TABLE 7-5	SITE OBSERVATIONS OF CONTRACT 5
TABLE 8-1	STATISTICAL SUMMARY OF ENVIRONMENTAL COMPLAINTS
TABLE 8-2	STATISTICAL SUMMARY OF ENVIRONMENTAL SUMMONS
TABLE 8-3	STATISTICAL SUMMARY OF ENVIRONMENTAL PROSECUTION
TABLE 9-1	Environmental Mitigation Measures
LIST OF APPI	ENDICES
APPENDIX A	LAYOUT PLAN OF THE PROJECT
APPENDIX B	PROJECT ORGANIZATION STRUCTURE
APPENDIX C	THREE-MONTHS ROLLING CONSTRUCTION PROGRAMME
APPENDIX D	MONITORING LOCATIONS FOR IMPACT MONITORING
Appendix E	CALIBRATION CERTIFICATE OF MONITORING EQUIPMENT AND HOKLAS-ACCREDITATION CERTIFICATE OF THE TESTING LABORATORY

- APPENDIX F EVENT AND ACTION PLAN
- APPENDIX G IMPACT MONITORING SCHEDULE
- APPENDIX H DATABASE OF MONITORING RESULT
- APPENDIX I GRAPHICAL PLOTS FOR MONITORING RESULT



APPENDIX J	METEOROLOGICAL DATA
APPENDIX K	WASTE FLOW TABLE
APPENDIX L	IMPLEMENTATION SCHEDULE FOR ENVIRONMENTAL MITIGATION MEASURES
APPENDIX M	COMPLAINT LOG
APPENDIX N	IMPLEMENTATION STATUS FOR WATER QUALITY MITIGATION MEASURES



INTRODUCTION

1.1 PROJECT BACKGROUND

- 1.1.1 Action-United Environmental Services & Consulting (hereinafter referred as "AUES") has been awarded the CEDD Service Contract No. NTE/07/2016 Environmental Team for Development of Anderson Road Quarry Site – Site Formation and Associated Infrastructure Works (hereinafter called "the Service Contract") on 15 December 2016. The commencement date of the Service Contract was December 2016 and the Contract Period is 70 months.
- 1.1.2 The Services under the Service Contract is to provide environmental monitoring and audit (EM&A) services for the Works Contracts pursuant to the requirement of Environmental Team (ET) under the EM&A manual to ensure that the environmental performance of the Works Contracts comply with the requirement specified in the EM&A Manual and Environmental Impact Assessment (EIA) Report of Development of Anderson Road Quarry and other relevant statutory requirements.
- 1.1.3 Development of Anderson Road Quarry is to provide land and the associated infrastructures for the proposed land used at the existing Anderson Road Quarry Site at the North-eastern of East Kowloon according to the final Recommended Outline Development Plan (hereinafter named as the Project Works).
- 1.1.4 To facilitate the project management and implementation, the Service Contract has been divided to three CEDD contracts including Contract NE/2016/01 (Contract 1), Contract NE/2016/05 (Contract 2) and Contract NE/2017/03 (Contract 3). As advised by the Resident Engineer (RE), the commencement date of Contract 1 was 21 December 2016 and the major construction works has been commenced on 12 April 2017. The commencement date of Contract 2 was 31 March 2017 and the major construction activities have been commenced on 2 May 2017. Furthermore, Contract 3 was commenced on 31 May 2018 and the major construction activities works was commenced in November 2018. The EM&A programme under the Project was commenced on 12 April 2017 pursuant to the requirement under the EM&A manual. In addition, variation order for extend service scope to E5, E6, E7 and C10 under Contract 5 was on 30 March 2021. Moreover, variation order for extend service under Contract ED/2020/02 (Contract 4) was issued by AECOM. The commencement date of Contract 4 was on 27 September 2021.
- 1.1.5 According to the Approved EM&A Manual, air quality and noise monitoring are required to be monitored during the construction phase of the Project. As part of the EM&A program, baseline monitoring is required to determine the ambient environmental conditions. Baseline monitoring including air quality and noise conducted between *January* and *April 2019* at all designated monitoring locations were before construction work commencement. Furthermore, the Baseline Monitoring Report which verified by the Independent Environmental Checker (hereinafter referred as "the IEC") has been submitted to Environmental Protection Department (EPD) on *9 May 2017* for endorsement.
- 1.1.6 This is the **59th** monthly EM&A report presenting the monitoring results and inspection findings for the period from **1 to 28 February 2022** (hereinafter referred as "Reporting Period").

1.2 1.2 REPORT STRUCTURE

- 1.2.1 The monthly EM&A Report is structured into the following sections:-
 - Section 1 Introduction
 - Section 2 Project Organization and Construction Progress
 - Section 3 Summary of Impact Monitoring Requirements
 - Section 4 Air Quality Monitoring
 - Section 5 Construction Noise Monitoring



Section 6	Waste Management
Section 7	Site Inspections
Section 8	Environmental Complaints and Non-Compliance
Section 9	Implementation Status of Mitigation Measures
Section 10	Conclusions and Recommendations



2. PROJECT ORGANIZATION AND CONSTRUCTION PROGRESS

2.1 CONSTRUCTION CONTRACT PACKAGING

2.1.1 To facilitate the project management and implementation, the Project was divided by 5 works contracts as described in following. The details of each contract are summarized below and the delineation of each contract is shown in *Appendix A*.

Contract 1 (Contract No. NE/2016/01)

- 2.1.2 Commencement date of Contract 1 was in late December 2016 and the major scope of work of Contract 1 is listed below:
 - Formation of about 40 hectares (ha) of land platforms at the ARQ site and the associated geotechnical works;
 - Road works including construction of approximately 3-kilometer long vehicular roads, footpaths, cycle tracks, an approximately 130-meter long underpass at the southern end an a public transport terminus at the northern end at the ARQ site;
 - Provision of and improvement to water supply, drainage and sewerage systems as well as landscaping works; and
 - Construction of proposed subway structures and lift tower structures of pedestrian connectivity facilities.

Contract 2 (Contract No. NE/2016/05)

- 2.1.3 Commencement date of Contract 2 was 31 March 2017 and the major Scope of Work of the Contract 2 is listed below:
 - (i) Construction of the following pedestrian connectivity facilities with covered elevated walkways, covered at grad walkways, escalators, life towers with associate staircase and lifts:-
 - (a) Linking Hiu Kwong street with Hiu Ming Street (E1)
 - (b) Linking the proposed "Footbridge Link at Sau Ming Road" with Hiu Ming Street (E2, C1 and E3)
 - (c) Linking the proposed bus-to-bus interchange at Tseung Kwan O Tunnel Toll Plaza with Lin Tak Road (E12)
 - (ii) Construction of bus-to-bus interchange (BBI) at Tseung Kwan O Tunnel Toll Plaza;
 - (iii) Associated landscape works;
 - (iv) Construction of green routes connecting to Jordan Valley Park and Choi Wing Road; and
 - (v) Slope improvement works in the vicinity of Po Lam Road South and other associated works.

Contract 3 (Contract No. NE/2017/03)

- 2.1.4 The commencement date of Contract 3 is on 31 May 2018 and the major Scope of Work of the Contract 3 is listed below:
 - (i) Site formation and road works in the following sections:-
 - (a) at junction of Clear Water Bay Road (CWBR) and On Sau Road constructed under the Development at Anderson Road (DAR) project including the provision of U-turn facility and noise mitigation measures (RIW1);
 - (b) at New Clear Water Bay Road (NCWBR) near Shun Lee Tsuen Road including the road widening works at NCWBR, modification of existing subway structure and provision of noise mitigation measures (RIW2); and
 - (c) at the junction of Lin Tak Road and Sau Mau Ping Road, construction of flyover above Tseung Kwan O Road, provision of loading and unloading bays along Lin Tak Road and noise mitigation measures (RIW3).
 - (ii) construction of the following pedestrian connectivity facilities with covered elevated walkways, escalators and lift towers with associated staircases and lifts:-



- (a) linking Anderson Road Quarry site with the DAR Site (except the works covered under Contract 1) (System A and System B);
- (b) linking Hiu Ming Street with Hiu Yuk Path (E8); and
- (c) linking the proposed bus-bus interchange at Tseung Kwan O Tunnel Toll Plaza with Sau Mau Ping Road (E11).
- (iii) Associated landscape works.

Contract 4 (Contract No. ED/2020/02)

- 2.1.5 The commencement date of Contract 4 is on 27 September 2021 and the major Scope of Work of the Contract 4 is listed below:
 - Construction of hard landscaping and other ancillary works (e.g. paver footpath, planter walls, benches, lighting etc.);
 - Construction of soft landscaping works;
 - Lighting, irrigation, electrical and mechanical engineering works within the landscaping area;
 - Construction of landscape deck; and
 - Electrical and mechanical works for underground water treatment facilities and pumping system for Regional Open Space and Artificial Flood Attenuation Lake.

Contract 5 (Contract No. ED/2019/02)

- 2.1.6 The commencement date of Contract 5 is on 30 March 2021 and the major Scope of Work of the Contract 5 is listed below:
 - Construction of two-way escalator link between Sau Mau Ping Road and the existing footbridge to Po Tat Estate;
 - Construction of two-way escalator link between Sau Mau Ping South Estate and the existing footbridge to Sau Mau Ping Road;
 - Construction of footbridge, 3m, clear width, with and about 20m high lift tower between Hiu Kwong Street and the podium of Sau Ming House, Sau Mau Ping Estate;
 - Construction of footbridge, 3m clear width, with an about 40m high lift tower between Sau Mau Ping Road and the podium of Po Tat Estate; and
 - Ancillary works including associated civil, geotechnical, structural, electrical and mechanical engineering and landscaping works.

2.2 **PROJECT ORGANIZATION**

2.2.1 The project organization and contact details for Contracts 1, 2, 3, 4 and 5 are shown in *Appendix B*.

2.3 CONSTRUCTION PROGRESS

2.3.1 The 3-month rolling construction programme for Contracts 1, 2, 3, 4 and 5 are shown in *Appendix C*. The major construction activities conducted in the Reporting Period are summarized in below.

Contract 1 (NE/2016/01)

East Portal Area:

- RWA1C Bay 2 & 3 base slab completed and Bay 2 stem wall complete and formwork and rebar for bay 4 are in progress.
- Buttress wall (left and right) construction works completed from 164mPD to 172mPD (LHS) and 164mPD to 170mPD (RHS).
- Construction of RWA1B Retaining Wall completed
- Rock dowel at slope A1 164mPD to 169mPD level, drilling holes for rock dowel in progress 48/48nos completed.



- Installation of the cross-ducting pipes complete.
- Laying the WSD 150PE pipe at east portal carriageway and pressure test complete.
- Laying the 2nd road base bitumen complete.
- Bay 4 RWA1c drilling vertical dowel bar completed and L-shaped dowel bar for RWA1c Type 1 buttress wall total 21nos complete.
- Cast concrete of Pillar Box and Kiosk complete and install stone pitch completed
- Formworks for construction 900sc, catchpit and 1000mm downpipe at Slope A1 and 185mPD platform in progress

West Portal Area:

- Buttress wall (left) from 178.5mPD to 186.5mPD complete.
- Buttress wall (right) from 170 to 178mPD in progress at Slope A3 near West Portal.
- Soil nailing works at Slope A3 complete.
- Slope A3, Construction of 200mPD, 186mPd and 178mPD berm in progress.

Underpass Tunnel:

- Tunnel Concrete Lining construction works (Total 25 Bays) included B1 with West portal structure and Bay 25 with East Portal structure, and progress upto Bay 24 (124m), Bay 25 and East Portal structure (excluding headwall) completed west portal structure completed and construction of headwall completed, construction of headwall at East Portal completed.
- Excavation for Box Culvert BC3 completed and structure works completed.
- Erection and installation of the VE Panel sub-frame in progress and 95% complete.
- Construction of mass concrete wall in underpass completed 260m/260m.
- Painting the 1st ,2nd & 3rd layer on lining structure completed.
- Installation of the profile barrier inside underpass (LHS and RHS) completed 260m/260m.
- Rock excavation of Manhole A4 and 900mm stormwater drainage pipe completed at East Portal and construction of manhole A4 with backdrop completed and laying of 900mm pipe completed.
- Excavation works for manhole R618 to R623 completed and installation of manholes R618 to R623 completed.
- Laying of 300mm thick drainage layer,225mm thick subbase and geotextile complete.
- Laying road base bituminous insider underpass complete

Po Lam Road

- Excavation work and install ducting pipes and draw pits and installation of k1 kerb completed
- Removal the existing concrete pavement completed for installation of ducting crossing pipes.
- Reinstatement of the concrete carriageway at Po Lam road at stage 3 in progress.
- Re-build the modification catch pit at Po Lam road and Slope A1 complete.
- 900sc excavation work completed
- Structure works for traffic sign board footing DS01 and polar mount footing complete.
- Installation of the beam barrier at Po Lam Road Layby complete
- Installation of 2 of 3 no of lighting complete at Po Lam Road
- Stage 2 TTA at Po Lam Road implemented and completed
- Installation of 3nos manholes and gully complete
- Construction double island and concrete carriageway completed at stage 3
- Reinstatement works of temporary footpath are completed
- Installation of detector loop at Po Lam Road in progress

Internal Road L4, RWA18, RWA12, Noise Barrier and Pedestrian Connectivity System A (PC System A):

- Filling grade 200 completed.
- Noise barriers RC and steel structure completed & backfill complete.



• DN300 fresh watermain, NS125 salt watermain and fibre optic cable laying CHC-10 to CHC390 completed. Pressure test and swabbing for CHC-10 to CHC390 complete.

- Laying wearing course of flexible pavement complete.
- Excavation and installation of road lighting ducting and drawpits complete.
- K1 kerb installation at CH130 to CH440 complete.
- Laying subbase layer for footpath at CH180 to CH430 complete.
- Paving works at footpath at CH100 to CH430 complete.
- Construction of mass concrete and u-channel in front of noise barrier complete from Bay 1 to Bay 33.
- Hand railing installation at mass concrete in front of noise barrier completed.
- Replacement of existing downpipes connecting to new as-built catchpit completed
- Kerb installation and road base bituminous laying at Ch495- Ch565 complete.
- Concrete pavement laying work at Ch495- Ch565 in progress.

Retaining Wall RWA18

- Storm drain & manhole M35-4 to S007C, R426 to M35-4 BD and R429 to M35-4BD complete, Gully of S002 to S007B & R426 to R429 complete.
- Construction of DN 450 Sewage Pipe from existing manhole to B223 complete, Manhole B223 to B229a complete
- Laying of wearing course of flexible pavement at CH100 to CH130 complete.
- K1 kerb installation at CH100 to CH130 complete.
- Additional buttress wall complete.
- Installation of steel parapet at RWA18 complete.
- Traffic controller relocation for signalized junction completed.
- Installation of type 2 railing at junction of Road L4 and On Sau Road complete.
- Paving works at junction of Road L4 and On Sau Road complete.
- U-channel construction between SC42a to existing catchpit complete.
- Concrete apron between U-channel and existing slope completed (CH100 to CH395).

Water Reservoir:

- The water tightness test for Salt Water Reservoir complete and passed and Fresh Water Reservoir water tightness test complete and pass, defect rectification works completed.
- Rock excavation work to formation level outside water reservoir completed and soil excavation work (to formation level) completed. Rock excavation for drainage works completed. Manhole construction and Drainage Pipe laying are completed, Backfilling works completed. The excavation works of VC chambers (Watermain) and additional dia.600mm drainage pipe with manhole completed. The construction of recorder houses complete. The construction of valve chamber completed and watermain laying almost completed.
- Rock trench excavation for watermain and utilities along WSD access road completed.
- Pipe laying along WSD access road complete.
- Concreting of pipe plinths and staircase for downpipe from reservoir to PTT was completed. Downpipe installation from ~210mPD to 230mPD complete.
- Downpipe installation from PTT to Reservoir completed.
- Water pressure test for DN250 Downpipe completed.

Water Pumping Station, Retaining Wall RWA13 and RWA14:

- Backfill retaining wall RWA13 and RWA14 Bay 9-14 complete.
- Rock excavation for Watermain works completed. The chambers (VC8, VC9, EFM & DN450 valve) construction works pipe laying complete.
- Metal Works and ABWF Work are completed. E&M Works at Water Pumping Station in progress.
- Mapping works and excavation of A13 Slope completed. Mass concrete fill works (VO/238) complete.
- Pipe laying of watermain behind retaining wall RWA13 was completed.
- Excavation and construction work of drawpit and ducting works complete.



- Excavation work and construction work of Boundary Fence Footing in progress.
- Rock breaking to road formation level completed. Rock breaking to bedding level of watermain from pumping station to RWA13 complete.
- All watermains from pumping station to RWA13 complete.
- Stone Block Facing Works for RWA13 in progress.
- Pipe laying along WSD access road completed.
- Water pressure test and swabbing for CHE0 to CHE516 completed
- Drainage works inside boundary of Pumping Station in progress.

Artificial Flood Attenuation Lake

- East side and west side of concrete lining at Lake bottom complete. Remaining part (near Bay 50-51) completed.
- Laying granular bed at remaining parts (center) of Lake bottom complete.
- Laying HDPE membrane at center of Lake bottom completed.
- Retaining wall base slab complete and stem wall complete.
- Whole Treatment Plant construction complete.
- Drainage work at hill side complete. To continue the remaining part(S114 and drainpipe direct to existing catchpit).
- The footing with guidepost of floating bridge, retaining wall & all landing are complete.
- The additional 150mm thk mass concrete slab under floating bridge is in progress.
- The additional guide post extension in progress.
- The floating bridge installation in progress.

Pedestrian Connectivity System B (PC System B):

- PC System B structure complete, South Tower structure Rock fill completed.
- 1050mm dia. pipe from M/H S311 to S312 installation completed.
- Internal ABWF works in System B in progress

Construction of Internal Road L1:

- Road breaking and drainage works for road L1 west in progress.
- Drainage works for road L1 east cycle track in progress.
- Watermain construction in progress, 90 % complete. All rock breaking for watermain at L1 west completed.
- Road L1 west lower level and middle level drainage construction in progress lower drainage complete middle drainage 90%, upper level 75% and gully pipe installation in progress.
- Road L1 east lower level and middle level drainage construction in progress lower drainage completed 100% middle drainage 95%, upper level and gully pipe complete.
- Construction of Infiltration Planter in Progress, and 98% completed.
- Kerb laying, asphalt paving in progress.
- Formation of footpath and cycle track in progress.
- Planter construction and soil mix filling in progress.

Box Culvert BC2 at Internal Road L3:

- AMH5 to BC2 pipe laying and manhole construction completed, backfilling complete.
- Drainage at junction L1 and L3 completed, total drainage of L3 road in progress 90% complete
- Watermain trenching and pipe installation at L1 and L3 junction complete.
- UU laying complete.
- Installation of Multi-part cover in progress.
- Cat ladder installation complete.

MEP Works:

- i. Submission of designs and materials related to MEP works to continue.
- ii. E&M installation works at PTT to continue.
- iii. E&M installation works at Underground Stormwater Retention Tank to continue.



- iv. E&M installation works at Pedestrian Connectivity System B to continue.
- v. Lighting installation works at Pedestrian Connectivity System B completed.
- vi. Sump Pump installation works at Pedestrian Connectivity System B completed.
- vii. E&M installation works at Underpass to continue.
- viii. Cable & Lighting Supporting Frame installation works at Underpass completed.
- ix. E&M installation works at Fresh Water Pumping station to continue.
- x. Road lighting fitting installation at Underpass complete.
- xi. Road lighting fitting installation at Public Transport Terminus complete.
- xii. E&M installation works at Pillar Box (East portal) to continue.
- xiii. E&M installation works at the cleansing pump room (Fresh Water Pumping Station) to continue.
- xiv. E&M installation works at the EMF & valve chamber VC8 (Fresh Water Pumping Station) to continue.
- xv. T&C of Fresh Water Pumping Station to continue.
- xvi. E&M installation works at the Service Reservoir to continue.
- xvii. E&M installation works at Pillar Box (West portal) to continue.
- xviii. E&M installation works at F.S. Kiosk (East portal) to continue.

Existing Anderson Road:

- Temporary slope protection works for pipe trough excavation completed.
- Pipe trough construction completed.
- Watermain laying from CHD0~424 completed.
- Water pressure test and swabbing for CHD0~424 completed.
- Trial pits at watermain connection point were excavated to identify existing water pipes. Water connection to be carried out by WSD in late-Jan.

<u>Hiking Trail</u>

- Site Clearance in progress from CH470 to 1000.
- Construction of footpath and staircase in progress from CH1000 to 1910.
- Site clearance is in progressing at B5 due to adverse weather
- Hydroseeding of Hiking Trial completed.

Contract 2 (NE/2016/05)

- Temporary Traffic Arrangement (TTA)
- Soil Nail Construction
- Mass Concrete construction
- Formwork and Falsework installation and dismantling
- Escalator Installation and lifting Tower Construction
- Rebar fixing

Contract 3 (NE/2017/03)

Works in Road Improvement Works 1 (RIW1)

- Construct RC works & backfilling at Type 2 are in-progress.
- Construct socketed H pile at RWC2 Type 3 for piling construction are in-progress; Rock excavation at RWC2 Type 3 are in-progress.
- Preparation works of drainage diversion at Type 4 is in-progress.
- Backfilling works at Type 6 to 8 is in-progress.
- Mini-pile works at FE1-PC1b is in-progress.
- Excavate trial pit works at CT5 is in-progress.
- Drainage works at KS27 (West Side) also is in-progress; Install sheet pile & ELS works at KS27 (East Side) near Shun Lee Estate.

Works in Road Improvement Works 2 (RIW2)

Construct RC works at RWC3b; Rock excavation & ELS works at RWC3b are



in-progress.

- Install pipe pile wall at CT4 roadside is in-progress.
- Construct mini-pile works at SE2 (hill side toward Sai Keung direction) is in-progress; Excavate for expose utilities and utilities protection / diversion are in-progress.

Works in Road Improvement Works 3 (RIW3)

- Excavate trial pits at Sau Mui Ping Road / Lin Tak Road for watermain alignment confirmation in-progress.
- Concreting and backfilling works at RWD1 Bay 1 10.
- ELS works at RWD1 Bay 11 14 is in-progress.
- Rock excavate at Slope D1 lower portion is in-progress.
- Road works and backfilling works at Slope D2 are in-progress.
- Rock excavation using drill & split method, drainage works and road works at Slope D3 / Lin Tak Road are in-progress.

Pedestrian Connectivity Facility E8 (PC-E8)

• Touch-up outstanding works are in progress.

Pedestrian Connectivity Facility E11 (PC-E11)

- ABWF works and E&M works at LT2 & ST2 are in-progress.
- ABWF works and E&M works at LT1 & ST1 are in-progress.
- ABWF work and E&M works inside the footbridge steel frame are in-progress.

Pedestrian Connectivity Facilities Systems A (PC-SYA)

- ABWF works and E&M works at LT1, LT2 & ST1 are in-progress.
- Erect steel works inside RC structure is in-progress.

Pedestrian Connectivity Facilities Systems B (PC-SYB)

- RC works at SyB-LT1 & ST1 is in-progress.
- Construct pile cap at PC4 & PC6 are in-progress.
- Install sheet-pile and excavation works at PC1 are in-progress.

Tseung Kwan O Bus-Bus Interchange New Public Toilet (BBI-Toilet)

• The completed toilet was handed over to Food and Environmental Hygiene Department on 30 September 2020; Additional works under an instruction is in-progress.

Contract 4 (ED/2020/02)

- Completion of CRE Office & Chainlink Fence
- Completion of GI works at Portion 14 and Commence GI works at Portion 3
- Complete Modification of RWA10 Footing
- Site Drainage work at Portion 2a, 8 and 12
- Site Formation work at Portion 8
- Hard Landscaping at Portion 2b (Gabion, rockfill, stone facing)
- Construction of Staircase, U-channel repairing work, Railing Installation at Portion 10

Contract 5 (ED/2019/02)

Portion 1

- Piling Platform at E5 PC1
- Retaining Wall breaking at E5 PC2
- Mobilization of 55T Crawler Crane at E5 PC1
- Drainage System for E5 Water License

Portion 2

- Welding Test
- Piling Works
- Grouting Works



Portion 3

• Trial Pit for CLP cable slewing <u>Portion 4</u>

- Preparation for blinding at E10 F3
- Protection of rock dowel bar at E10 F1
- 2.3.3 Summary of the relevant permits, licenses, and/or notifications on environmental protection for the Project of contracts 1, 2, 3, 4 and 5 are presented in *Tables 2-1, 2-2, 2-3, 2-4 and 2-5*.

		License/Permit Status			
Item	Description	Permit no./ account	Valid Pe	riod	64-4
		no./ Ref. no.	From	То	Status
1	Form NA – Notification pursuant to Air pollution Control (Construction Dust) Regulation	EPD ref. no. 411762	NA	NA	Valid
	Form NB – Notification pursuant to Air pollution Control (Construction Dust) Regulation	EPD ref. no. 412730	NA	NA	Valid
2	Chemical Waste Producer Registration	Registration no. WPN 5213-292-C4115-01	15 Feb 17	End of project	Valid
3	Water Pollution Control Ordinance – Discharge License	WT00028050-2017	29 May 17	31 May 22	Valid
4	WasteDisposalRegulation–BillingAccount for Disposal ofConstruction Waste	Account no. 7026925	20 Jan 17	End of project	Valid
5	Construction Noise Permit	GW-RE0166-22	2 Mar 22	16 Aug 22	Valid
		GW-RE1335-21	26 Jan 22	25 Jul 22	Valid
		GW-RE0035-22	24 Jan 22	22 Apr 22	Valid

 Table 2-1
 Status of Environmental Licenses and Permits of the Contract 1

Table 2-2 Status of Environmental Licenses and Permits of the Contract 2

		License/Permit Status					
Item	Description	Permit no./ account	Valid	64-4			
		no./ Ref. no.	From	То	Status		
1	Notification pursuant to Air pollution Control (Construction Dust) Regulation	EPD ref. no. 312173	NA	NA	Valid		
2	Chemical Waste Producer Registration	Registration no. WPN 5213-294-K2890-08	7 Jul 17	End of Project	Valid		
3	Water Pollution Control Ordinance – Discharge	WT00028685-2017	02 Aug 17	31 Aug 22	Valid		
	License	WT00028686-2017	02 Aug 17	31 Aug 22	Valid		



Monthly Environmental Monitoring & Audit Report (February 2022)

		License/Permit Status					
Item	Description	Permit no./ account	Valid	64-4			
		no./ Ref. no.	From	То	Status		
		WT00028687-2017	02 Aug 17	31 Aug 22	Valid		
4	WasteDisposalRegulation– BillingAccount for Disposal ofConstruction Waste	Account no.7027548	12 Apr 17	End of project	Valid		

Status of Environmental Licenses and Permits of the Contract 3 Table 2-3

		License/Permit Status			
Item	Description	Permit no./ account	Valid	Period	Status
		no./ Ref. no.	From	То	
1	Form NA – Notification pursuant to Air Pollution Control (Construction Dust) Regulation	EPD ref. no. 434186	31-May-18	NA	Valid
2	Chemical Waste Producer Registration	For Area R1W3 (E11) Registration no. WPN : 5213-294-C4239-04 For Area System A	6-Aug-18 6-Aug-18	End of Project End of	Valid Valid
		Registration no. WPN: 5213-293-C4239-05		Project	
		For Area System B Registration no. WPN 5213-294-C4239-03	6-Aug-18	End of Project	Valid
		For Area E8 Registration no. WPN 5213-292-C4239-06	6-Aug-18	End of Project	Valid
3	WaterPollutionControlOrdinance	For Area R1W3 (E11) WT00032742-2018	18-Jan-19	31-Jan-24	Valid
	– Discharge License	For Area System A WT00033223-2019	31-Jan-19	31-Jan-24	Valid
		For Area System B WT00033229-2019	24-Jun-19	30-Jun-24	Valid
		For Area E8 WT00033224-2019	21-Mar-19	31-Mar-24	Valid
4	Waste Disposal Regulation – Billing Account for Disposal of Construction Waste	Account no.7031075	20-Jun-18	End of project	Valid

Table 2-4 Status of Environmental Licenses and Permits of the Contract 4

	Description		License/Permit Status			
Item			Permit no./ account	Valid	Period	Status
			no./ Ref. no.	From	То	
1	Form NA	_	EPD ref. no. 470496	19 August	NA	Valid
	Notification			2021		
	pursuant to	Air				



Monthly Environmental Monitoring & Audit Report (February 2022)

		License/Permit Status			
Item	Description	Permit no./ account	Valid	Period	Status
		no./ Ref. no.	From	То	
	Pollution Control				
	(Construction Dust)				
	Regulation				
2	Waste Disposal	Account no. 7041336	6	NA	Valid
	Regulation –		September		
	Billing Account for		2021		
	Disposal of				
	Construction Waste				
3	Chemical Waste	Registration no.	14	End of	
	Producer	WPN 5213-296-C1206-12	September	project	Valid
	Registration		21		
4	Water Pollution				
	Control Ordinance	Working in Progress			
	– Discharge	working in Flogress			
	License				

Table 2-5	Status of Environmental Licenses and Permits of the Contract 5

	License/Permit Status			tus	
Item	Description	Permit no./ account	Valid	Period	Status
		no./ Ref. no.	From	То	
1	Form NA – Notification pursuant to Air Pollution Control (Construction Dust) Regulation	EPD ref. no. 466255	NA	NA	Valid
2	Chemical Waste Producer Registration	Registration no. WPN 5298-293-W3611-01	12 May 21	End of project	Valid
3	WaterPollutionControlOrdinance-DischargeLicense	WT00039694-2021	16 Nov 21	30 Nov 26	Valid
4	Waste Disposal Regulation – Billing Account for Disposal of Construction Waste	Working in Progress			



3. SUMMARY OF IMPACT MONITORING REQUIREMENTS

3.1 GENERAL

- 3.1.1 The Environmental Monitoring and Audit requirements are set out in the Approved EM&A manual. Environmental issues such as air quality, construction noise and water quality were identified as the key issues during the construction phase of the Project.
- 3.1.2 A summary of construction phase EM&A requirements are presented in the sub-sections below.

3.2 MONITORING PARAMETERS

THE EM&A PROGRAM OF CONSTRUCTION PHASE MONITORING SHALL COVER THE FOLLOWING ENVIRONMENTAL ISSUES:

- Air quality; and
- Construction noise

3.2.1 A summary of the monitoring parameters is presented in *Table 3-1*.

Table 3-1Summary of EM&A Requirements

Environmental Issue	Parameters
Air Quality	 1-hour TSP by Real-Time Portable Dust Meter; and 24 hour TSP by High Volume Air Sampler
	 Leq(30min) in normal working days (Monday to Saturday) 07:00-19:00 except public holiday
Noise	• Supplementary information for data auditing, statistical results such as L ₁₀ and L ₉₀ shall also be obtained for reference.

3.3 MONITORING LOCATIONS

3.3.1 According to the EM&A Manual Section 4.6, seven (7) most representative and affected air sensitive receivers (ASR) were selected as air monitoring stations (AQM). During site visit at the subject site before the baseline monitoring, it was noted that some planned ASRs identified in the EM&A Manual are still under construction/ has not yet constructed and there were no suitable location to set up the high volume sampler to carry out the baseline 24-hour TSP monitoring. Therefore, a proposed change for the baseline monitoring programme was submitted and agreed by EPD before the baseline monitoring. The impact air quality monitoring locations are listed in *Table 3-2* and illustrated in *Appendix D*.

Table 3-2	Impact Monitoring Stations – Air Quality
-----------	--

ID	ASR ID	Location in the	Identified Location during	Status
ID	in EIA	EM&A Manual	Site Visit	
AMS-1	ACYC-01	Chi Yum Ching	Ground of Chi Yum Ching	Replaced by
		She	facing the project site	AMS-1a
AMS-1a (*)	ACYC-01	Tan Shan	Ground of Tan Shan Village	Active
		Village No. 5 - 6	No. 5 - 6 facing the project site	
AMS-2 (#)	DARB-13	Block 8, Site B	Ground of Fung Tai House of	Active
			On Tai Estate	
AMS-3 (:)	DARC-16	Planned Clinic	Ground of Planned Clinic and	Active
		and Community	Community Centre facing	
		Centre, Site C2	Anderson Road (Ancillary	
			Facilities Building)	
AMS-4	DARC-26	Planned School,	Ground of Planned School	Not yet
		Site C2 Note 1	facing Anderson Road	commenced
AMS-5	DARE-06	Block 5, DAR	Main roof of Oi Tat House of	Active
		Site E	On Tat Estate facing the	



Monthly Environmental Monitoring & Audit Report (February 2022)

ID	ASR ID in EIA	Location in the EM&A Manual	Identified Location during Site Visit	Status
			project site	
AMS-6	DARE-17	Block 9, Site E	Main roof of Hau Tat House of	Active
			On Tat Estate facing the	
			project site	
AMS-7	AMYT-04	Ma Yau Tong	Balcony at 2 nd floor of Village	Active
		Village	House Anderson Road No. 1	
			facing the project site	

Note 1: The ASR is under construction.

(#) AMS-2 was activated on 26 November 2018 since Fung Tai House became an air sensitive receiver. 1-hour TSP monitoring was commenced on 26 November 2018 while installation of HVS for 24-hour TSP was pending approval from Housing Authority.

(*) 24-hour TSP monitoring at AMS1 was abandoned since May 2019 due to lack of power supply and the landlord was unreachable. The alternation location of AMS1a was activated on 15 June 2019 for 1-hour and 24-hour TSP monitoring. The proposal was agreed by EPD on 9 Aug 2019. (:) AMS-3 was effective on 3 December 2019.

Construction Noise

3.3.2 According to the EM&A Manual Section 5.5, three (3) most representative and affected noise sensitive receivers (NSR) were selected as monitoring stations. As recommended by the RE and agreed by IEC, one (1) additional noise monitoring location is proposed to add in Oi Tat House of On Tat Estate (hereafter "NMS-4") to oversee the possible noise impact pose to the resident in On Tat Estate, which is an existing NSR close to the major works activities. Moreover, review of impact monitoring location was proposed to IEC in view of the current site condition and it was agreed by all parties. The details of noise monitoring location are listed in Table 3-3 and illustrated in Appendix D.

ID	NSR ID in EIA	Location	Status
NMS-1	Site C2 –	Ground of planned school at DAR facing	Not yet
	School 05 Note 1	the project site	commenced
NMS-2	Site E – School	Rooftop of S.K.H. St. John's Tsang Shiu	Active
(@)		Tim Primary School, where 1m from the	
		exterior of the building facing the project	
		site	
NMS-3(:	Site C2 – R102-	Ground of Ancillary Facilities Building	Active
)		facing the project site	
NMS-4*	Oi Tat House	1m from the exterior of ground floor	Suspended
		façade of Oi Tat House of On Tat Estate	
		facing the project site	
NMS-4a	Oi Tat House	Rooftop of Oi Tat House where 1m from	Active
#		the exterior of Oi Tat House facing the	
		project site	
NMS-5#	Hau Tat House	22/F, refuge floor of Hau Tat House where	Active
		1m from the exterior of Hau Tat House	
		facing the project site.	
NMS-6~	Yung Tai	Rooftop of Yung Tai House where 1m	Active
	House of On	from the exterior of the building facing	
	Tai Estate	the project site)	
NMS-7~	Chi Tai House	Rooftop of Chi Tai House where 1m from	Active
	of On Tai	the exterior of the building facing the	
	Estate	project site	

Table 3-3 **Impact Monitoring Stations – Construction Noise**



Monthly Environmental Monitoring & Audit Report (February 2022)

ID	NSR ID in EIA	Location	Status
NMS-8^	No. 3-4 Ma Yau Tong Village	1m from the exterior of the building façade and facing the construction site	Active

Note 1: Construction of the NSR is not yet commenced.

- (*) Additional noise monitoring location was recommended by RE and agreed by IEC. It was temporary suspended and the monitoring location is relocated to NMS4a with effective on 15 Nov 2017.
- (@) NMS-2 was effective on 15 November 2019.
- (:) NMS-3 was effective on 3 December 2019
- (#) Review of noise monitoring locations was proposed by ET and NMS-5 was effective on 15 November 2017.
- (~) Review of noise monitoring locations was proposed by ET and NMS-6 and NMS-7 were effective on 28 Feb 2018.
- () Review of noise monitoring locations was proposed by ET and NMS-8 was effective on 18 April 2018. Noise monitoring at NMS-8 was started on 3 May 2018 upon commencement of construction at relevant section.

Addition Construction Noise Monitoring Location

3.3.3 A Work Instruction was issued from AECOM to AUES in November 2018 for installing three additional noise monitoring stations under Contract 3. According to the Work Instruction, one noise monitoring station was proposed to install at System A Area and two station monitoring points were proposed to install at E8 Area. The noise monitoring locations are shown in *Table* 3-4 below and illustrated in Appendix D.

ID	Location	Description
CN1	Holm Glad	Ground floor of Holm Glad College, where 1m from the
CIVI	College	exterior of the building facing E8
CN2	Leung Shek Chee	Ground floor of Leung Shek Chee College, where 1m from
CN2	College	the exterior of the building facing E8
CN2	Oi Tat House of	Ground floor of Oi Tat House of On Tat Estate, where 1m
CINS	On Tat Estate	from the exterior of the building facing System A

Additional Impact Monitoring Stations – Construction Noise Table 3-4

3.4 MONITORING FREQUENCY AND PERIOD

3.4.1 The requirements of impact monitoring in the approved EM&A Manual and presented as follows.

Air Quality Monitoring

- 3.4.2 Frequency of impact air quality monitoring is as follows:
 - 3 times every six days during course of works throughout the construction 1-hour TSP period
 - 24-hour TSP Once every 6 days during course of works throughout the construction period

Noise Monitoring

- 3.4.3 Noise monitoring will be to conduct at the all available designated monitoring stations. The monitoring frequency shall depend on the scale of the construction activities. The following is an initial guide on the regular monitoring frequency for each station on a weekly basis when noise generating activities are underway:
 - one set of Leq_(30min) measurements between 07:00 and 19:00 hours on normal weekdays



3.5 MONITORING EQUIPMENT

Air Quality Monitoring

3.5.1 The 24-hour and 1-hour TSP levels shall be measured by following the standard high volume sampling method as set out in the *Title 40 of the Code of Federal Regulations, Chapter 1 (Part 50)*, Appendix *B*. If the ET proposes to use a direct reading dust meter to measure 1-hour TSP levels, it shall submit sufficient information to the IEC to prove that the instrument is capable of achieving a comparable results to the HVS. The instrument should be calibrated regularly, and the 1-hour sampling shall be determined on yearly basis by the HVS to check the validity and accuracy of the results measured by direct reading method. The filter paper of 24-hour TSP measurement shall be determined by HOKLAS accredited laboratory.

3.5.2 All equipment to be used for air quality monitoring is listed in *Table 3-5*.

	Equipment	Model
24-hour TSP	High Volume Air Sampler	TISCH High Volume Air Sampler, HVS Model TE-5170
	Calibration Kit	TISCH Model TE-5025A
1- hour TSP	Portable Dust Meter	Sibata LD-3B Laser Dust Monitor

Table 3-5Air Quality Monitoring Equipment

Noise Monitoring

- 3.5.3 Sound level meter in compliance with the International Electrotechnical Commission Publications 651: 1979 (Type 1) and 804: 1985 (Type 1) specifications shall be used for carrying out the noise monitoring. The sound level meter shall be checked using an acoustic calibrator. The wind speed shall be checked with a portable wind speed meter capable of measuring the wind speed in ms⁻¹.
- 3.5.4 Noise equipment as perform for construction phase monitoring is listed in *Table 3-6*.

Table 3-6Construction Noise Monitoring Equipment

Equipment	Model
Integrating Sound Level Meter	B&K 2238, NL-52
Calibrator	Rion NC-74
Portable Wind Speed Indicator	Anemometer AZ Instrument 8908

3.6 MONITORING METHODOLOGY

1-hour TSP

- 3.6.1 The 1-hour TSP monitor was a brand named "Sibata LD-3 Laser Dust monitor Particle Mass Profiler & Counter" which is a portable, battery-operated laser photometer. The 1-hour TSP meter provides a real time 1-hour TSP measurement based on 90° light scattering. The 1-hour TSP monitor consists of the following:
 - (a.) A pump to draw sample aerosol through the optic chamber where TSP is measured;
 - (b.) A sheath air system to isolate the aerosol in the chamber to keep the optics clean for maximum reliability; and
 - (c.) A built-in data logger compatible with Windows based program to facilitate data collection, analysis and reporting.
- 3.6.2 The 1-hour TSP meter to be used will be within the valid period, calibrated by the manufacturer prior to purchasing. Zero response of the instrument will be checked before and after each monitoring event.



24-hour TSP

- 3.6.3 The equipment used for 24-hour TSP measurement is Thermo Andersen Model GS2310 TSP high volume air sampling system, which complied with *EPA Code of Federal Regulation*, *Appendix B to Part 50*. The High Volume Air Sampler (HVS) consists of the following:
 - (a.) An anodized aluminum shelter;
 - (b.) A 8"x10" stainless steel filter holder;
 - (c.) A blower motor assembly;
 - (d.) A continuous flow/pressure recorder;
 - (e.) A motor speed-voltage control/elapsed time indicator;
 - (f.) A 7-day mechanical timer, and
 - (g.) A power supply of 220v/50 Hz
- 3.6.4 For HVS for 24-hour TSP monitoring, the HVS is mounted in a metallic cage with a top for protection and also it is sat on the existing ground or the roof of building. The flow rate of the HVS between 0.6m³/min and 1.7m³/min will be properly set in accordance with the manufacturer's instruction to within the range recommended in *EPA Code of Federal Regulation, Appendix B to Part 50*. Glass Fiber Filter 8" x 10" of TE-653 will be used for 24-Hour TSP monitoring and would be supplied by laboratory. The general procedures of sampling are described as below:-
 - A horizontal platform with appropriate support to secure the samples against gusty wind should be provided;
 - No two samplers should be placed less than 2 meters apart;
 - The distance between the sampler and an obstacle, such as building, must be at least twice the height that the obstacle protrudes above the sample;
 - A minimum of 2 meters of separation from any supporting structure, measured horizontally is required;
 - Before placing any filter media at the HVS, the power supply will be checked to ensure the sampler work properly;
 - The filter paper will be set to align on the screen of HVS to ensure that the gasket formed an air tight seal on the outer edges of the filter. Then filter holder frame will be tightened to the filter hold with swing bolts. The holding pressure should be sufficient to avoid air leakage at the edge;
 - The mechanical timer will be set for a sampling period of 24 hours (00:00 mid-night to 00:00 mid-night next day). Information will be recorded on the field data sheet, which would be included the sampling data, starting time, the weather condition at current and the filter paper ID with the initial weight;
 - After sampling, the filter paper will be collected and transfer from the filter holder of the HVS to a sealed envelope and sent to a local HOKLAS accredited laboratory for quantifying.
- 3.6.5 All the sampled 24-hour TSP filters will be kept in normal air conditioned room conditions, i.e. 70% HR (Relative Humidity) and 25°C, for six months prior to disposal.
- 3.6.6 The HVS used for 24-hour TSP monitoring will be calibrated before the commencement for sampling, and after in two months interval for 1 point checking of maintenance and six months interval for five points calibrate in accordance with the manufacturer's instruction using the NIST-certified standard calibrator (Tisch Calibration Kit Model TE-5025A) to establish a relationship between the follow recorder meter reading in cfm (cubic feet per minute) and the standard flow rate, Qstd, in m³/min. Motor brushes of HVS will be regularly replaced of about five hundred hours per time. The calibration certificates of all monitoring equipment used for the impact monitoring program in the Reporting Period and the HOKLAS accredited certificate of laboratory are attached in *Appendix E*.



<u>Noise Monitoring</u>

- 3.6.7 As referred to in the Technical Memorandum (TM) issued under the NCO, sound level meters in compliance with the International Electrotechnical Commission Publications 651: 1979 (Type 1) and 804:1985 (Type 1) specifications shall be used for carrying out the noise monitoring. Immediately prior to and following each noise measurement the accuracy of the sound level meter shall be checked using an acoustic calibrator generating a known sound pressure level at a known frequency. Measurements may be accepted as valid only if the calibration levels from before and after the noise measurement agree to within 1.0 dB.
- 3.6.8 All noise measurements will be performed with the meter set to FAST response and on the A-weighted equivalent continuous sound pressure level (Leq). Leq_(30 min) in six consecutive Leq_(5 min) measurements will be used as the monitoring parameter for the time period between 07:00-19:00 hours on weekdays throughout the construction period.
- 3.6.9 The sound level meter will be mounted d on a tripod at a height of 1.2 m and placed at the assessment point and oriented such that the microphone is pointed to the site with the microphone facing perpendicular to the line of sight. The windshield will be fitted for all measurements. Where a measurement is to be carried out at a building, the assessment point would normally be at a position 1 m from the exterior of the building façade. Where a measurement is to be made for noise being received at a place other than a building, the assessment point would be at a position 1.2 m above the ground in a free-field situation, i.e. at least 3.5 m away from reflective surfaces such as adjacent buildings or walls.
- 3.6.10 Immediately prior to and following each noise measurement the accuracy of the sound level meter will be checked using an acoustic calibrator generating a known sound pressure level at a known frequency. Measurements will be accepted as valid only if the calibration level from before and after the noise measurement agrees to within 1.0 dB.
- 3.6.11 Noise measurements will not be made in fog, rain, wind with a steady speed exceeding 5m/s or wind with gusts exceeding 10m/s. The wind speed will be checked with a portable wind speed meter capable of measuring the wind speed in m/s.
- 3.6.12 The sound level meter and calibrator are calibrated and certified by a laboratory accredited under HOKLAS or any other international accreditation scheme at yearly basis. The calibration certificates of all monitoring equipment used for the impact monitoring program in the Reporting Period is attached in *Appendix E*.

Meteorological Information

3.6.13 The meteorological information including wind direction, wind speed, humidity, rainfall, air pressure and temperature etc. during baseline monitoring is extracted from the closest Hong Kong Observatory Station. To obtain the most appropriate meteorological information where available, the data of temperature is extracted from the Kwun Tong Observatory Station; the data of wind speed and wind direction are extracted from Kai Tak Observatory Station and the data of humidity is extracted from King's Park Station.

3.7 DERIVATION OF ACTION/LIMIT (A/L) LEVELS

3.7.1 The baseline results form the basis for determining the environmental acceptance criteria for the impact monitoring. According to the approved Environmental Monitoring and Audit Manual, the air quality, construction noise were set up, namely Action and Limit levels are listed in *Tables 3-7 and 3-8*.

Table 3-7	Action and I	Limit Leve	ls for Air (Duality Monitoring

Monitoring Station	Action Lev	vel (µg /m ³)	Limit Lev	vel (µg/m ³)
Monitoring Station	1-hour TSP	24-hour TSP	1-hour TSP	24-hour TSP
AMS-1	313	154	500	260



Monthly Environmental Monitoring & Audit Report (February 2022)

Monitoring Station	Action Lev	vel ($\mu g / m^3$)	Limit Lev	rel (µg/m ³)
Monitoring Station	1-hour TSP	24-hour TSP	1-hour TSP	24-hour TSP
AMS-1a(*)	313	154	500	260
AMS-2	319	165	500	260
AMS-3	319	165	500	260
AMS-4	315	165	500	260
AMS-5	299	166	500	260
AMS-6	303	168	500	260
AMS-7	307	156	500	260

(*) 24-hour TSP monitoring at AMS1 was abandoned since May 2019 due to lack of power supply and the landlord was unreachable. The alternation location of AMS1a was activated on 15 June 2019 for 1-hour and 24-hour TSP monitoring. The proposal was agreed by EPD on 9 Aug 2019.

Table 3-8	Action and	Limit L	evels for (Construction	Noise

Monitoring Location	Action Level	Limit Level in dB(A)
Monitoring Location	Time Period: 0700-1900 ho	ours on normal weekdays
NMS-1		70 $d\mathbf{P}(\mathbf{A})^{\text{Note } 1}$ 65 $d\mathbf{P}(\mathbf{A})^{\text{Note } 1}$
NMS-2 (@)		70 dB(A) = 703 dB(A)
NMS-3(:)		75 dB(A)
NMS-4*		75 dB(A)
NMS-4a#		75 dB(A)
NMS-5#	When one or more documented	75 dB(A)
NMS-6~	complaints are received	75 dB(A)
NMS-7~		75 dB(A)
NMS-8^		75 dB(A)
CN1+		70 dB(A) ^{Note 1} / 65 dB(A) ^{Note 1}
CN2+		70 dB(A) ^{Note 1} / 65 dB(A) ^{Note 1}
CN3 +		75 dB(A)

Noise Limit Levels for school is 70dB(A) and should be reduced to 65dB(A) during Note 1: examination period.

Note: If works are to be carried out during restricted hours, the conditions stipulated in the construction noise permit issued by the Noise Control Authority have to be followed.

(*) Additional noise monitoring location was recommended by RE and agreed by IEC. It was Remark: temporary suspended and the monitoring location is relocated to NMS4a with effective on 15 Nov 2017.

(@) NMS-2 was effective on 15 November 2019.

(:) NMS-3 was effective on 3 December 2019

(#) Review of noise monitoring locations was proposed by ET and NMS-5 was effective on 15 Nov 2017.

(~) Review of noise monitoring locations was proposed by ET and NMS-6 and NMS-7 were effective on 28 Feb 2018.

(^) Review of noise monitoring locations was proposed by ET and NMS-8 was effective on 18 April 2018. Noise monitoring at NMS-8 was started on 3 May 2018 upon commencement of construction at relevant section.

(+) Additional noise monitoring locations as instructed by AECOM which effective in Dec 18.

Should non-compliance of the environmental quality criteria occurs, remedial actions will be 3.7.2 triggered according to the Event and Action Plan which presented in Appendix F.

3.8 DATA MANAGEMENT AND DATA QA/QC CONTROL

All monitoring data will be handled by the ET's in-house data recording and management 3.8.1 system. The monitoring data recorded in the equipment will be downloaded directly from the equipment at the end of each monitoring day. The downloaded monitoring data will input into a computerized database properly maintained by the ET. The laboratory results will be input directly into the computerized database and checked by personnel other than those who input



the data.

3.8.2 For monitoring parameters that require laboratory analysis, the local laboratory shall follow the QA/QC requirements as set out under the HOKLAS scheme for the relevant laboratory tests.



4. AIR QUALITY MONITORING

4.1 GENERAL

- 4.2.1 In the Reporting Period, air quality monitoring was performed at the active designated monitoring locations AMS-1a, AMS-2, AMS-3, AMS-5, AMS-6 and AMS-7. Since installation of HVS for 24-hour TSP at AMS-2 and AMS-3 were pending approval from relevant departments, only 1-hour TSP monitoring was conducted at AMS-2 and AMS-3. No monitoring was conducted at AMS-4 since they are planned ASR which are still under construction/ not yet constructed.
- 4.2.2 The air quality monitoring schedule is presented in *Appendix G* and the monitoring results are summarized in the following sub-sections.

4.3 RESULTS OF AIR QUALITY MONITORING

4.3.1 In the Reporting Period, a total of *108* events of 1-hour TSP monitoring and *20* events of 24-hours TSP were carried out and the monitoring results are summarized in *Tables 4-1 to 4-5*. The detailed 24-hour TSP monitoring data are presented in *Appendix H* and the relevant graphical plots are shown in *Appendix I*.

	24-hour		1-hour 7	ГSP (µg/m ³)	
Date	TSP (µg/m ³)	Date	Start Time	1 st reading	2 nd reading	3 rd reading
4-Feb-22	10	5-Feb-22	9:14	83	77	70
8-Feb-22	14	9-Feb-22	8:50	45	47	42
14-Feb-22	13	15-Feb-22	9:02	75	80	76
19-Feb-22	12	21-Feb-22	8:56	40	47	44
25-Feb-22	18	26-Feb-22	9:08	67	74	70
Average (Range)	13 (10 - 18)	Averag (Rang	ge e)		62 (40 - 83)	

 Table 4-1
 Summary of 24-hour and 1-hour TSP Monitoring Results (AMS-1a)

Table 4-2Summary of 1-hour TSP Monitoring Results (AMS-2)

		1-hour TSP	(μg/m ³)	
Date	Start Time	1 st reading	2 nd reading	3 rd reading
5-Feb-22	9:19	84	78	81
9-Feb-22	9:15	48	54	50
15-Feb-22	9:27	83	87	85
21-Feb-22	9:22	50	53	48
26-Feb-22	9:34	76	81	74
Ave	erage		69	
(Ra	ange)		(48 - 87)	

Table 4-3Summary of 1-hour TSP Monitoring Results (AMS-3)

		1-hour TSP	(μg/m ³)	
Date	Start Time	1 st reading	2 nd reading	3 rd reading
5-Feb-22	9:25	83	74	79
9-Feb-22	9:26	49	52	48
15-Feb-22	9:37	79	83	81
21-Feb-22	9:34	48	52	46
26-Feb-22	9:46	76	79	73
Ave	erage		67	
(Ra	ange)		(46 - 83)	



	Summer J			101 110111011		
	24-hour		1	l-hour TSP (µ	.g/m ³)	
Date	TSP (µg/m ³)	Date	Start Time	1 st reading	2 nd reading	3 rd reading
4-Feb-22	19	5-Feb-22	13:01	77	89	75
8-Feb-22	18	9-Feb-22	14:04	55	61	68
14-Feb-22	19	15-Feb-22	14:17	82	85	88
19-Feb-22	21	21-Feb-22	14:15	62	66	70
25-Feb-22	12	26-Feb-22	14:30	98	97	101
Average (Range)	18 (12 - 21)	Average (Rang	ge e)		78 (55 – 101)	

Table 4-4Summary of 24-hour and 1-hour TSP Monitoring Results (AMS-5)

Table 4-5

Summary of 24-hour and 1-hour TSP Monitoring Results (AMS-6)

	24-hour	1-hour TSP (µg/m³)					
Date	TSP (µg/m ³)	Date	Start Time	1 st reading	2 nd reading	3 rd reading	
4-Feb-22	13	5-Feb-22	13:09	80	78	85	
8-Feb-22	30	9-Feb-22	13:52	58	60	65	
14-Feb-22	33	15-Feb-22	14:05	85	87	89	
19-Feb-22	33	21-Feb-22	14:02	59	63	68	
25-Feb-22	62	26-Feb-22	14:17	92	96	99	
Average (Range)	34 (13 - 62)	Average (Range)		78 (58 - 99)			

Table 4-6	Summary of 24-hour and 1-hour TSP Monitoring Results (AMS-7)
-----------	--

	24 hour	1-hour TSP (μg/m³)						
Date	TSP (μg/m ³)	Date	Start Time	1 st reading	2 nd reading	3 rd reading		
4-Feb-22	14	5-Feb-22	13:16	81	70	68		
8-Feb-22	33	9-Feb-22	13:25	55	54	60		
14-Feb-22	28	15-Feb-22	13:40	73	79	84		
19-Feb-22	29	21-Feb-22	13:38	51	55	58		
25-Feb-22	12	26-Feb-22	13:52	89	92	97		
Average	23	Average		71				
(Range)	(12 - 33)	(Range	e)	(51 – 97)				

- 4.3.2 As shown in *Tables 4-1 to 4-6*, all the 1-hour TSP and 24-hour TSP monitoring results in the Reporting Period were below the Action and Limit Levels. No Notification of Exceedance (NOE) was issued in this Reporting Period.
- 4.3.3 The meteorological data during the impact monitoring days are summarized in *Appendix J*.



5. CONSTRUCTION NOISE MONITORING

5.1 GENERAL

- 5.2.1 In the Reporting Period, noise monitoring was performed at designated monitoring locations NMS2 and NMS3 and the additional monitoring locations NMS4a, NMS5, NMS6, NMS7 and NMS8. No monitoring was conducted at the designated monitoring locations NMS1 since they are the planned NSR and still under the construction.
- 5.2.2 In addition, a Work Instruction was issued from AECOM to AUES in November 2018 for installing three additional noise monitoring stations, i.e., CN1, CN2 and CN3 for Contract 3. Impact noise monitoring was performed at the three additional noise monitoring locations since December 2018.
- 5.2.3 The noise monitoring schedule is presented in *Appendix G* and the monitoring results are summarized in the following sub-sections.

5.3 NOISE MONITORING RESULTS IN REPORTING MONTH

5.3.1 In the Reporting Period, a total of 22 events noise measurements were carried out at the designated locations under Contract 1. The noise monitoring results at the designated locations are summarized in *Tables 5-1*. The detailed noise monitoring data are presented in *Appendix H* and the relevant graphical plots are shown in *Appendix I*.

 Table 5-1
 Summary of Construction Noise Monitoring Results for Contract 1

Construction Noise Level (L _{eq30min}), dB(A)						
Date	NMS2	NMS3	NMS4a	NMS5	NMS6	NMS7
9-Feb-22	60	59	67	67	68	66
15-Feb-22	62	64	64	69	69	67
21-Feb-22	64	60	69	69	66	65
Limit Level	$70 \text{ dB(A)} / 65 \text{ dB(A)}^{\text{Note 1}}$			75 dB(A)		

Note 1: Noise Limit Levels for school is 70dB(A) and should be reduced to 65dB(A) during examination period;

	Fable 5-1a	Summary of	Construction	Noise Monitorin	g Results	for Contract
--	------------	------------	--------------	------------------------	-----------	--------------

Construction Noise Level (L _{eq30min}), dB(A)					
Date	NMS8				
5-Feb-22	68				
11-Feb-22	69				
17-Feb-22	64				
23-Feb-22	63				
Limit Level	75 dB(A)				

5.3.2 For the additional noise monitoring under Contract 3, a total of **12** events noise measurements were performed for the Contract. The noise monitoring results are summarized in *Tables 5-2*. The detailed noise monitoring data are presented in *Appendix H* and the relevant graphical plots are shown in *Appendix I*.

 Table 5-2
 Summary of Construction Noise Monitoring Results for Contract 3

Construction Noise Level (L _{eq30min}), dB(A)						
Date	CN1	CN2	CN3			
5-Feb-22	62	64	69			
11-Feb-22	64	62	66			
17-Feb-22	62	63	62			
23-Feb-22	64	66	63			
Limit Level	70 dB(A) / 65 dB(A) ^{Note 1}	70 dB(A) ^{Note 1} / 65 dB(A) ^{Note 1}	75 dB(A)			



- *Note 1: Noise Limit Levels for school is 70dB(A) and should be reduced to 65dB(A) during examination period.*
- 5.3.3 As shown in *Tables 5-1 and 5-2*, no Limit Level exceedance was recorded in this Reporting Period. No noise complaint (which triggered Action level exceedance) was received under the Project.



6. WASTE MANAGEMENT

6.1 GENERAL WASTE MANAGEMENT

6.2.1 Waste management was carried out by an on-site Environmental Officer or an Environmental Supervisor from time to time.

6.3 **RECORDS OF WASTE QUANTITIES**

- 6.3.1 All types of waste arising from the construction work are classified into the following:
 - Construction & Demolition (C&D) Material;
 - Chemical Waste;
 - General Refuse; and
 - Excavated Soil.
- 6.3.2 The quantities of waste for disposal in this Reporting Period are summarized in *Tables 6-1* and *6-2* and the Monthly Summary Waste Flow Table is shown in *Appendix K*. Whenever possible, materials were reused on-site as far as practicable.

Type of	Cont	ract 1	Cont	tract 2	Cont	ract 3	Cont	ract 4	Cont	ract 5
Waste	Quantity	Disposal Location								
Total generated Inert C&D Materials ('000m ³) (#)	1.372	-	0.01	-	2.078	-	25.019	-	0.02	-
Hard Rock and Large Broken Concrete ('000m ³)	0	-	0	-	0	-	11.495	-	0	-
Reused in this Contract (Inert) ('000m ³)	1.187	-	0	-	0.4	-	0	-	0	-
Reused in other Projects (Inert) ('000m ³)	0	*	0	-	0	-	0	-	0	-
Disposal as Public Fill (Inert) ('000m ³)	0.185	TKO 137	0.01	TKO 137	1.678	TKO 137	13.524	-	0.02	-

Table 6-1Summary of Quantities of Inert C&D Materials

Remark (#): *The total generated inert C&D materials will not take account for the hard rock and large broken concrete.*

(*) Approved alternative disposal ground.



True of	Cont	ract 1	Cont	ract 2	Cont	ract 3	Cont	ract 4	Cont	ract 5
Waste	Quantity	Disposal Location								
Recycled	0		0		0		0		0	
('000kg)	0	-	0	-	0	-	0	-	0	-
Recycled										
Paper /								-		
Cardboard	0	-	0	-	0	-	0		0	-
Packing										
('000kg)										
Recycled						Licensed				
Plastic	0	-	0	-	1.694	collector	0	-	0	-
('000kg)						concetor				
Chemical										
Wastes	0	-	0	-	0	-	0	-	0	-
('000kg)										
General										
Refuses	0.102	SENT	0.05	SENT	0.016	SENT	0.019	SENT	0	SENT
$(`000m^3)$										

Table 6-2Summary of Quantities of C&D Wastes



7. SITE INSPECTION

7.1 REQUIREMENTS

7.1.1 According to the approved EM&A Manual, the environmental site inspection shall be formulation by ET Leader. Weekly environmental site inspections should be carried out to confirm the environmental performance.

7.2 FINDINGS / DEFICIENCIES DURING THE REPORTING MONTH

Contract 1

7.2.1 In the Reporting Period, joint site inspections for Contract 1 to evaluate site environmental performance were carried out by the RE, ET and the Contractor on 10, 15 and 22 February 2022 in which IEC joined the site inspection with SSEMC on 10 February 2022. No non-compliance was noted. The findings / deficiencies of *Contract 1* that observed during the weekly site inspection are listed in *Table 7-1*.

Date	Findings / Deficiencies	Follow-Up Status
10 February 2022	 No adverse environmental issue was observed during site inspection The Contractor was reminded to clean stagnant water inside drip tray at PTT. 	NA Reminder only
15 February 2022	 No adverse environmental issue was observed during site inspection. The Contractor was reminded to spray water on site regularly. 	NAReminder only
22 February 2022	Chemical containers were observed. The Contractor was advised to put it inside drip tray or remove it (Reservoir)	Chemical containers were removed.

Table 7-1Site Observations of Contract 1

Contract 2

7.2.2 In the Reporting Period, joint site inspections for Contract 2 to evaluate site environmental performance were carried out by the RE, ET and the Contractor on 9, 16 and 25 February 2022 in which IEC joined the site inspection with SSEMC on 25 February 2022. No non-compliance was noted. The findings / deficiencies of *Contract 2* that observed during the weekly site inspection are listed in *Table 7-2*.

Table 7-2Site Observations of Contract 2

Date	Follow-Up Status	
9 February	No adverse environmental issue was	• NA
2022	observed.	
	The Contractor was reminded to clean	Reminder only
	stagnant water regularly at Portion 3	
16 February	• No adverse environmental issue was	• NA
2022	observed.	
	• The Contractor was reminded to maintain	Reminder only
	good housekeeping.	
25 February	Chemical container should be placed	Chemical container
2022	inside drip tray to avoid land	were removed.
	contamination.	



Contract 3

7.2.3 In the Reporting Period, joint site inspections for Contract 3 to evaluate site environmental performance were carried out by the RE, ET and the Contractor on 4, 11, 18 and 25 February 2022 in which IEC joined the site inspection with SSEMC on 25 February 2022. No non-compliance was noted. The findings / deficiencies of *Contract 3* that observed during the weekly site inspection are listed in *Table 7-3*

Fable 7-3	Site Observations	of Contract 3

Date)	Fi	nding	s / Deficie	ncies			Fo	ollow-Up Status
4	February	•	No	adverse	environmental	issue	was	٠	NA
2022			obse	rved.					
11	February	٠	No	adverse	environmental	issue	was	٠	NA
2022	·		obse	rved durin	g site inspection.				
18	February	•	No	adverse	environmental	issue	was	•	NA
2022			obse	rved.					
25	February	•	No	adverse	environmental	issue	was	•	NA
2022			obse	rved.					

Contract 4

7.2.4 In the Reporting Period, joint site inspections for Contract 4 to evaluate site environmental performance were carried out by the RE, ET and the Contractor on 9, 16 and 24 February 2022 in which IEC joined the site inspection with SSEMC on 24 February 2022. No non-compliance was noted. The findings / deficiencies of *Contract 4* that observed during the weekly site inspection are listed in *Table 7-4*

Table 7-4Site Observations of Contract 4

Date	Findings / Deficiencies	Follow-Up Status		
9 February	• No adverse environmental issue was	• NA		
2022	observed.			
	• The Contractor was reminded to implement	Reminder only		
	dust mitigation measures at Portion 12.			
16 February	• No adverse environmental issue was	• NA		
2022	observed.			
24 February	• No adverse environmental issue was	• NA		
2022	observed.			
	• The Contractor was reminded to clean	Reminder only		
	accumulated water in U-channel at 185+mpD			

Contract 5

7.2.5 In the Reporting Period, joint site inspections for Contract 5 to evaluate site environmental performance were carried out by the RE, ET and the Contractor on 10, 17 and 21 February 2022 in which IEC joined the site inspection with SSEMC on 21 February 2022. No non-compliance was noted. The findings / deficiencies of *Contract 5* that observed during the weekly site inspection are listed in *Table 7-5*

Table 7-5Site Observations of Contract 5

Date	Findings / Deficiencies	Follow-Up Status
10 February 2022	 No adverse environmental issue was observed during site inspection. The Contractor was reminded to pump away stagnant water produced from 	NAReminder only
	drilling work regularly at E6.The Contractor was reminded to clean oil stain on the ground at E5.	• Reminder only



Monthly	Environmental	Monitoring a	& Audit Rej	port (February	2022
---------	---------------	--------------	-------------	----------------	------

Date	Findings / Deficiencies	Follow-Up Status	
17 February2022	• No adverse environmental issue was observed during site inspection.	• NA	
	• The Contractor was reminded to avoid potential muddy water out of site boundary at E6	• Reminder only	
21 February 2022	• Oil stain was observed near the U-channel at E10. The Contractor was advised to clean it regularly.	Oil stains observed was clean.	


8. ENVIRONMENTAL COMPLAINT AND NON-COMPLIANCE

8.1 Environmental Complaint, Summons and Prosecution

- 8.1.1 In the Reporting Period, no environmental complaint was received for the project. Besides, no summons and prosecution under the EM&A Programme was lodged for the project. Investigation for the complaint was undertaken and presented in following sections.
- 8.1.2 The complaint log and Investigation Reports issued in the Reporting Period are shown in *Appendix M*.
- 8.1.3 The statistical summary table of environmental complaint, summons and prosecution is presented in *Tables 8-1, 8-2* and *8-3*.

Depenting Devied	Contract	Enviro	nmental Compl	aint Statistics
Reporting Period	no.	Frequency	Cumulative	Complaint Nature
1 Apr 2017 – 31 Jan 2022	1	0	52	Dust, Noise and light nuisance
21 Mar 2017 – 31 Jan 2022	2	0	10	Noise
31 May 2018 – 31 Jan 2022	3	0	8	Waste Management, Noise, Water Quality
27 Sep 2021- 31 Jan 2022	4	0	0	NA
30 Mar 2021 – 31 Jan 2022	5	0	0	NA
	1	0	52	NA
	2	0	10	NA
1 – 28 February 2022	3	0	8	NA
	4	0	0	NA
	5	0	0	NA

Table 8-1Statistical Summary of Environmental Complaints

Table 8-2 Statistical Summary of Environmental Sumi	nons
---	------

Depenting Devied	Contract	Environmental Summons Statistics		
Reporting Period	no.	Frequency	Cumulative	Summons Nature
1 Apr 2017 – 31 Jan 2022	1	0	0	NA
21 Mar 2017 – 31 Jan 2022	2	0	0	NA
31 May 2018 – 31 Jan 2022	3	0	0	NA
27 Sep 2021- 31 Jan 2022	4	0	0	NA
30 Mar 2021 – 31 Jan 2022	5	0	0	NA
	1	0	0	NA
	2	0	0	NA
1 – 28 February 2022	3	0	0	NA
	4	0	0	NA
	5	0	0	NA

Table 8-3	Statistical Summary of Environmental Prosecutio	n
-----------	---	---

Deperting Devied	Contract	Environmental Prosecution Statistics		
Reporting Period	no.	Frequency	Cumulative	Prosecution Nature
1 Apr 2017 – 31 Jan 2022	1	0	0	NA
21 Mar 2017 – 31 Jan 2022	2	0	0	NA
31 May 2018 – 31 Jan 2022	3	0	0	NA
27 Sep 2021- 31 Jan 2022	4	0	0	NA

CEDD Contract No. NTE/07/2016 Environmental Team for Development of Anderson Road Quarry Site - Site Formation and Associated Infrastructure Works Monthly Environmental Monitoring & Audit Report (February 2022)



Departing Deviad	Contract	Environmental Prosecution Statistics		
Reporting Period	no.	Frequency	Cumulative	Prosecution Nature
30 Mar 2021 – 31 Jan 2022	5	0	0	NA
Reporting Period 30 Mar 2021 – 31 Jan 2022 1 – 28 February 2022	1	0	0	NA
	2	0	0	NA
1 – 28 February 2022	3	0	0	NA
	4	0	0	NA
	5	0	0	NA



9. IMPLEMENTATION STATUS OF MITIGATION MEASURES

9.1 GENERAL REQUIREMENTS

- 9.1.1 The environmental mitigation measures that recommended in the Implementation Schedule for Environmental Mitigation Measures (ISEMM) in the approved EM&A Manual covered the issues of dust, noise, water and waste and they are summarized presented in *Appendix L*.
- 9.1.2 All contracts under the Project shall be implementing the required environmental mitigation measures according to the approved EM&A Manual as subject to the site condition. Environmental mitigation measures generally implemented in this Reporting Period are summarized in *Table 9-1*.

	0
Issues	Environmental Mitigation Measures
Water Quality	 Wastewater to be treated by filtration system; such as, silt curtain or sedimentation tank before discharge. Replace silt curtain materials if necessary
Air Quality	 Maintain damp / wet surface on access road Keep slow speed in the sites All vehicles must use wheel washing facility before off site All vehicles must use wheel washing facility before off site Sprayed water during breaking works
Noise	 Restrain operation time of plants from 07:00 to 19:00 on any working day except for Public Holiday and Sunday. Keep good maintenance of plants Place noisy plants away from residence or school Provide noise barriers or hoarding to enclose the noisy plants or works Shut down the plants when not in used.
Waste and Chemical	 On-site sorting prior to disposal Follow requirements and procedures of the "Trip-ticket System"
Management	 Predict required quantity of concrete accurately
	• Collect the unused fresh concrete at designated locations in the sites for subsequent disposal
General	The site was generally kept tidy and clean.

 Table 9-1
 Environmental Mitigation Measures

9.2 TENTATIVE CONSTRUCTION ACTIVITIES IN THE COMING MONTH

9.2.1 Construction activities for Contract 1 in the coming month are listed below:

Temporary Traffic Arrangement (TTA) at On Sau Road:

• Implementation of TTA at the junction between On Sau Road and Road L4 for road improvement works to continue.

Pedestrian Connectivity System B:

Bamboo Scaffold Erection for external ABWF works

Box Culvert BC1 at Internal Road L1:

- Defect rectification work to continue
- Slurry removal to continue
- Cat ladder installation complete
- Material of Multi-part cover will arrive in early December 2021.

Construction of Internal Road L1:

- Excavation and laying of watermain to continue.
- Road work, footpath and cycle track at L1 east to continue.



• Gullies and upper drainage construction for road L1 west to continue.

Artificial Flood Attenuation Lake:

- To continue the drainage works (the remaining part: S114 manhole and drainpipe direct to existing catchpit).
- To commence the installation works of Floating Bridge.
- To continue the additional guide post extension for Floating Bridge.

Slope Stabilization at Portion B5:

- Continue to erect inspection scaffolds from 2nd to 5th berm.
- Continue to carry out stabilization works at Feature No. 11NE-D/C949 and 11NE-D/C948.

Cavern (Portion B5):

- Rock fall fence installation complete.
- Rock breaking of existing slope at Ch200-248 on level +196 202mPD complete.
- Rock dowel construction to continue.
- Drilling of Portal to continue.
- Planter wall construction to continue.
- UC construction at CH248 +198.5mPD berm in progress.
- Construction of Inspection scaffold on temporary triangle bracket was completed and rock mapping will be completed in late February 2022.
- UC construction at +230mPD berm to continue.
- Buttress construction and spray concrete at Ch0-150 on +230 to +250 completed.

MEP Works:

- Submission of designs and materials related to MEP works in progress.
- E&M installation works at PTT in progress to continue.
- E&M installation works at Pump Hall of Fresh Water Pumping Station in progress.
- E&M installation works at Pedestrian Connectivity System B in progress.
- E&M installation works at Underground Stormwater Retention Tank in progress.
- E&M installation works at Underpass in progress
- E&M installation works at Pillar Box (Underground Stormwater Retention Tank) in progress.
- E&M installation works at Pillar Box (East portal) in progress.
- E&M installation works at the cleansing pump room (Fresh Water Pumping Station) in progress.
- E&M installation works at the EMF & valve chamber VC8 (Fresh Water Pumping Station) in progress.
- Energization of Fresh Water Pumping Station on mid of January 2022.
- T&C of Fresh Water Pumping Station in progress.
- E&M installation works at the Service Reservoir to be commence.
- E&M installation works at Pillar Box (West portal) to be commence.
- E&M installation works at F.S. Kiosk (East portal) to be commence.
- E&M installation works at Pedestrian Connectivity System A to commence.

Road Improvement Works at Po Lam Road:

- Construction of permanent footpath and surface drainage system complete
- Excavation works to facilitate installation of the E&M/ACT/Earth pit and construction of permanent footpath and surface drainage system complete
- Construct concrete carriageway and footpath completed
- Install beam barrier complete
- Construct Island in progress
- Implement stage 3 TTA



Internal Road L4, Pedestrian Connectivity System A, Noise Barrier, RWA12 and RWA18:

- Backfilling G200 rock at RWA12 to continue
- Drainage, sewerage construction in progress
- UU installation in progress
- Watermain laying in progress.
- Ducting installation works for street lighting in progress.
- Forming road formation and laying subbase in progress.

<u>PTT</u>

• Lighting system and PMMA panel installation to continue, concrete pavement construction, kerb laying and noise barrier works would continue.

Hiking Trail (Portion B5):

• Waiting for AECOM issue new design and new material specification

Existing Anderson Road

- Pipe trough construction to continue.
- 9.2.2 Construction activities for Contract 2 in the coming month are listed below:
 - Temporary Traffic Arrangement (TTA)
 - Soil Nail Construction
 - Mass Concrete construction
 - Formwork and Falsework installation and dismantling
 - Lifting Tower Construction
 - Rebar fixing
- 9.2.3 Construction activities for Contract 3 in the coming month are listed below:

Works in Road Improvement Works 1 (RIW1)

- Construct RC works & backfilling at Type 2 are in-progress.
- Construct socketed H pile at RWC2 Type 3 for piling construction are in-progress; Rock excavation at RWC2 Type 3 are in-progress.
- Preparation works of drainage diversion at Type 4 is in-progress.
- Backfilling works at Type 6 to 8 is in-progress.
- Mini-pile works at FE1-PC1b is in-progress.
- Excavate trial pit works at CT5 is in-progress.
- Drainage works at KS27 (West Side) also is in-progress; Install sheet pile & ELS works at KS27 (East Side) near Shun Lee Estate.

Works in Road Improvement Works 2 (RIW2)

- Construct RC works at RWC3b; Rock excavation & ELS works at RWC3b are in-progress.
- Install pipe pile wall at CT4 roadside is in-progress.
- Construct mini-pile works at SE2 (hill side toward Sai Keung direction) is in-progress; Excavate for expose utilities and utilities protection / diversion are in-progress.

Works in Road Improvement Works 3 (RIW3)

- Excavate trial pits at Sau Mui Ping Road / Lin Tak Road for watermain alignment confirmation in-progress.
- Concreting and backfilling works at RWD1 Bay 1 10.
- ELS works at RWD1 Bay 11 14 is in-progress.
- Rock excavate at Slope D1 lower portion is in-progress.
- Road works and backfilling works at Slope D2 are in-progress.
- Rock excavation using drill & split method, drainage works and road works at Slope D3 / Lin Tak Road are in-progress.



Pedestrian Connectivity Facility E8 (PC-E8)

• Touch-up outstanding works are in progress.

Pedestrian Connectivity Facility E11 (PC-E11)

- ABWF works and E&M works at LT2 & ST2 are in-progress.
- ABWF works and E&M works at LT1 & ST1 are in-progress.
- ABWF work and E&M works inside the footbridge steel frame are in-progress.

Pedestrian Connectivity Facilities Systems A (PC-SYA)

- ABWF works and E&M works at LT1, LT2 & ST1 are in-progress.
- Erect steel works inside RC structure is in-progress.

Pedestrian Connectivity Facilities Systems B (PC-SYB)

- RC works at SyB-LT1 & ST1 is in-progress.
- Construct pile cap at PC4 & PC6 are in-progress.
- Install sheet-pile and excavation works at PC1 are in-progress.

Tseung Kwan O Bus-Bus Interchange New Public Toilet (BBI-Toilet)

- The completed toilet was handed over to Food and Environmental Hygiene Department on 30 September 2020; Additional works under an instruction is in-progress.
- 9.2.4 Construction activities for Contract 4 in the coming month are listed below:
 - Completion of CRE Office & Chainlink Fence
 - Construction of access road leading to CRE's office (Depends on CWSTVJV)
 - GI works at G-2, Portion 3
 - Modification of RWA10 Footing
 - Site Drainage work at Portion 2a, 8 and 12
 - Hard Landscaping at Portion 2b
 - Construction of Staircase, U-channel repairing work, Railing Installation at Portion 1 0
 - Erection of Project Signboard at +175mPD
- 9.2.5 Construction activities for Contract 5 in the coming month are listed below:

Portion 1

- Form Piling Platform at E5, PC2 and PC3
- Piling Work at E5 PC1
- Portion 2
- Piling Works
- Portion 3
- Diversion of existing staircase
- Trial Run
- Trail pit at carriageway and install utility settlement marker (USM) Portion 4
- Excavation of E10-F3
- Excavation of E10-F1

9.3 KEY ISSUES FOR THE COMING MONTH

- 9.3.1 Key issues to be considered in the coming month include:
 - Implementation of dust suppression measures at all times;
 - Potential wastewater quality impact due to surface runoff;
 - Potential fugitive dust quality impact due from the dry/loose/exposure soil surface/dusty material;
 - Disposal of empty engine oil containers within site area;



- Ensure dust suppression measures are implemented properly;
- Sediment catch-pits and silt removal facilities should be regularly maintained;
- Management of chemical wastes;
- Discharge of site effluent to the nearby wetland, stockpiling or disposal of materials, and any dredging or construction area at this area are prohibited;
- Follow-up of improvement on general waste management issues; and
- Implementation of construction noise preventative control measures
- 9.3.2 During dry season, the Contractor should fully implement air quality mitigation measures to reduce construction dust emission as far as practicable. Furthermore, since construction site is highly visible to the resident at nearby estates, noise mitigation measures such as using of quiet plants should be implemented in accordance with the EM&A requirement
- 9.3.3 The Contractor should pay special attention on water quality mitigation measures and fully implement according to the ISEMM of the EM&A Manual, in particular to prevent muddy water or other water pollutants from site surface overflow to public area should be properly maintained. The implementation of water quality mitigation measures conducted by the Contractor is shown in *Appendix N*.



10. CONCLUSIONS AND RECOMMENDATIONS

10.1 CONCLUSIONS

- 10.1.1 This is **59th** monthly EM&A report presenting the monitoring results and inspection findings for the Reporting Period from **1** to **28 February 2022**.
- 10.1.2 No 24-hour or 1-hour TSP monitoring and noise monitoring results that triggered the Action or Limit Levels were recorded. No NOEs or the associated corrective actions were therefore issued.
- 10.1.3 In the Reporting Period, no exceedance was recorded and no Notification of Exceedance was issued. Moreover, no noise complaints (which triggered Action Level) were received for the Project.
- 10.1.4 In the Reporting Period, no environmental complaint was received from the Project.
- 10.1.5 No notification of summons or successful prosecution was received under the Project.
- 10.1.6 During the Reporting Period, weekly joint site inspection by the RE, ET with the relevant Main-contractor was carried out for Contracts 1, 2, 3, 4 and 5 in accordance with the EM&A Manual stipulation whereas IEC performed monthly site inspection for both contracts. No non-compliance observed during the site inspection.

10.2 RECOMMENDATIONS

- 10.2.1 During dry season, the Contractors are reminded to fully implement air quality mitigation measures to reduce construction dust emission as far as practicable. Furthermore, since construction site is highly visible to the resident at nearby estates, noise mitigation measures such as using of quiet plants should be implemented in accordance with the EM&A requirement.
- 10.2.2 Since construction site is highly visible to the resident at nearby estates, the Contractors should pay special attention on potential environmental impact generated by the site activities and adhere implement adequate air quality and noise mitigation measures as far as practicable to reduce the impact to the public.
- 10.2.3 Construction noise is one of the key environmental issues during construction work of the Project. Noise mitigation measures such as using quiet plants and noise barriers shall be implemented where practicable according to the EM&A manual.
- 10.2.4 In addition, the Contractors should ensure all effluent discharge shall be fulfilled the Technical Memorandum of Effluent Discharged into Drainage and Sewerage Systems, inland and Coastal Waters criteria or relevant discharge license requirement.
- 10.2.5 Mosquito control measures should be continued to prevent mosquito breeding on site.



Appendix A

Layout plan of the Project

Contract Packages





Layout plan of Contract 1 (N/2016/01)



Printed by



Layout plan of Contract 2 (NE/2016/05)





PROJECT _{項目}

DEVELOPMENT OF ANDERSON ROAD QUARRY SITE - INVESTIGATION, DESIGN AND CONSTRUCTION

CONTRACT TITLE PEDESTRIAN CONNECTIVITY FACILITIES WORKS PHASE 1

CLIENT 業主



上木工程拓展署
 Civil Engineering and
 Development Department

CONSULTANT 工程顧問公司

AECOM Asia Company Ltd. www.aecom.com

SUB-CONSULTANTS 分判工程顧問公司

ISSUE/REVISION 修訂



			M
-	OCT. 16	TENDER DRAWING	AC
/ R 修	DATE 日期	DESCRIPTION 內容摘要	CHK. 複核

STATUS 階段

SCALE 比例

A1 1 : 500

KEY PLAN A1 1 : 60000 索引圖

NGAU TAU KOK

SHEET NUMBER 岡紙編號

CONTRACT NO. ^{合約編號}

TSUI LAM

DIMENSION UNIT ^{尺寸單位}

METRES

60328348

PROJECT NO. _{項目編}號

NE/2016/05 SHEET TITLE 圖紙名稱

E2-C1-E3 - PORTION OF SITE

60328348/PC1/2016





PROJECT _{項目}

DEVELOPMENT OF ANDERSON ROAD QUARRY SITE - INVESTIGATION, DESIGN AND CONSTRUCTION

CONTRACT TITLE PEDESTRIAN CONNECTIVITY FACILITIES WORKS PHASE 1

CLIENT 業主



CONSULTANT 工程顧問公司

AECOM Asia Company Ltd. www.aecom.com

SUB-CONSULTANTS 分判工程顧問公司

ISSUE/REVISION 修訂



//R 修訂	DATE 日期	DESCRIPTION 內容摘要	CHK. 複核
-	OCT. 16	TENDER DRAWING	AC
			M

SCALE _{比例}

A1 1 : 500

NGAU TAU KOK

KWUN TONG

KEY PLAN A1 1 : 60000 索引圖

			M
-	OCT. 16	TENDER DRAWING	AC
/ R 修訂	DATE 日期	DESCRIPTION 內容摘要	CHK. 複核
			ł

			M
-	OCT. 16	TENDER DRAWING	AC
I/R 修訂	DATE 日期	DESCRIPTION 內容摘要	CHK. 複核

			M
-	OCT. 16	TENDER DRAWING	AC
I/R 修訂	DATE 日期	DESCRIPTION 內容摘要	CHK. 複核
о т	ATUO		i

STATUS ^{階段}

60328348/PC1/3016



DIMENSION UNIT 尺寸單位

METRES

60328348

SHEET TITLE 圖紙名稱

PROJECT NO. 項目編號

NE/2016/05

E12 AND BBI - PORTION OF SITE

SHEET NUMBER ^{國紙編號}





PROJECT ^{項目}

DEVELOPMENT OF ANDERSON ROAD QUARRY SITE - INVESTIGATION, DESIGN AND CONSTRUCTION

CONTRACT TITLE PEDESTRIAN CONNECTIVITY FACILITIES WORKS PHASE 1

CLIENT 業主



上木工程拓展署
 Civil Engineering and
 Development Department

CONSULTANT 工程顧問公司

AECOM Asia Company Ltd. www.aecom.com

SUB-CONSULTANTS 分判工程顧問公司

ISSUE/REVISION 修訂

- OCT. 16 TENDER DRAWING	
- OCT. 16 TENDER DRAWING	
I/R 修訂 DATE 日期 DESCRIPTION CI 後	₩. 核

			- AL
-	OCT. 16	TENDER DRAWING	"AC
I/R 修訂	DATE 日期	DESCRIPTION 內容摘要	CHK. 複核

STATUS 階段

SCALE 比例

A1 1 : 500

NGAU CHT WAN

KOWLOON BAY

PROJECT NO. _{項目编}號

SHEET TITLE 圖紙名稱

60328348

KEY PLAN A1 1 : 60000 家引圖

54

KWUN TONG

GREEN ROUTE - PORTION OF SITE

			M
1	OCT. 16	TENDER DRAWING	AC
I/R 修訂	DATE 日期	DESCRIPTION 內容摘要	CHK. 複核

DIMENSION UNIT 尺寸單位

WAN

METRES

LAMTIN

CONTRACT NO. ^{合約編號}

NE/2016/05

SHEET NUMBER 圖紙編號

60328348/PC1/5007





JL		101115
DINTS	EASTING	NORTHING
001	843917.587	818906.541
002	843929.342	818905.094
003	843939.483	818901.709
004	843956.219	818898.942
005	843965.528	818896.168
006	843969.261	818895.667
007	843979.545	818905.452
008	843984.131	818907.650
009	843985.175	818907.685
010	843985.110	818897.974
011	843981.962	818891.121
012	843972.510	818885.990
013	843966.562	818885.703
014	843938.026	818893.479
015	843914.8936	818899.2916
016	843917.5873	818906.5418
017	844004.9983	818934.8475
018	844000.3294	818947.0185
019	843992.9288	818955.3047
020	843983.1315	818980.9995
021	844015.8829	818990.0481
022	844051.2430	819004.7564
023	844055.1790	818964.5518
024	844050.7010	818959.3870
025	844048.1970	818967.9590
026	844027.1930	818961.0890
027	844028.4560	818957.440
028	844007.2170	818950.1120
029	844009.2850	818940.8450
030	844008.6995	818936.6258
031	844024.2060	818941.7840
032	844034.8059	818938.4355
033	844034.4315	818936.6727
034	844026.3820	818938.3480
035	844021.0980	818936.6740
036	844016.7340	818931.2790
037	843986.6120	818923.3580
038	843990.360	818926.797
039	843997.172	818929.287
040	844007.154	818941.102
041	844003.647	818950.980
042	844024.555	818959.707
043	844023.162	818964.725
044	844049.278	818971_887
045	844049.396	818964_017
046	843980 693	010047 575
047	844009 179	818913.535
048	844010 709	818922.804
040	843982 701	818918.044
UH J	043302•131	818907.077



PROJECT ^{項目}

DEVELOPMENT OF ANDERSON ROAD QUARRY SITE - INVESTIGATION, DESIGN AND CONSTRUCTION

CONTRACT TITLE PEDESTRIAN CONNECTIVITY FACILITIES WORKS PHASE 1

CLIENT _{業主}



た木工程拓展署
 Civil Engineering and
 Development Department

CONSULTANT 工程顧問公司

AECOM Asia Company Ltd. www.aecom.com

SUB-CONSULTANTS 分判工程顧問公司

ISSUE/REVISION 修訂



STATUS 階段

SCALE 比例

A1 1 : 500

METRES

DIMENSION UNIT ^{尺寸單位}

KEY PLAN A1 1 : 60000 家引國



PROJECT NO. _{項目編}號

CONTRACT NO. ^{合約編號}

60328348

NE/2016/05

SHEET TITLE 圖紙名稱

INFRASTRUCTURAL WORKS AT PO LAM ROAD SOUTH TIU KENG LENG – PORTION OF SITE

SHEET NUMBER 圖紙編號

60328348/PC1/9501A



Layout plan of Contract 3 (NE/2017/03) (Non-Designated Area)







PROJECT ^{項目}

DEVELOPMENT OF ANDERSON ROAD QUARRY SITE - INVESTIGATION, DESIGN AND CONSTRUCTION

CONTRACT TITLE DEVELOPMENT OF ANDERSON ROAD QUARRY SITE - ROAD IMPROVEMENT WORKS AND PEDESTRIAN CONNECTIVITY FACILITIES WORKS PHASE 2A CLIENT _{業主}



全林工程拓展署 Civil Engineering and Development Department

CONSULTANT 工程顧問公司

AECOM Asia Company Ltd. www.aecom.com

SUB-CONSULTANTS 分判工程顧問公司

ISSUE/REVISION 修訂



STATUS ^{階段}

SCALE 比例

A1 1 : 500

DIMENSION UNIT _{尺寸單位}

METRES

KEY PLAN A1 1 : 60000 家引國



PROJECT NO. _{項目編}號

SHEET 8 OF 8

60328348

SHEET TITLE 圖紙名稱

SHEET NUMBER 圖紙編號

60328348/R&P/1008A

CONTRACT NO. ^{合約編}號

NE/2017/03

GENERAL LAYOUT



Layout plan of Contract 4 (ED/2020/02)



γC



PROJECT

DEVELOPMENT OF ANDERSON ROAD QUARRY SITE - INVESTIGATION, DESIGN AND CONSTRUCTION

CONTRACT TITLE DEVELOPMENT OF ANDERSON ROAD QUARRY SITE - INFRASTRUCTURE, GREENING AND LANDSCAPE WORKS

CLIENT



 CEDD

 土木工程拓展署

 CEDD

 Civil Engineering and Development Department

CONSULTANT

AECOM Asia Company Ltd. www.aecom.com

SUB-CONSULTANTS 分判工程顧問公司

ISSUE/REVISION



SCALE 比例	DIMENSION UNIT 尺寸單位
A1 1 : 6000	METRES

PROJECT NO. ^{項目編號} CONTRACT NO. ^{合約編號} ED/2020/02 60328348 **SHEET TITLE** 圖紙名稱 KEY PLAN

SHEET NUMBER 圖紙編號

60328348/LS/1000



Layout plan of Contract 5 (ED/2019/02)











Appendix B

Project Organization Structure



Project Organization Structure





Organization	Project Role	Name of Key Staff	Tel No.	Fax No.
CEDD	Engineer	S W Lam, Sam	3842 7087	2739 0076
AECOM	Chief Resident Engineer	Lee, Yu Ching Paul	5723 6880	2473 3221
AECOM	Senior Resident Engineer	Li, Ling Tommy	9389 8792	2473 3221
ANEWR	Independent Environmental Checker	James Choi	2618 2836	3007 8648
CSVJV	Project Manager	William Leung	2638 7181	2744 6937
CSVJV	Site Agent	TY Leung	2638 7181	2744 6937
CSVJV	Project Environmental Manager	Jimmy Cheng	2638 7181	2744 6937
CSVJV	Environmental Officer	Ken Chu	2638 7181	2744 6937
AUES	Environmental Team Leader	T. W. Tam	2959 6059	2959 6079
AUES	Environmental Consultant	Nicola Hon	2959 6059	2959 6079
AUES	Environmental Consultant	Ben Tam	2959 6059	2959 6079

Contact Details of Key Personnel for Contract 1 – NE/2016/01

Legend:

CEDD (Employer) – Civil Engineering and Development Department

AECOM (Engineer) – AECOM Asia Co. Ltd.

CSVJV (Main Contractor) – Chun Wo-STEC-Vasteam Joint Venture

ANEWR (IEC) – ANewR Consulting Limited



Organization	Project Role	Name of Key Staff	Tel No.	Fax No.
CEDD	Engineer	S W Lam, Sam	3842 7087	2739 0076
AECOM	Chief Resident Engineer	Lee, Yu Ching Paul	5723 6880	2473 3221
AECOM	Senior Resident Engineer	Bill Hon	5599 1466	2473 3221
ANEWR	Independent Environmental Checker	James Choi	2618 2836	3007 8648
KOCCL	Project Director	Ambrose Kwong	2889 2675	2558 6900
KOCCL	Site Agent	Mr. Albert PK Ng	9150 1523	2558 6900
KOCCL	Safety and Environmental Manager	Joly C K Kwong	6111 5711	2558 6900
KOCCL	Environmental Officer	Ken Tam	9555 9958	2558 6900
AUES	Environmental Team Leader	T. W. Tam	2959 6059	2959 6079
AUES	Environmental Consultant	Nicola Hon	2959 6059	2959 6079
AUES	Environmental Consultant	Ben Tam	2959 6059	2959 6079

Contact Details of Key Personnel for Contract 2 – NE/2016/05

Legend:

CEDD (Employer) – Civil Engineering and Development Department

AECOM (Engineer) – AECOM Asia Co. Ltd.

KOCCL (Main Contractor) -Kwan On Construction Company Limited

ANEWR (IEC) – ANewR Consulting Limited



Organization	Project Role	Name of Key Staff	Tel No.	Fax No.
CEDD	Engineer	S W Lam, Sam	3842 7087	2739 0076
AECOM	Chief Resident Engineer	Lee, Yu Ching Paul	5723 6880	2473 3221
AECOM	Senior Resident Engineer	Brad Chan	5506 0068	2473 3221
ANEWR	Independent Environmental Checker	James Choi	2618 2836	3007 8648
CW – CMGC - JV	Construction Manager	William Leung	9464 1392	3965 9900
CW – CMGC - JV	Site Agent	Yu, Chi Kuen Paul	9456 9819	3965 9900
CW – CMGC - JV	Environmental Officer	King Lam	9570 6187	3965 9900
CW – CMGC - JV	Environmental Supervisor	Anna Tsang	9333 8499	3965 9900
AUES	Environmental Team Leader	T. W. Tam	2959 6059	2959 6079
AUES	Environmental Consultant	Nicola Hon	2959 6059	2959 6079
AUES	Environmental Consultant	Ben Tam	2959 6059	2959 6079

Contact Details of Key Personnel for Contract 3 -NE/2017/03

Legend:

CEDD (Employer) – Civil Engineering and Development Department

AECOM (Engineer) – AECOM Asia Co. Ltd.

CW - CMGC - JV (Main Contractor) - Chun Wo- CMGC - Joint Venture

ANEWR (IEC) – ANewR Consulting Limited



Contact Details of Key Personnel for Contract 4 - ED/2020/02

AUES

Legend:

CEDD (Employer) – Civil Engineering and Development Department

AECOM (Engineer) – AECOM Asia Co. Ltd.

CIWEC (Main Contractor) – China International Water & Electric Corporation

ANEWR (IEC) – ANewR Consulting Limited



Organization	Project Role	Name of Key Staff	Tel No.	Fax No.
CEDD	Engineer	S W Lam, Sam	3842 7087	2739 0076
AECOM	Chief Resident Engineer	Lee, Yu Ching Paul	9824 7016	2473 3221
AECOM	Senior Resident Engineer	Bill Hon	5599 1486	2473 3221
ANEWR	Independent Environmental Checker	James Choi	2618 2836	3007 8648
WL-UJV	Construction Manager	РН Но	9464 1392	2983 6640
WL-UJV	Site Agent	Lee Chi Wai	9255 7014	2983 6640
WL-UJV	Environmental Officer	Guo Liming	5723 9883	2983 6640
AUES	Environmental Team Leader	T. W. Tam	2959 6059	2959 6079
AUES	Environmental Consultant	Nicola Hon	2959 6059	2959 6079
AUES	Environmental Consultant	Ben Tam	2959 6059	2959 6079

Contact Details of Key Personnel for Contract 5 - ED/2019/02

Legend:

- CEDD (Employer) Civil Engineering and Development Department
- AECOM (Engineer) AECOM Asia Co. Ltd.
- WL-UJV (Main Contractor) Wing Lee Univic Joint Venture
- ANEWR (IEC) ANewR Consulting Limited
- AUES (ET) Action-United Environmental Services & Consulting



Appendix C

Construction Programme

- (a) Contract 1 (NE/2016/01)
- (b) Contract 2 (NE/2016/05)
- (c) Contract 3 (NE/2017/03)
- (d) Contract 4 (ED/2020/02)
- (e) Contract 5 (ED/2019/02)



Contract 1 (NE/2016/01)


CONTRACT NO.NE/2016/01 SITE FORMATION AND INFRASTRUCTURE WORKS FOR DEVELOPMENT OF ANDERSON ROAD QUARRY SITE 3-MONTH ROLLING PROGRAMME

	CHUN WO - STEC - VASTEAM JOINT VENTURE					• 1					
Activity ID	Activity Name	BL Project Duration	BL Project Start	BL Project Finish	At Completion Duration	Start	Finish	Dec		lan	Qtr 1, 2022 Feb
Anderson Rd S	ub-programme (January 2022) _ccn _220117										
Fresh Water Pump	ing Station										
Stage 5 - ABWF, F	inishing & E&M										
FWP-1320	Pumping Station E&M works	0			457	29-Jun-20 A	08-Jan-22 A				
Salt Water Reservo	ir										
ABWF, Finishing	& E&M										
SWR-1420	Saltwater Reservior E&M works	0			464	29-May-20 A	15-Dec-21 A	P			
Fresh Water Reserv	/oir										
ABWF, Finishing	& E&M										1
FWR-2000	Freshwater Reservior E&M works	0			406	12-Oct-20 A	23-Feb-22				
RWS Access Road	& External Works										
FWP-1410	Watermain (DN600 & DN450) & Irrigation System along WSA access road	0			529	16-May-20 A	23-Feb-22				
FWP-1420	Drainage (sewerage & surface) along WSA access road	0			467	30-Jul-20 A	23-Feb-22				
EWP-1430	Q P nower supply duct	0			426	16-Sen-20 A	23-Eeb-22	-			
EWP-1440	Road Works & Februira	0			120	24-Feb-22	21-10-22	-			
EWP-1450	Crisen Poof & Daving Area	0			100	17- lan-22	21-May/22				-
Padastrian Connect					100	11-0011-22	2 T-Widy-22				
Pedestrian Connec	tion System A& B										
PC system B			10.1 10	00.11 40	574		17 1 00	_			
PCB-1090	System B - Backfill south tower	81	19-Aug-19	23-Nov-19	571	16-Feb-20 A	17-Jan-22			System B - Backfill south to	wer
PCB-1100	System B - Backfill north tower	81	19-Aug-19	23-Nov-19	571	16-Feb-20 A	17-Jan-22			System B - Backfill north to	ver
PCB-1120	System B - E&M	22	23-Sep-19	19-Oct-19	488	05-Jun-20 A	22-Jan-22	_		System B - E&M	
PCB-1130	System B - E&M T&C	24	21-Oct-19	16-Nov-19	274	02-Mar-21 A	29-Jan-22			Sy	stem B - E&M T&C
PCB-1140	System B - Lift installation	75	21-Oct-19	18-Jan-20	288	02-Mar-21 A	18-Feb-22				System B
PCB-1150	System B - Lift T&C	27	20-Jan-20	22-Feb-20	27	19-Feb-22	22-Mar-22				
PCB-1160	System B - Submission of form 5 & EMSD instaction	18	24-Feb-20	14-Mar-20	18	23-Mar-22	13-Apr-22				
PCB-1170	System B - Issurance of Uer Permit	6	16-Mar-20	21-Mar-20	6	14-Apr-22	23-Apr-22				
PC system A											1
PCA-1050	B5 - Back Fill Lift Tower (North) upwards Formation Level	0			160	02-Jul-21 A	11-Jan-22 A				
PCA-1060	B5 - E&M and BS Works	0			184	02-Jul-21 A	11-Feb-22				B5 - E&M and BS Works
PCA-1070	B5 - ABWF Works	0			131	20-Dec-21 A	02-Jun-22				
PCA-1160	C1a - Back Fill Lift Tower (South) up wards Formation Level	0			87	18-Oct-21 A	29-Jan-22			C1	a - Back Fill Lift Tower (South) upwards Formation
PCA-1170	C1a - E&M and BS Works	0			119	22-Nov-21 A	20-Apr-22				
PCA-1180	C1a - ABWF Works	0			116	03-Jan-22 A	26-May-22	-			
Artificial Flood Atte	nuation Lake										
Construction of la	ke bottom										
ART-1990	Art Lake - water testing for bottom of lake	45	28-Feb-20	24-Apr-20	292	02-Mar-21 A	23-Feb-22				
Construction of Fl	oating Bridge										
ART-2060	Art Lake Floating Brdige - footing construction	30	06-Dec-19	13-Jan-20	314	11-Jan-21 A	29-Jan-22			Art	Lake Floating Brdige - footing construction
ART-2070	Art Lake Floating Brdige - installation bridge	30	14-Jan-20	20-Feb-20	54	31-Jan-22	07-Apr-22	-		E	
Slot Chamber											
ART-2080	Art Lake - Slot chamber no. 1 & stop log chamber	18	09-Dec-19	31-Dec-19	505	16-May-20 A	22-Jan-22			Art Lake - Slot ch	amber no. 1 & stop log chamber
ART-2090	Art Lake - Slot chamber no. 2 & stop log chamber	26	31-Jan-20	29-Feb-20	286	23-Feb-21 A	09-Feb-22	_			Art Lake - Slot chamber po 2
ART-2100	Art Lake - Slot chamber no. 3	33	31-Jan-20	09-Mar-20	286	23-Feb-21 A	09-Feb-22				Art Lake - Slot chamber no. 2
Drainago		55	CT GATED	55 Mar 20	200	201.00-2177	00 - 00 - 22				AIL LAKE - SIUL GHAMDEL HU. 3
	Art Lake - Outoide bay 38.45	62	04 Nov 10	18- Jon 20	570	02-Mor 20 A	29- Jan 22				Laka Outsida hay 20.45
AN PZ TIV		00	01907-19	io-Jaii-20	510	UZ-IVIAI-ZU A	2 <i>0</i> -Jail-22			Ar	Lake - Oulsue Day 38-45
Plan	ned Bar (WP) 🔶 🔶 Planned Milestone (WP)					2				Dat	e F
Actu	al Bar \blacklozenge \blacklozenge Milestone					s-mont	III KOIII	ng Program	me	15-Dec-2	1 C1-MPU202112
Fore	cast Bar			Anders	on Ka Sub-p 22	rogramme					
				I ID-Jau-	-22						

	Pa	ge 1 of 3	
	Mar		Qtr 2, 2022 Apr
reshwat	er Reservior E&M works		
Vaterma	ain (DN600 & DN450) & Irrigation System	along WSA access roa	i
Drainage	(sewerage & surface) along WSA acces	s road	
ЪР ром	er supply duct		
Lift inet	allation		
		System B - Lift T	кС
			s
_evel			
AT Lake	- water testing for bottom of lake		
			Art Lake Floa
& stop I	bg chamber		
	: n	Checked	Annroved



CONTRACT NO.NE/2016/01 SITE FORMATION AND INFRASTRUCTURE WORKS FOR DEVELOPMENT OF ANDERSON ROAD QUARRY SITE 3-MONTH ROLLING PROGRAMME

	CHUN WO - SIEC - VASTEAM JOINT VENTURE									
Activity ID	Activity Name	BL Project Duration	BL Project Start	BL Project Finish	At Completion Duration	Start	Finish	Dec J	an	Qtr 1, 2022 Feb
ART-2120	Art Lake - Outside bay 3-8	28	09-Dec-19	13-Jan-20	511	16-May-20 A	29-Jan-22		Ar	t Lake - Outside bay 3-8
ART-2130	Art Lake - Outside bay 9-28	56	21-Nov-19	31-Jan-20	540	07-Apr-20 A	29-Jan-22		Ar	t Lake - Outside bay 9-28
ART-2140	Art Lake - Outside bay 50-52	14	31-Jan-20	15-Feb-20	398	28-Sep-20 A	29-Jan-22		Ar	Lake - Outside bay 50-52
Treatment Plant										
ART-1620	Treatment plant - Construct the wall(W1,2,3,6,7,8,9,11,12,13,14)	14	10-Dec-19	27-Dec-19	483	11-Jun-20 A	22-Jan-22		Treatment plant	Construct the wall(W1,2,3,6,7,8,9,11,12,13,14)
ART-1630	Treatment plant - Backfilling (by course material) to 197.1mPD, 8.2m Depth	30	28-Dec-19	05-Feb-20	330	11-Jan-21 A	21-Feb-22			Treal
Bioretention Sys	tem									
APT 2150	Attaka Batt124	70	01 Eab 20	20 Apr 20	400	12 Jun 20 A	16 Ech 22		-	
ADT:0100		12	44 law 00	23-Api-20	455	00 Aur 00 A	40 5-6 00		-	Art Lake - Part
AR1-2160	Art Lake - Part 3	32	14-Jan-20	22-FeD-20	455	06-Aug-20 A	16-FeD-22		-	Art Lake - Part
ART-2170	Art Lake - Part 6,7,12	16	17-Feb-20	05-Mar-20	453	08-Aug-20 A	16-Feb-22		L	Art Lake - Part
Underpass Tunne	d .									
VE Panels, Road	I Works, E&M									
TUN-3540	Tunnel - FS main, Socket & AFA equipment	0			376	19-Oct-20 A	22-Jan-22		Tunnel - FS mair	h, Socket & AFA equipment
TUN-3550	Underpass L1 paving, funiture, marking, signage from East Portal	0			376	19-Oct-20 A	22-Jan-22		Underpass L1 pa	wing, funiture, marking, signage from East Portal
TUN-3560	Tunnel - E&M 2nd Fix (Lighting & Equipment)	0			376	19-Oct-20 A	22-Jan-22		Tunnel - E&M 2n	d Fix (Lighting & Equipment)
TUN-3570	Underpass ABWF works	0			359	09-Nov-20 A	22-Jan-22		Underpass ABW	Fworks
TUN-3580	Tunnel - E&M Final Fix (Equipment connection & testing)	0			359	09-Nov-20 A	22-Jan-22		Tunnel - E&M Fir	al Fix (Equipment connection & testing)
TUN-3590	Tunnel - T&C & Statutory inspection	0			189	30-Jun-21 A	16-Feb-22			Tunnel - T&C &
Road L4 (RWA18.	Noise Barrier. RWA12. Utilities & Road Works)									
Retaining Wall R	wa12									
	14 (PMA12) Pay 17.20 construct well 8 headfill unto ±175	0			102	22 Jun 21 A	20. Jan 22			(RWA12) - Bay 17-20 construct wall & backfill upto
L4-5400	L4 (NVA12) - Day 17-20 Constitute wait & backlin upto +175	0			100	23-Juli-21 A	29-Jan-22			
L4-3530	L4 (RVVA12) - Bay 22 construct wall & backnill upto +170 (after twin 1950 pipe)	U			156	16-Aug-21 A	23-FeD-22	_		
L4-3540	L4 (RWA12) - Bay 22 construct wall & backfill upto +175	0			85	24-Feb-22	09-Jun-22			
L4-3630	L4 (RWA12) - Bay 21 construct wall & backfill upto +170 (after system A sub-way)	0			183	23-Jun-21 A	29-Jan-22		L4	(RWA12) - Bay 21 construct wall & backfill upto +1
L4-3640	L4 (RWA12) - Bay 21 construct wall & backfill upto +175	0			85	31-Jan-22	18-May-22		E	
Road Works - Dr	ainage									
L4-4260	L4 (Drainage) - Backfill for water main CH0 to CH200	0			268	02-Mar-21 A	22-Jan-22		L4 (Drainage) - E	ackfill for water main CH0 to CH200
L4-4280	L4 (Drainage) - Excavate & lay drain CH250 to CH300	0			274	02-Mar-21 A	29-Jan-22		L4	(Drainage) - Excavate & lay drain CH250 to CH30
L4-4300	L4 (Drainage) - Excavate & lay drain CH350 to CH400	0			274	02-Mar-21 A	29-Jan-22		L4	(Drainage) - Excavate & lay drain CH350 to CH40
L4-4310	L4 (Drainage) - Backfill for water main CH200 to CH400	0			69	29-Nov-21 A	23-Feb-22	_	C	l
Watermain & Uti	ities									
L4-4320	L4 (Watermain & UU) - Constuct watermain & UU CH0 to CH200	0			109	15-Dec-21 A	03-May-22			
14-4330	14 (Watermain & UU) - Constuct watermain & UU CH200 to CH400	0			109	15-Dec-21 A	03-May-22			
Poteining Wall P		-								
	DNA0_F04 & select fining to Day 10 yrs 1				450	00 km 01 t	04 D 04 4			
RWA9-1240	RWA9 - F/W & rebat fixing to Bay 16 wall	0			159	23-Jun-21 A	31-Dec-21 A	_		
RWA9-1250	RWA9 - Concrete laying for Bay 16 wall	0			1	03-Jan-22 A	03-Jan-22 A	• • • • • • • • • • • • • • • • • • •		
RWA9-1260	RWA9 - F/W & rebat fixing to Bay 13, 14 & 15 wall	0			21	04-Jan-22 A	27-Jan-22		RWA9	- F/W & rebat fixing to Bay 13, 14 & 15 wall
RWA9-1270	RWA9 - Concrete laying for Bay 13, 14 & 15 wall	0			31	04-Jan-22 A	11-Feb-22			RWA9 - Concrete laying f
RWA9 Bay 21 &	Bay 22									
RWA9-1400	RWA9 - F/W & rebat fixing to Bay 21 & 22 Wall	0			183	30-Jun-21 A	09-Feb-22			RWA9 - F/W & rebat fixing to
RWA9-1410	RWA9 - Concrete laying for Bay 21 & 22 Wall	0			3	10-Feb-22	12-Feb-22			RWA9 - Concrete laying
Road Works L5,L	1 east (between Junction L3 & L5)									
Road L1 east pa	t 2 (L5 toward PC system B)									
RL1b-1040	Road L1 east 2 - ducting for Street Lighting	0			618	19-Dec-19 A	19-Jan-22		Road L1 east 2 - ductir	g for Street Lighting
										· · · · · · · · · · · · · · · · · · ·
Pla	nned Bar (WP) 💠 🔷 Planned Milestone (WP)					3-mont		ing Programme	Dat	te F
Act	ual Bar 🔶 🔶 Milestone			Andorec	n Rd Qub n			ing i rogramme	15-Dec-2	1 C1-MPU202112
For	ecast Bar			15-Jan-	22	gramme				
									1	

	Page 2	of 3	
	Mar		Qtr 2, 2022 Apr
		0.0m Douth	
ment pi	ant - Backnilling (by course material) to 197.1mPL), 8.2m Depth	
1,2,4			
3			
5,7,12			
Statuto	y inspection		
+175			
4 (RWA	12) - Bay 22 construct wall & backfill upto +170 (after twin 1950 pir	be)
70 (afte	r system A sub-way)		
)			
) 4 (Drain	age) - Backfill for water main CH200 to CH400		
or Bay 1	3, 14 & 15 wall		
Bay 21	& 22 Wall		
.ог вау			
evisio	on C	hecked	Approved



俊和-上隧-浩隆聯營 CHUN WO - STEC - VASTEAM JOINT VENTURE

CONTRACT NO.NE/2016/01 SITE FORMATION AND INFRASTRUCTURE WORKS FOR DEVELOPMENT OF ANDERSON ROAD QUARRY SITE 3-MONTH ROLLING PROGRAMME

Activity ID	Activity Name	BL Project	BL Project	BL Project	At Completion	Start	Finish			Qtr 1, 2022
		Duration	Start	Finish	Duration			Dec	Jan	Feb
RL1b-1050	Road L1 east 2 - Road Pavement	0			534	17-Apr-20 A	29-Jan-22			Road L1 east 2 - Road Pavement
RL1b-1060	Road L1 east 2 - Landscape funiture	0			511	13-Jun-20 A	02-Mar-22			
Road L1 east part	3 (Junction L3 toward L5)									
RL1c-1060	Road L1 east 2 - Landscape funiture	0			493	13-Jun-20 A	09-Feb-22			Road L1 east 2 - Landscape f
Road Works PTT, L	1 west (between Junction L3 & PTT)									
Road L1 west part	t 1 (Box culvert BC1)									
RL1c-1140	Road L1 west 1 - Landscape funiture	0			227	21-Jun-21 A	23-Mar-22			
Hiking Trail Connec	cting to Wison Trail (Portion B5)									
Construction work	ks at Hiking Trail									
HIK10130	(NOC215) Delay due to Design review on Hiking Trail	0			203	06-Jul-21 A	09-Mar-22			
HIK10150	Resume work - Construction of Dwarf Walls for Hiking Trail (SP001 to SP001A)	0			75	10-Mar-22	11-Jun-22			

Planned Bar (WP) 🔷	 Planned Milestone (WP) Milestone 	3-month Rolling Programme	Date 15-Dec-21	C1-MPU202112	F
Forecast Bar	▼ Milestone	Anderson Rd Sub-programme 15-Jan-22			

		_	2 62	
		Pa	ge 3 of 3	Qtr <u>2, 2022</u>
	ļ	Mar		Apr
		Road L1 east 2 - Landscape funite	ure	
funiti	ure			
			Road L1 west 1	- Landscape funiture
		(NOC215) Delay due	e to Design review on Hikir	ng Trail
201		2	Charles	Annerica
xev	ISIO	II		Approved



Contract 2 (NE/2016/05)

D Task N	lime	Dentio	n Start Fnish Producessors	Suizessers	INEZ (MEZ	
NE/1	2015/05	218 d	1. 1. 2. A. 2. A. 2. 1. 5.1. 7.2. A. 2.1		Acci Greeter Octor Norman Destrict Izaan Greeter Mark Ann. Mar Ace An Ace Ace An Ace	E September
2 Pc	prtion 1	240 d	ays? Tue 03-08-21 Thu 26-05-22 ays? Tue 03-08-21 Thu 26-05-22			
3	E1 Escalator	84 da	ys Tue 03-08-21 Thu 11-11-21			
	PC1 to PC2	26 da 5 days	ys 70e 03-08-21 Wed 01-09-21 s Tue 03-08-21 Sat 07-08-21	12,26		
6	PC2 to PC3	9 days	s Mon 23-08-21 Wed 01-09-21	13,27		
8	PC3 to PC4 PC4 to PC5	5 days 5 days	s Fri 20-08-21 Wed 25-08-21 s Sat 14-08-21 Thu 19-08-21	14,28		
y	PC5 to PC6	5 days	s Mon 09-08-21 Fri 13-08-21	16,30		
10	Steel Frame Adjustment & Corrugated Sheet Roofing Insta	alla 32 dav	ys Mon 16-08-21 Tue 21-09-21	10.17		
12	PC1 to PC2	5 days	s Fri 20-08-21 Wed 25-08-21 5,26	19,48		
13	PC2 to PC3	5 days	s Fri 10-09-21 Wed 15-09-21 6	20,27,14,49		
14	PC3 to PC4 PC4 to PC5	5 days 5 days	s Thu 16-09-21 Tue 21-09-21 7,13 s Thu 16-09-21 Tue 21-09-21 8.16	21,28,50		
16	PC5 to PC6	5 days	s Fri 10-09-21 Wed 15-09-21 9	23,30,15,52		
17	Cladding Features & Gutter Installation	27 day	ys Sat 04-09-21 Thu 07-10-21	25 55 62		
19	PC1 to PC2	12 day	ys Sat 04-09-21 Fri 17-09-21 12	25,55,62 56,63		
20	PC2 to PC3	12 day	ys Thu 16-09-21 Thu 30-09-21 13	57,64		
21	PC3 to PC4 PC4 to PC5	12 day 12 day	ys Thu 23-09-21 Thu 07-10-21 14 ys Thu 23-09-21 Thu 07-10-21 15	58,65		
23	PCS to PC6	12 day	ys Thu 16-09-21 Thu 30-09-21 16	60		
24	Lighting & Unistrut & Lightning Protection	53 day	ys Mon 09-08-21 Mon 11-10-21			
26	PC1 to PC2	10 day	ys Mon 09-08-21 Thu 19-08-21 5	12,62		
27	PC2 to PC3	10 day	ys Thu 16-09-21 Tue 28-09-21 6,13	28,63		
28	PC3 to PC4 PC4 to PC5	10 day 10 day	ys Wed 29-09-21 Mon 11-10-21 7,14,27 ys Wed 29-09-21 Mon 11-10-21 8,15,30	64 65		
30	PC5 to PC6	10 day	ys Thu 16-09-21 Tue 28-09-21 9,16	29,66		
31	Flashing Installation	20 day	ys Thu 23-09-21 Mon 18-10-21			TTTTTTTTTTTTTTTTTTTTTTTTTTTTTTTTTTTTTTT
33	RS1 to PC1	6 days 2 days	5 Inu 23-09-21 Wed 29-09-21 5 Thu 23-09-21 Fri 24-09-21	40,34,90,83		
31	PC1 to PC2	2 days	Sat 25-09-21 Mon 27-09-21 33	35,90,84		
35	PC2 to PC3 PC3 to PC4	2 days	Tua 28-09-21 Wed 29-09-21 34	90,85		
37	PC4 to PC5	2 days	Sat 25-09-21 Mon 27-09-21 36	38,90,87		
38	PC5 to PC6	2 days	Tue 28-09-21 Wed 29-09-21 37	90,88		
40	RS1 to PC1	18 day 6 days	rs Sat 25-09-21 Sat 02-10-21 33	41		
41	PC1 to PC2	6 days	Mon 04-10-21 Sat 09-10-21 40	42		
42	PC2 to PC3	6 days	Mon 11-10-21 Mon 18-10-21 41	44		
-14	PC4 to PC5	6 days	Mon 04-10-21 Sat 09-10-21 43	45		
45	PC5 to PC6	6 days	Mon 11-10-21 Mon 18-10-21 44			
47	R51 to PC1 (Entrance & Landing)	34 day 12 day	rs Mon 13-09-21 Mon 25-10-21 rs Mon 20-09-21 Tue 05-10-21 11	48		
48	PC1 to PC2 (Landing)	5 days	Wed 06-10-21 Mon 11-10-21 47,12	49		
50	PC2 to PC3 (Landing) PC3 to PC4 (Landing)	5 days 5 days	Tue 12-10-21 Mon 18-10-21 48,13 Tue 28-09-21 Mon 04-10-21 53.14	51		
51	PC4 to PC5 (Landing)	5 days	Tue 05-10-21 Sat 09-10-21 50,15	52		
52	PC5 to PC6 (Entrance & Landing) Staircase	12 day	rs Mon 11-10-21 Mon 25-10-21 51,16	50		
54	Downpipe	17 day	rs Sat 18-09-21 Sat 09-10-21			
55	RS1 to PC1	2 days	Sat 18-09-21 Mon 20-09-21 18	8		
57	PC2 to PC3	2 days 2 days	Sat 02-10-21 Mon 04-10-21 20	63		
58	PC3 to PC4	2 days	Fri 08-10-21 Sat 09-10-21 21	64		
60	PC5 to PC6	2 days	Sat 02-10-21 Mon 04-10-21 23	66		
61	Dismantling of Bamboo Scaffolding	18 day	rs Tue 21-09-21 Wed 13-10-21			
63	PC2 to PC3	2 days 2 days	Tue 05-10-21 Wed 06-10-21 55,25,18	70 71		
64	PC3 to PC4	Z days	Tue 12-10-21 Wed 13-10-21 58,28,20	72		
66	PC4 to PC5	2 days 2 days	Fri 08-10-21 Sat 09-10-21 50,30,22	73		
67	GMS Railing with PMMA	29 day	s Mon 20-09-21 Tue 26-10-21			
69	Pole Installation R51 to PC1	22 day 3 days	s Mon 20-09-21 Mon 18-10-21 Mon 20-09-21 Thu 23-09-21	76.70		
70	PC1 to PC2	3 days	Fri 24-09-21 Mon 27-09-21 62,69	77		
72	PC2 to PC3 PC3 to PC4	3 days 3 days	Thu 07-10-21 Sat 09-10-21 63 Fri 15-10-21 Mon 18-10-21 64	78		
73	PC4 to PC5	3 days	Fri 15-10-21 Mon 18-10-21 65	80		
74	PC5 to PC6	3 days	Mon 11-10-21 Wed 13-10-21 66	81		
76	RS1 to PC1	∠4 day 5 days	s rr 24-09-21 Set 23-10-21 Fri 24-09-21 Wed 29-09-21 69	90,83,84,85		
77	PC1 to PC2	5 days	Tue 28-09-21 Mon 04-10-21 70	90,84,83,85		
79	PC2 to PC3 PC3 to PC4	5 days 5 days	Mon 11-10-21 Sat 16-10-21 71 Tue 19-10-21 Sat 23-10-21 77	90,85,83,84		
80	PC4 to PC5	5 days	Tue 19-10-21 Sat 23-10-21 73	90,87,86,88		
31	PC5 to PC6	5 days	Fri 15-10-21 Wed 20-10-21 74	90,88,86,87		
83	RS1 to PC1	2 days	Mon 18-10-21 Tue 19-10-21 76,77,78,33	90		
85	PC1 to PC2	2 days	Mon 18-10-21 Tue 19-10-21 77,76,78,34	90		
36	PC3 to PC4	∠ days 2 days	Mon 15-10-21 Tue 15-10-21 78,76,77,35 Man 25-10-21 Tue 26-10-21 79,80,81,36	90		
37	PC4 to PC5	2 days	Man 25-10-21 Tue 26-10-21 80,79,81,37	90		
85 89	PC5 to PC6 Submission for LE5	2 days 13 days	Mon 25-10-21 Tue 26-10-21 81,79,80,38 s Wed 27-10-21 Wed 10-11-21	90		
90	AP Inspection, Testing & Submission Preparation	12 days	s Wed 27-10-21 Tue 09-11-21 79,80,36,81,37,38,76,77,78,33,34,35,83,84,85,86,87,	18 91		
91 .	Submission	1 day	Wed 10-11-21 Wed 10-11-21 90		I	
93	Manhole	30 days	s Fri 20-08-21 Fri 24-09-21	95		
94	Drain Pipe Installation	30 days	s Fri 20-08-21 Fri 24-09-21	95		
96	resung Telemetry System to Escalator	∋ days 68 days	sar 23-03-21	 А		
97	XP / TTA	6 days	Wed 15-09-21 Tue 21-09-21	98		
- 99	Cabling Works outside Site Boundary	50 days 5 days	s inu 25-09-21 Fn 29-10-21 97 Sat 30-10-21 Thu 04-11-21 98	פע 101		
100	Cabling Works at Escalators	5 days	Fri 20-08-21 Wed 25-08-21	101		
101	Testing Traffic Light Box	5 days 42 days	Fri 05-11-21 Wed 10-11-21 99,100,106 s Sat 21-08-21 Mon 11-10-21	109		
103	Mounting Installation	12 days	s Wed 15-09-21 Wed 29-09-21	105		
104	Procurement of Traffic Box Box Installation and Cabling	34 days 5 days	s Sat 21-08-21 Thu 30-09-21 Sat 02-10-21 Thu 07-10-21 103,104	105		
Project: NE201	1605_Programme_20 T=k Miles	1.02	Project Scenario Project Scenario Intervie Milestone	Massai Task 🚺	i i i i i i i i i i i i i i i i i i i	1
	Spin Spin	<u></u> 79	hautve Toak hautve Summary) Durations-rely	Serie Manal Section 1 Fault-se's 1 Estate Martin Section Concil Westerne Promo	

ID Ta	Name	Dzitis	n Start	Finish	Protectioners		Suzzurs												
								6	Asoca B / M	E Serverier	Octoer 8 i vi	I E Norther	M F B M	E Jasan	v i s Ferun	Math		Aml	
206	Testing	3 days	Fri 08-10-21	Mon 11-10-2	1 105		101	Mara		1 2 1 9 1 1 1 1 1 2			<u></u>		<u> </u>	<u> </u>	1		1
107	Fall Arrest System Installation	5 days	Thu 30-09-21	Wed 06-10-2:	t		109				5255 <u>5</u>								
109	Painting Handover of Escalators	30 da 1 day	rs Fri 20-08-21	Fri 24-09-21	101 05 108 107		109			00000000000000000000000000000000000000									
110	Landscaping on Slope	29 da	riu 11-11-21	Mon 27-09-21	101,95,108,107					F	-	3							
111	U-Channel	7 days	Tue 24-08-21	Tue 31-08-21	-		112			-	•								
112	Planting	14 da	s Wed 01-09-2	1 Thu 16-09-21	111		113		1	accountered as									
- 113	Hydroseeding	7 days	Fri 17-09-21	Sat 25-09-21	112		114			Sources_	1								
114	Handover of Slope	1 day	Mon 27-09-2	1 Mon 27-09-21	113		126,128,127				·								
116	XP & TTA Obtainment	28 day	wed 01-17-7	Wed 05-01-22									204762359314427331427						
117	Remove Ext. Planter Wall	28 day	s Fri 20-08-21	Tue 21-09-21					and the part of th					the officer of the first of the second s					
118	Remove Ext. Tree	12 day	s Fri 20-08-21	Thu 02-09-21						NOTES STATE									
119	Construction of Pavement	30 da	s Fri 20-08-21	Fri 24-09-21															
120	Construction of Pavilon, Bench	1 dayi	Fri 20-08-21	Fri 20-08-21						3									
121	Construction of Sau Mau Ping Memorial Park	69 da	s Tue 01-03-22	Thu 26-05-22															
122	Submission for Pole Light, Pavilion, Bench	15 day	s Tue 01-03-22	Thu 17-03-22			123									2,002,002,002	areas a		
124	Construction of Pavilon	50 0ay	s Fri 18-03-22	Tue 26-04-22	122		124,125										1000000000	-Selectors and the	
125	Construction of Pole Light with Cabling	10 day	s Wed 27-04-2	2 Tue 10-05-22	123		130												
126	Construction of Pavement	56 day	s Tue 01-03-22	Wed 11-05-22	114		130,129									Reference inter	NAMES OF COMPANY		
127	Construction of Irrigation System	Z8 day	s Tue 01-03-22	Fri 01-04-22	114		130									100000		2021)	
128	Construction of Railing	12 day	s Tue 01-03-22	Mon 14-03-22	114		130 .	.								×.			
129	Planting	12 day	s Thu 12-05-22	Wed 25-05-22	126		130												
131	Handover to LCSD	1 day	Thu 26-05-22	Thu 26-05-22	124,125,126,128,12	9,127													
132	Portion 2	300 da	vs Tue 24-08-21	Sat 27-08-22						·····									
133	E3-PC2 Pile Cap, Column and Pier	163 da	ys Wed 01-09-2	1 Sat 19-03-22						r							1		
134	Concrete Capping Works	6 days	Wed 08-09-2	1 Tue 14-09-21			137			352223									
135	Temporary Working Platform for Piling	12 day	s Wed 01-09-2	1 Tue 14-09-21			137	2111A		TANGGREEN									
126	Risk Assessment for Existing RC Canopy at Fu Wah Court	12 day	s Fri 24-09-21	Fri 08-10-21			137,172			3505									
138	Anchor Plate for Pile Heads incl. Terting	40 day	5 3at 09-10-21	Thu 02-12-24	135,134,136		138,154,155						Manager and American Street and American Stree	Τ		1			
139	Construction of Blinding Layer	2 davs	Fri 03-12-21	Sat 04-12-21	138		140						non-states and		ł	1			
140	Constructiono of Pile Cap	10 day	s Mon 06-12-2:	1 Thu 16-12-21	139		141						The second se		ł	1			
141	Construction of Column	12 day	s Fri 17-12-21	Mon 03-01-22	140		142						tes		1				
142	Construction of Pier Head and Corbal	22 day	s Tue 04-01-22	Fri 28-01-22	141		143,144							*	·····································	1			
143	Concrete Curing for Pier Head	28 day	s 5at 29-01-22	Sat 05-03-22	142		145								Taxaaliyaad	ſ			
145	Erect Temp. Steel Support (for 2nd Session, E3-EB1)	3 days	Wed 09-02-22	2 Fri 11-02-22	142		145								(7)(*		Det Tartes et Data		
146	E3-FB1 Bridge	243 da	vs Tue 24-08-21	Tue 21-06-22	144,143		137		-							2009			
147	Design Submission of Temporary Support at E3-Abt	1 day	Tue 24-08-21	Tue 24-08-21			154,148,155									1			
148	Design Submission Approval of Temporary Support at E3-A	bt 28 day	Wed 24-11-21	1 Tue 28-12-21	147		151							news-	1				
140											[1			
150	Shop Drawing Submission of E3-FB1	1 day	Fri 27-08-21	Fri 27-08-21			154,150,155			. 5			•						
154	Procurement of Material for Terms Support	28 day	Wed 24-11-21	Ute 28-12-21	149		152,153									1			
152	Procurement / fabribation for E3-FB1 (1st Session)	50 day	Wed 29-12-21	Tue 01-03-22	150		156							↓ I		and the second se			
153	Procurement / fabribation for E3-FB1 (2nd-4th Session)	50 day	Mon 03-01-22	2 Fri 04-03-22	150		157,158,159		-					•					
154	Erect Temp. Support at E3-Abt (For 1st Session, E3-FB1)	6 days	Tue 15-02-22	Mon 21-02-22	147,149,151,137,17	5	156								+	in the second se			
155	Bearing Installation at E3-Abt	3 days	Thu 13-01-22	Sat 15-01-22	147,149,151,137		156							1		F			
157	Install E3-FB1 - 1st Session (from E3-Abt)	6 days	Wed 02-03-22	2 Tue 08-03-22	152,154,155		176,157,158									100-0000			
157	Install E3-FB1 - 2nd Session (from E3-PC2)	3 days	Mon 21-03-22	2 Wed 23-03-22	145,156,153		231,158										`		
159	Install E3-FB1 - 4th Session (E3-LT1 to E3-PC2)	6 days	Mon 28-03-22	Sat 02-04-22	158,157,155		159										T,	20 Juli 2	
160	Concreting Bridge Deck	12 day	Mon 04-04-22	Thu 21-04-22	159		163.161.162												
161	Construction of RC Planters	28 day	Fri 22-04-22	Thu 26-05-22	160		168,162												4
162	Floor Tiling	21 day	Fri 27-05-22	Tue 21-06-22	160,161														.
163	Erection of Scaffolding	10 day	Fri 22-04-22	Wed 04-05-22	160		165,166,164												8
165	Installation of Corrugated Roof Panel & Gutter	21 day	Thu 05-05-22	Mon 30-05-22	163		167,169,170,165												
166	Installation of E&M Works incl. Lighting. Power Cable (From	12 day. 1 28 day	Thu 05-05-22	Wed 08-06-22	163		170 253												
	E3 Pillar to E2 Pillar)	,					170,200												
167	Installation of Downpipe	6 days	Tue 31-05-22	Tue 07-06-22	164		170												
168	Installation of Irrigation System	12 day:	Fri 27-05-22	Fri 10-06-22	161		170												
107	Fail Arrest System	6 days	Tue 31-05-22	Tue 07-06-22	164														
171	Covered Walkway, Sump Pit, E2 Pillar Box	215 da	vied 13-00-22	Mon 04-07-22	104,105,100,167,100														
172	Excavation of Footing and Sump Pit	69 day	Sat 09-10-21	Fri 31-12-21	136		173,174								i				
173	Construction of Footing of Covered Walkway	28 days	Mon 03-01-22	Mon 07-02-22	172		175							*	and the second second		*****	1	
174	Construction of Sump Pit	28 day	Mon 03-01-22	Mon 07-02-22	172		175,182							Andrew and a first		├ ────┼			
175	backnilling and compaction Test	6 days	Tue 08-02-22	Mon 14-02-22	173,174		176,154								Toolog-]			
177	Installation of Roofing (Covered Walkway)	6 davs	Wed 16-03-22	Tue 22-03-22	176		181.183 184 190 203 179 1	182								38	COLOR DE LA COLOR		
178	Construction of E2 Pillar Box (Civil)	28 days	Wed 23-03-22	Thu 28-04-22	177		179,180										The second s		
179	Construction of E2 Pillar Box (E&M)	12 days	Fri 29-04-22	Sat 14-05-22	178		180												
180	E2 Pillar Energized from E3 Pillar	1 day	Mon 04-07-22	Mon 04-07-22	253,178,179		200										Ш		
181	Construction of Pavement	Z8 days	Wed 23-03-22	Thu 28-04-22	177				1.0								∭anaer		STREETER IN
183	Installation of irrigation Pipe	∡⊥ days 6 dave	Wed 23-03-22	Tue 29-03-77	177												Report	antheological and	1000000
184	Fail Arrest System	6 days	Wed 23-03-22	Tue 29-03-22	177												Normal Action of the International Action of the Internati		
185	E2 Lift Tower	248 da	s Tue 14-09-21	Tue 19-07-22						I				i					
186	Scaffolding Modification	6 days	Tue 14-09-21	Mon 20-09-21			187,188,189			Taska I									
187	Window and Louvre Installation	28 days	Tue 21-09-21	Tue 26-10-21	186		190,197				ta an	1	-				—		
189	maig works on wall Waterpropfing Works	∠8 days	Fri 15-10-21	Tue 16-11-21	185		190						3						
190	Erect Falseworks for E2-LT1 Staircase Landing at +62 85mPD) 6 davs	Wed 23-03-77	Tue 29-03-22	177,187.188,189		191		*****		-								
:91	Construction of E2-LT1 Staircase Landing at +62.85mPD	6 days	Wed 30-03-22	Wed 06-04-22	190		192,195											t	
192	Erect Falseworks for E2-11 RC Decking at +66.3mPD	8 days	Thu 07-04-22	Tue 19-04-22	191		193,205						97-1091.					X arter	
193	Construction of E2-LT1 RC Decking at +66.3mPD	10 days	Wed 20-04-22	Sat 30-04-22	192		194												T RE
194	Installation of Steel Frame	6 days	Tue 03-05-22	Tue 10-05-22	193		195,196												
196	Tiling Works	12 days 28 days	Wed 11-05-22 Wed 11-05-22	Mon 13-06-77	134,131		101												
197	E&M Works	28 days	Wed 27+10+21	Sat 27-11-21	187		198,199					1							
193	Cabling for Permanent Power	12 days	Mon 29-11-21	Sat 11-12-21	197		201												
199	Lift installation	75 days	Mon 29-11-21	Wed 02-03-22	197		201,200												
200	Lift Testing	12 days	Tue 05-07-22	Mon 18-07-22	199,253,180		201						and the second se						
201	LES Submission to EMSD	1 day	Tue 19-07-22	Tue 19-07-22	199,198,195,253,200								and the second se				_		
303	Excavation for Column Construction	3 dave	Wed 23-03-22	mon 06-06-22	177		204										1		
204	Construction of Column	12 days	Sat 26-03-22	Sat 09-04-22	203		205	1					And a compared of the second se						
205	Construction of Pier Head and Corbal	10 days	Wed 20-04-22	Sat 30-04-22	204,192		207,208,206										10×0%-0		
206	Concrete Curing for Pier Head and Corbai	28 days	Tue 03-05-22	Mon 06-06-22	205		293												
308	Bearing Installation	3 days	Tue 03-05-22	(hu 05-05-22 Mon 06-06-22	205		293						1 101 v 401						
	and the second s	20 0035		Brist Come		laura Maria	Steed 7:5 post-		I Server C. C. C.			Taka second	(100) Dec Esc.	p					
Project: NE	201605_Programme_20 Split +++++++++ Satar	2r)		hunive Tuk	,	Increase Summary 4	i Dunton-nis 2000	omersensist A Referencies A	annan sammary Robup 🥫 Annai Sammary 🔰	Probative D	Extrail Extrail	i 1983 I Milestine 🔷	Crated Balance	Critical Split Recipital Progress	Mincil Pr	gui -			
												Page 2							



10 Ta	da Name	Duration	Sian	Faish	Producessors	Successors	loney	
							E Aled Sector Date Number Date Sector And	1 1
309	Reinstatment	12 days	Tue 07-06-22	Mon 20-06-22	208			1 1
210	E3-LT1 Lift TowerPortion 2	294 days	i Tue 31-08-21	Sat 27-08-22				
211	E3-UT1 lift tower structure	57 days	Tue 31-08-21	Mon 08-11-21				
212	15tb pour (+59 7 + +63 3mPD)	75 days	Tue 31-08-21	Wed 29-09-21		213		
213	16th pour (+63 3 + +66 5mPD)	12 days	Thu 20.09.21	Eri 15 10 21	212	214		
714	13th pour (+65.5 + +66.5mPD)	10 4-14	(iiii 30-03-21 C-1 1 C 10 21	11110-10-21	212	214		
215	17(n pour (+66.5 + +70.45mPD)	10 days	Sat 16-10-21	wed 27-10-21	213	215		
215	18th pour (+/0.45 + +/1.35mPD & Partial Parapet wall)	10 days	Inu 28-10-21	Mon 08-11-21	214	217,258	GUNT CONFIG	
216	E3-ST1 Staircase (landing & stairs)	128 days	Wed 22-12-21	Thu 02-06-22				
217	1st pour (+25.0 - +28.6mPD)	7 days	Wed 22-12-21	Fri 31-12-21	215	218		
218	2nd pour (+28.6 - +32.2mPD)	10 days	Mon 03-01-22	Thu 13-01-22	217	219		
219	3rd pour (+32.2 - +35.8mPD)	10 days	Fri 14-01-22	Tue 25-01-22	218	220		
220	4th pour (+35.8 - +38.8mPD)	10 days	Wed 26-01-22	Wed 09-02-22	219	221		i i
221	5th pour (+38.8 - +41.8mPD)	10 days	Thu 10-02-22	Mon 21-02-22	220	222		
222	6th nour (+41 8 - +45 dmPD)	10 days	Tue 22-02-22	Fri 04-03-22	221	773	**************************************	
223	7th pour (+45.4 - +49.0m90)	10 days	Sat 05-03-22	Wed 16-02-22	222	220		
224	7(1) pour (+45.4 - +45.0(1)PD)	to days	341 03-03-22	Weg 18-03-22	222	224		
	8th pour (+49.0 - +52.6mPD)	10 days	Inu 17-03-22	Mon 28-03-22	223	225		
	9th pour (+52.6 - +56.2mPD)	10 days	Tue 29-03-22	Sat 09-04-22	224	226		ป
226	10th pour (+56.2 - +59.7mPD)	10 days	Mon 11-04-22	Mon 25-04-22	225	227		46,085
227	11th pour (+59.7 - +63.3mPD)	10 days	Tue 26-04-22	Sat 07-05-22	226	228,262		
228	12th pour (+63.3mPD)	7 days	Tue 10-05-22	Tue 17-05-22	227	229,249		
229	13th pour (+66.5mPD)	7 days	Wed 18-05-22	Wed 25-05-22	228	230		
230	14th pour (+70,45mPD)	7 days	Thu 26-05-22	Thu 02-06-22	229			
231	Frection of small crane at roof	15 days	Thu 24-03-22	Mon 11-04-22	157	232		34
232	Ramoval of towar crans & fasting	7 days	Tup 12:04:32	Eri 22 04 22	221 150	224		*
211	Relactatement werks for towns some slob	75 days	F-+ 22 04 22	11-22-04-22	101,100	154		
73.5	Cick Operating Delegation cover chaine state	30 Jawa	54122-04-22	1101 00-00-22	222			
376	Siao Opening Reinstatement	28 days	Sat 23-04-22	Fn 27-05-22	232	235,262,266		
	Parapet wan (Remaining)	/ days	5at 28-05-22	wion 06-06-22	234	243,244,236		
	Kernoval of small crane	14 days	1 ue 07-06-22	wed 22-06-22	235			
257	Steel truss - welding works & welding test	31 days	Thu 23-09-21	Sun 31-10-21		238,239		
238	Window installation	61 days	Mon 01-11-21	Thu 13-01-22	237	240		
239	Louvre installation	61 days	Mon 01-11-21	Thu 13-01-22	237	240		
240	Water tightness test for E3-LT1 louvre / windows	12 days	Fri 14-01-22	Thu 27-01-22	238,239	24155,24255,248,264		
241	Tiles (Wall/Staircase/Floor)	90 days	Fri 14-01-22	Sat 07-05-22	240SS	246		
242	Paint	90 days	Fri 14-01-22	Sat 07-05-22	240SS	246		
243	Fall Arrest System (Roof)	6 davs	Tue 07-06-22	Mon 13-06-22	235			
241	Waterproof (Roof)	6 dave	Tue 07-06-77	Mon 13-06-77	235	245		
245	Water tightness test for F2-I T1 roof	4 days	Tue 14-06-22	Fri 17-06-77	744	246		
216	Discount of an field and discount for	4 uays	Tue 14-00-22	FIT 17-00-22	244	248		
147	Dismantie of scattoloing working platform	30 days	Sat 18-06-22	Sat 23-07-22	245,241,242	247		
247	Glass canopy at G/F	15 days	Mon 25-07-22	Wed 10-08-22	246			
248	Install inclined plate at the recess of Windows & Louvres	59 days	Fri 04-02-22	Thu 14-04-22	240			2003
249	Railing (GMS) on staircase	59 days	Wed 18-05-22	Wed 27-07-22	228			
150	E&M works	219 days	Mon 04-10-21	Sat 02-07-22				
251	Incoming Cable by CLP	90 days	Mon 04-10-21	Thu 20-01-22		253		
252	E3 Pillar Box (Civil)	65 days	Mon 18-10-21	Tue 04-01-22		253,260		
253	E3 Pillar Energized by CLP	1 day	Sat 02-07-22	Sat 02-07-22	251,252,166,262,260	267,201,200,180		
254	Telemetry Duct	47 days	Fri 15-10-21	Wed 08-12-21		25555		
255	Drainage Manhole	109 days	Fri 15-10-21	Fri 25-02-22	254SS			
256	Sump pit (Civil)	92 days	Mon 01-11-21	Tue 22-02-22		259		
257	Electrical installation	188 days	Tue 09-11-21	Thu 30-06-22				
258	Lift Shafts	90 days	Tue 09-11-21	Mon 28-02-22	215	261		
259	Sump Pit (E&M)	30 days	Wed 23-02-22	Tue 29-03-22	256			
260	Pillar Box (E&M)	30 days	Wed 05-01-22	Fri 11-02-22	252	253		
261	Lighting	31 days	Tue 01-03-22	Wed 06-04-22	258			
262	Machine room	28 days	Sat 28-05-22	Thu 30-06-22	234,227	253		
263	Lift installation	155 days	Fri 28-01-22	Tue 09-08-22				
264	Lift Car Installation	90 days	Fri 28-01-22	Mon 23-05-22	240	26555.267		(SASTREE)
265	Door frames / Misc.	90 days	Fri 28-01-22	Mon 23-05-22	26455	267		5554556687
266	Machine room installation	30 davs	Sat 28-05-22	Mon 04-07-22	234	267.268		
367	Self test	30 days	Tue 05-07-22	Mon 08-08-22	266.253.264.265			
26%	T&C	30 days	Tue 05-07-22	Mon 08-08-22	266	269		
269	Submit LES to EMSD	1 day	Tue 09-08-22	Tue 09-08-22	268	270		
270	Pre-handing over inspection (F3-LT1 & F3-FB1) by	15 days	Wed 10-08-22	Fri 26-08-22	269	271		
	HyD/Structure Maintenance							
271	Ready to open Lift Tower E3-LT1 / Footbridge E3-FB1 to	1 day	Sat 27-08-22	Sat 27-08-22	270			
ĺ	public							
272								
273	Portion 3	276 days	Mon 20-09-21	Fri 26-08-22			Provide and the second se	
274	E2-FB1 Bridge	276 days	Mon 20-09-21	Fri 26-08-22				
275	Shop Drawing Approval of E3-FB1	7 days	Mon 20-09-21 1	Tue 28-09-21		276	30600506	
276	Procurement of Material for E3-FB1	45 days	Mon 04-10-21	Thu 25-11-21	275	278		
277	E2-FB1 - 1st Span (Housing Lift Tower to E2-P2)	69 davs	Fri 21-01-22	Tue 19-04-22				
278	Bridge Erection (Only allow on Sat to Sun / Public Holiday)	2 davs	Fri 21-01-77	Sun 23-01-77	276	279		
279	Remaining Steelworks before Bridge Deck Casting	6 davs	Mon 24-01-22	Sat 29-01-77	278	280		
250	Concreting Bridge Deck	12 dave	Mon 31-01-22	Wed 16-02-22	279	781 283 787	Automatica additional additiona	
281	Construction of BC Planter	78 riase	Thu 17-02-22	Mon 21_02.22	280	789 788 207 787		
282		20 Udy5	Tue 22 02 22	Tue 10 04 00	100 201	103,100,307,202		507000
722	noor nung	21 gays	Tue 22-03-22 1	rue 19-04-22	200,201			
د <u>من</u> ، در	Erection of Scattolding	10 days	inu 17-02-22 N	Mon 28-02-22	280	284,285,286,287		
404	installation of Corrugated Roof Panel & Gutter	21 days	rue 01-03-22 1	1 nu 24-03-22	285	287,290,291,285		
100	installation of GRP Feature	12 days	rn 25-03-22 F	нп 08-04-22	283,284	291		
286	Installation of E&M Works incl. Unistruct & Lighting	28 days	Tue 01-03-22 F	Fri 01-04-22	283	291		
287	Installation of Downpipe	6 days	Fri 25-03-22 1	Thu 31-03-22	284,283	291		
288	Installation of Railing	12 days	Tue 22-03-22	Mon 04-04-22	281			
289	Installation of Irrigation System	6 days	Tue 22-03-22	Mon 28-03-22	281	291		
290	Fall Arrest System	6 days	Fri 25-03-22 7	Thu 31-03-22	284	291		
291	Dismantling of Scaffolding	6 days	Sat 09-04-22 T	Tue 19-04-22	285,286,287,289,284,290			37577255
292	E2-FB1 - 2nd Span (E2-P2 to E2-LT1)	69 days	Tue 07-06-22	Fri 26-08-22				
293	Bridge Lifting (Only allow on Sat to Sun / Public Holiday)	2 days	Tue 07-06-22	Wed 08-06-22	206,207	294		
294	Remaining Steelworks before Bridge Deck Casting	6 days	Thu 09-06-22 V	Wed 15-06-22	293	295		
295	Concreting Bridge Deck	12 days	Thu 16-06-22	Wed 29-06-22	294	296,298,297		
2%6	Construction of RC Planter	28 days	Thu 30-06-22	Tue 02-08-22	295	303,304,297		
297	Floor Tiling	21 days	Wed 03-08-22	Fri 26-08-22	295,296	· ····· ··· · · · · · ·		
298	Erection of Scaffolding	10 days	Thu 30-06-22	Tue 12-07-22	295	299,300,301,302		
299	Installation of Corrugated Roof Panel & Gutter	21 days	Wed 13-07-22 F	Fri 05-08-22	298	305,302,300,306		
300	Installation of GRP Feature	12 days	Sat 06-08-22 F	Fri 19-08-22	298,299	306		
301	Installation of E&M Works incl. Unistruct & Lighting	28 days	Wed 13-07-22 S	Sat 13-08-22	298	306		
302	Installation of Downnine	6 days	Sat 06-08-22 F	Fri 12-08-22	298,299	306		
101			!		and the second			
1.44	Installation of Irrigation System	6 days	Wed 03-08-22 T	Tue 09-08-22	296	306		
304	installation of Irrigation System Installation of Railing	6 days 12 days	Wed 03-08-22 T Wed 03-08-22 T	Tue 09-08-22	296 296	306		
301	installation of Irrigation System Installation of Railing Fall Arrest System	6 days 12 days 6 days	Wed 03-08-22 T Wed 03-08-22 T Sat 06-08-22 F	Tue 09-08-22 Tue 16-08-22 Fri 12-08-22	296 296 299	306		
304 305 306	Installation of Irrigation System Installation of Railing Fall Arrest System Dismantling of Scaffolding	6 days 12 days 6 days 6 days	Wed 03-08-22 T Wed 03-08-22 T Sat 06-08-22 F Sat 20-08-22 F	Tue 09-08-22 Tue 16-08-22 Fri 12-08-22 Fri 26-08-22	296 296 299 300,301,302,303,305,299	306		
304 305 306 307	Installation of Irrigation System Installation of Railing Fail Arrest System Dismantling of Scaffolding Underground Orainage	6 days 12 days 6 days 6 days 50 days	Wed 03-08-22 T Wed 03-08-22 T Sat 06-08-22 F Sat 20-08-22 F Tue 22-03-22 V	Tue 09-08-22 Tue 16-08-22 Fri 12-08-22 Fri 26-08-22 Wed 25-05-22	296 299 300,301,302,303,305,299 281	306 306 308		*****
304 305 306 307 308	Installation of Irrigation System Installation of Railing Fall Arrest System Dismantling of Scaffolding Underground Orainage Road Surface Reinstatement	6 days 12 days 6 days 6 days 50 days 28 days	Wed 03-08-22 T Wed 03-08-22 T Sat 06-08-22 F Sat 20-08-22 F Tue 22-03-22 Y Thu 26-05-22 T	Tue 09-08-22 Tue 16-08-22 Fri 12-08-22 Fri 26-08-22 Wed 25-05-22 Tue 28-06-22	296 299 300,301,302,303,305,299 281 307	306 306 308		
305 305 306 307 308	installation of Irrigation System Installation of Railing Fail Arrest System Dismantling of Scaffolding Underground Orainage Road Surface Reinstatement	6 days 12 days 6 days 6 days 50 days 28 days	Wed 03-08-22 T Wed 03-08-22 T Sat 06-08-22 F Sat 20-08-22 F Tue 22-03-22 V Thu 26-05-22 T	Tue 09-08-22	296 299 300,301,302,303,305,299 281 307	306 306 308		

oject: NE201605_Programme_20	Tuk	Mictine	\$	Project Summary	inactive Milerance	Magnal Task	Manual Summary Ro	Cup encounterences Stati-ray	C	Extensal Tasks	Deafine	🕹 Cr.	raturai Spila	. Marsal Progress -	
· · · ·	Spi.s	Summary	H 1	baurave Turk	inactore Summary	1 Darst-m-salv	Menual Summary	Finish-univ	3	Extend Milestone	 Critical 	Provide State of Provid	oges -		
										Page 3					





Contract 3 (NE/2017/03)

\\192.168.1.230\z\Jobs\2016\TCS00864 (CEDD)\600\EM&A Report Submission\Monthly EM&A Report\2022\February\R0535v2.docx

	cuvity Name	Duration	Stan	FILISI	Jan Feb	Mar
NE2017/03 - ARQ PHASE 2A - Month	nly Programme Update (202112)-0 220125	1064	29-Aug-20 A	17-Apr-23	49 50	51
Road Improvement Works Location	n 1 (RIW1)	854	29-Aug-20 A	17-Apr-23		
Construction Works		854	29-Aug-20 A	17-Apr-23		
CON10728C Ap	pply CNP for temporary diversion (2 nos. application & 2 nos. extension)	26	29-Aug-20 A	04-Dec-21		
CON10650 Co	Construct RW wall (RWC2 type 1a & 1 [Bay 2 to Bay 1])	225	04-Nov-20 A	19-Jan-22		
CON12110 Dr	Drainage & utilities works (RWC2 type 4, 6, 7, 8)	60	21-Jun-21 A	06-Jan-23		
CON10748 EL	LS works at RWC2 type 3 (7500 m3, 100 m3/d, 2 teams)	38	05-Jul-21 A	22-Nov-21		
CON12130 Rd	Road works (RWC2 type 4, 6, 7, 8)	60	26-Jul-21 A	21-Feb-23		
CON12134 Ins	nstall stone facing for wall (RWC2 type 4, 6, 7, 8)	72	02-Aug-21 A	17-Apr-23		
CON11550 CC	Construct plling foundation at FE1 Type 2 (12nos, 2d/no, 1 team)	24	19-Aug-21 A	29-Nov-21		
CON12356E CC	Construct 4nos, sewage manhole & sewage drainage diversion (near KS27 w	130	20-Aug-21 A	15-Feb-22		
CON10748C (N	NCE144) Unforeseen rock boulders found at RWC2 type 3, near bay 21 to b	130	13-Sep-21 A	31-Dec-21		
CON10268 Tr	rial pit excavation (RWC2 type 5)	60	21-Sep-21 A	02-Dec-21		
CON10750 Co	Construct socket H-pile works (RWC2 type 3; 400nos, 3d/no, 4 teams)	300	13-Oct-21 A	02-Dec-22		
CON11328A (C	CE[TBA]) Cable duct alignlemt identify on CT5 & SLG meeting	42	26-Oct-21 A	13-Dec-21		
CON12370A (N	NCE179) Unforeseen ground condition obstructed sheet-pile installation at KS	30	29-Oct-21 A	30-Dec-21		
CON10231B (C	CE358) Prepare & subletting for watermain diversion design works; & PM acc	40	04-Nov-21 A	20-Dec-21		
CON10270 EL	LS to piling foundation pile cap (RWC2 type 5)	54	03-Dec-21	10-Feb-22		
CON10231C (C	CE358) JV prepare & submit; PM review, comment & acceptance watermain (30	21-Dec-21	27-Jan-22		
CON12570B (IN	VCE179) install sheet-pile works after obstruction removal ($VS27E11$) (id. CC	12	20_ lan_22	25-Jan-22		
CON12372 FL	S works (KS27 east side)	60	20-Jan-22	09-Apr-22		
CON10231D (C	CE358) Prepare & subletting for watermain diversion works; & PM acceptance	40	28-Jan-22	18-Mar-22		
CON10650B (N	NCE153) Inclement weather 21/6/2021 to 20/7/2021 RWC2 type 1a, 1 & 2	12	07-Feb-22	19-Feb-22		
CON10390 Co	Construct pile cap (RWC2 type 5 [bay 46])	90	11-Feb-22	02-Jun-22		
CON11550A Ga	Gas Main Diversion Works	29	16-Feb-22	21-Mar-22		1
CON10650C (N	NCE157) Inclement weather 21/7/2021 to 20/8/2021 RWC2 type 1a, 1 & 2	11	21-Feb-22	04-Mar-22		
CON10750B Re	Review temporary drainage system before year 2022 rain season (RIW1)	18	28-Feb-22	19-Mar-22		
CON10231E (C	CE358) Watermain diversion due to unforese en ground condition (by WSD 8	14	19-Mar-22	04-Apr-22		
CON10652 CC	Construct RW footing (RWC2 type 2)	60	21-Mar-22	06-Jun-22		
CON11552 Ins CON10240 Ey	istall sheet pile for pile cap construction (PET-PCTD, 32m, 1m/d)	14	22-Wal-22	25-Apr-22		
CON10240 EL	LS works for pile cap construction (FE1-PC1b, 32m, 1m/d)	36	08-Apr-22	25-May-22		
CON12410 Ap	pplication for power supply & energization (KS27)	156	11-Apr-22	20-Oct-22		
CON12390 EL	LS works & construct subway footing (KS27 east side)	90	11-Apr-22	01-Aug-22		
CON10654 Co	Construct RW wall (RWC2 type 2)	60	12-Apr-22	27-Jun-22		
Road Improvement Works Location	n 2 (RIW2)	313	28-Aug-21 A	05-Jul-22		
Construction Works in Slope C3 (Po	ortion B)	250	21-Oct-21 A	28-Jun-22		
CON20670C EL	LS to RW bay 9 to bay 16 formation (due to unforeseen ground condition)	34	21-Oct-21 A	03-Jan-22		
CON20910 Co	Construct RW bay 14 to bay 16 base (L=19m)	48	22-Oct-21 A	16-Dec-21		
CON20930 CC	construct RW bay 14 to bay 16 wall (L=19m) construct RW bay 9 to bay 13 base (L=30m) (due to unforeseen ground conc	48	02-Dec-21	29-Jan-22		
CON21010 Ut	Itilities & drainage works at Portion B (bay 3 to bay 8)	30	31-Jan-22	09-Mar-22		
CON20170 Fa	abrication of NB steel post - along slope side	70	09-Feb-22	19-Apr-22		
CON20152 Re	Review temporary drainage system before year 2022 rain season (RIW2)	18	28-Feb-22	19-Mar-22		
CON20810 Co	Construct RW bay 9 to bay 13 wall (L=30m) (due to unforeseen ground condi	66	08-Mar-22	30-May-22		
CON21030 Ut	Itilities & drainage works at Portion B (bay 1 to bay 2)	30	10-Mar-22	14-Apr-22		
CON20774A Sc	oil nail works at RW3b (remaining area)	30	10-Mar-22	14-Apr-22		
CON20990 Ut	Itilities & drainage works at Portion B (bay 9 to bay 13)	60	07-Apr-22	22-Jun-22		
CON21050 Ut	runnes & drainage works at Portion B (bay 14 to bay 16)	30	19-Apr-22	25-May-22	4	
CON20290	ater post doing slope sloe delivery	70	20-Apr-22	03-IVIAy-22		
Construction Noise Semi-Enclosure	SE2 (Portion C)	251	28-Aua-21 A	05-Jul-22		
CON21656 (C	CE332) Construct piling fdn of SE2 (Bay9 to Bay12, stage 1 58nos, 1 team)	72	28-Aug-21 A	31-Jan-22		
CON21962D Ut	Itilities potection works (SE2 Bay 13 to 18)	16	17-Nov-21 A	04-Dec-21		
CON21770 Re	Remove piling platform at CT4	18	04-Jan-22	24-Jan-22		
CON219661 EL	LS works to +174mPD	24	15-Jan-22	15-Feb-22		
CON21772 Ex	xcavate trial trench, SLG meeting & UU portection works	30	25-Jan-22	03-Mar-22		
CON21656A (N	NCE170) Inclement weather 21/9/2021 to 20/10/2021 at SE2 (Bay4 to Bay13	7	04-Feb-22	11-Feb-22		
CON219701 Th CON21659 (2)	MLG integring on 11/2/2022 and TIA Drawing Approval	(11-Feb-22*	18-Feb-22		
CON21056 (C	CESS2) Construct pling ion of SE2 (Bays to Bay 12, stage 2 sorios. T tearn)	20	12-Feb-22	22-Api-22		
CON219702	LS works to (Bav19 to Bav21)	51	19-Feb-22	23-Apr-22		
CON219703	xcavate trial trench, SLG meeting & UU protection works	45	26-Feb-22	23-Apr-22		
CON21774 Ins	nstall pipe pile wall at CT4 road side (46nos, 2no/d 1 team + setup)	27	04-Mar-22	04-Apr-22		
CON21968 Co	Construct piling fdn SE2 Bay13 to Bay18 (74nos, 2d/no. 2 teams + setup + uu	84	21-Mar-22	05-Jul-22		
CON21776 EL	LS works at CT4 (12nos. strut, 0.25no/d, 1 team + setup)	48	06-Apr-22	07-Jun-22		
Road Improvement Works Location	n 3 (RIW3)	738	19-Jul-21 A	07-Dec-22		
Construction Works		738	19-Jul-21 A	07-Dec-22		
Actual Work		NE	<u> /2017/03 Dev</u>	elopment of	Anderson Road Quarry Site - Investigation Design & Construction	ł
Remaining Work	Developm	ent of An	derson Road	Quarry Site	Road - Improvement Works & Pedestrian Connectivity Facilities W	/orks Phase 2A
♦ Milestone					3-Month Rolling Programme	



	Additing Healthe	Duration	Start	1 man	Jan Feb	Mar
CON31130	Cut slope works (CH115 to CH275) (L=160m, 24058m3, 65m3/d)	371	19-Jul-21 A	07-Dec-22	49 50	51
CON31150	Construct RWD3 (CH60 to CH152)	150	09-Aug-21 A	18-Mar-22		
CON32410	Construct type 2 NB footing (CH44~CH52, 130m3, team 1)	150	16-Aug-21 A	05-Jul-22		
CON30170	Slope works at slope D1 (stage 4, 55% completed)	72	19-Aug-21 A	08-Dec-21		
CON30410F	JV prepare pipe pile wall design; ICE review & approval; PM review, comment	92	24-Aug-21 A	13-Jan-22		
CON30410E	(NCE096) Awaiting an instruction for treat the unforeseen pipe	12	02-Sep-21 A	27-Nov-21		
CON30490	Drainage & utilities works (bay 8 to bay 14)	60	29-Nov-21	12-Feb-22		
CON30390	Construct RWD1 (bay 8 to bay 13) utilities works & backfill (2 teams)	60	29-Nov-21	12-Feb-22		
CON30190	Slope works at slope D1 (stage 5, 70% completed)	72	09-Dec-21	09-Mar-22		
CON30510	Road works (bay 8 to bay 14)	60	22-Dec-21	08-Mar-22		
CON30412B	Install pipe pile wall (around 32nos. 1d/no.+ setup) (Bay 14b to Bay 16)	36	14-Jan-22	28-Feb-22		
CON31710	Construct footing, pier & pier head F1-4	144	26-Jan-22	25-Jul-22		
CON30660	Construct Twin Fresh Watermain CH100 to CH190	174	18-Feb-22	19-Sep-22		
CON30666	Construct Salt Watermain A near F1-3 (TKO Rd Slip Rd)	60	18-Feb-22	04-May-22		
CON30092	Review temporary drainage system before year 2022 rain season (RIW3)	18	28-Feb-22	19-Mar-22		
CON30412C	ELS works and shotcrete (Bay 14b to Bay 16)	12	01-Mar-22	14-Mar-22		
CON30330	Construct RWD1 (bay 1 to bay 7) utilities works & backfill (2 teams)	60	09-Mar-22	24-May-22		
CON30530	Drainage & utilities works (bay 1 to bay 7)	60	09-Mar-22	24-May-22		
CON30191	Slope works at slope D1 (stage 5a, 80% completed)	72	10-Mar-22	09-Jun-22		
CON30412D	Install UU support (Bay 14b to Bay 16)	6	15-Mar-22	21-Mar-22		
CON32430	Construct type 2 NB tie beam (CH44~CH52, 130m3, team 1)	150	21-Mar-22	21-Sep-22		
CON30412E	Pre-drill & construct mini pile at RWD1 (bay 14b) (10nos, 3.0d/no, 1 team)	30	22-Mar-22	29-Apr-22		
CON30550	Road works (bay 1 to bay 7)	60	01-Apr-22	17-Jun-22		
Pedestrian Connectivity Facility	(PC-E11)	284	24-May-21 A	07-May-22		
Construction Works		284	24-May-21 A	07-May-22		
CON42690	ABWF works @E11-FB2 & E11-FB4	107	24-May-21 A	24-Nov-21		
CON42710	ABWF works @E11-FB3 & E11-FB5	107	24-May-21 A	24-Nov-21		
CON42772	ABWF works @LT2 (Other than lift shaft area)	48	04-Aug-21 A	29-Nov-21		
CON42872	E&M works to PC-E11 @LT2 (Other than lift shaft area)	36	01-Sep-21 A	24-Nov-21		
CON42470	Erect steel frame E11-FB1, construct floor slab & side planter	48	13-Oct-21 A	08-Dec-21		
CON42950	Lifts installation works in E11-LT2	60	02-Nov-21 A	17-Jan-22		
CON42630	Construct covered-walkway between PC-E11 & BBI toilet	102	04-Nov-21 A	09-Mar-22		1
CON42650	Install glass & window to lift tower no 1	21	10-Nov-21 A	03-Dec-21		
CON42570	Erect roof steel frame, gutter & corrugated metal sheet E11-FB1	42	18-Nov-21 A	08-Jan-22		
CON42790	E&M works to PC-E11 @E11-FB2 & E11-FB4	48	25-Nov-21	22-Jan-22		
CON42810	E&M works to PC-E11 @E11-FB3 & E11-FB5	48	25-Nov-21	22-Jan-22		
CON42732	ABWF works @LT1 (Other than lift shaft area)	48	18-Dec-21	18-Feb-22		
CON42930	Lifts installation works in E11-LT1	60	21-Dec-21	07-Mar-22		1
CON42750	ABWF works @E11-FB1	60	22-Dec-21	08-Mar-22		1
CON42850	E&M works to PC-E11 @E11-FB1	48	05-Jan-22	04-Mar-22		· · · · · · · · · · · · · · · · · · ·
CON42832	E&M works to PC-E11 @LT1 (Other than lift shaft area)	36	05-Jan-22	18-Feb-22		
CON42610A	Install fall arrest system on roof of footbridge	36	10-Jan-22	23-Feb-22		
CON42952	T&C to lift E11-LT2	30	18-Jan-22	24-Feb-22		
CON42774	Review temporary drainage system before year 2022 rain season (PC-E11)	18	28-Feb-22	19-Mar-22		
CON42970	T&C to lift E11-LT1	30	08-Mar-22	12-Apr-22		
CON42890	T&C and Statutory Inspection _PC-E11	24	06-Apr-22	07-May-22		
Pedestrian Connectivity Facility	(PC-E8)	527	26-Jul-21 A	29-Jan-23		
Construction Works		133	26-Jul-21 A	29-Jan-22		
CON40628A	Slope 326 drawing reviewing	36	26-Jul-21 A	06-Dec-21		
CON40650	Slope replacement works cycle 1 (slope 326)	18	13-Sep-21 A	18-Dec-21		
CON40710	Slope replacement works cycle 4 (slope 326)	15	13-Jan-22	29-Jan-22		
Works Under Section 7A		365	30-Jan-22	29-Jan-23		
CON41970	Establishment Works for Landscape Softworks in Section 7 (Portion G)	365	30-Jan-22	29-Jan-23		
Pedestrian Connectivity Facility	System A (SYA)	240	12-Nov-21 A	03-Sep-22		
Construction Works		240	12-Nov-21 A	03-Sep-22		
CON50320	ABWE works (lift tower & staircase)	120	12 Nov 21 A	08 Apr 22		
CON50332	ARWE works (III LOWEL & Stall Case)	120	12-INUV-21 A	00-Apr-22		
CON50312A	Off site fabrication for footbridge staal frame & doliver sta site	62	12-INUV-21 A	26 Jon 22		
	Install windows & low one (SVA tot & 2nd 1% sha@)	60	17 Dec 21	20-Jan-22		
CON50402	III ISLAII WIII IUUWS & IUUVEIS (STA ISL & 200 IIII SNAII)	10	17-Dec-21	03-Mar 22		
CON50200	Eavy works (STA ISLA ZHU IIT SNAT)	42	11-Jan-22	03-IVIAI-22		
	Install Willdows & Rouvers (SYA 3rd & 4th lift Shaft)	40	20-Jan-22	10 Max 22		
	Electionage steel frame for STA	42	21-Jan-22	19-1VIAF-22		
CON50494	Law works (STA Sta a 40 mil Stidil)	42	10-FED-22	10 Mor 22		
CON50272	Life installation works in SVA LT4A 9 SVA LT4D	10	20-FED-22	19-IVidi-22	-	
	Lins insidiation works in StarLIA & StarLID	70	04-IVIdI-22	19-1Viay-22	-	
	Lifts installation works in SVA LTAC & SVA LTAA	18	∠ 1-IVIAF-22	27-JUN-22	-	
	Lins installation works in Sta-L110 & Sta-L12A	100	09-Apr-22	24-JUN-22	-	
		120	09-Apr-22	03-Sep-22		
Pedestrian Connectivity Facility	System B (SYB)	372	21-Jun-21 A	20-Oct-22		
Construction Works		372	21-Jun-21 A	20-Oct-22		
Actual Work		NF		elopment of	Anderson Road Quarry Site - Investigation Design & Construction	
	Davalan	ont of A	daroon Deer		Pond Improvement Works 9 Dedectrian Compactivity Facilities 14	larka Dhasa 34
	Developm	IN OF A	INGI SUII ROAC	a Quarry Site	road - improvement works & redestrian Connectivity Facilities W	UINS FILASE ZA
Milestone					3-Month Rolling Programme	



Activity ID	Activity Name	Duration	Start	Finish			2022	
					Jan	Feb	Mar	Apr
					49	50	51	52
CON52170	Construct superstructure SYB-LT1	168	21-Jun-21 A	21-Mar-22	i		i	
CON51450A	(NCE156) Unforseen gound condition affected install sheet pile at SYB-PC1	130	28-Jul-21 A	22-Dec-21				
CON52110	Construct pier SYB-P3 (2 pour) & temporary LT1 support	42	08-Jan-22	01-Mar-22				
CON52150	Construct pier SYB-P5 (3 pour)	60	08-Jan-22	22-Mar-22				
CON51470	Excavate & install support at SYB-PC1 (108m3, 25m3/d, 1 team + 12d)	18	08-Jan-22	28-Jan-22				
CON51770	Construct pile cap SYB-PC1 (35m3)	36	29-Jan-22	15-Mar-22				
CON52230	Erect footbridge steel frame SYB-A1 to PC8 (A1 to P8)	18	29-Jan-22	22-Feb-22				
CON52250	Erect footbridge steel frame PC8 to PC7 (P8 to P7)	18	23-Feb-22	15-Mar-22				
CON52370	Construct deck slab, planter wall and roofing SYB-A1 to PC8 (A1 to P8)	30	23-Feb-22	29-Mar-22				
CON51592	Review temporary drainage system before year 2022 rain season (Sys B)	18	28-Feb-22	19-Mar-22		I		
CON51990	Construct pier SYB-P1 (2 pour)	42	16-Mar-22	10-May-22				
CON51810	Construct underground drainage pipe	177	16-Mar-22	20-Oct-22				
CON52390	Construct deck slab, planter wall and roofing PC8 to PC7 (P8 to P7)	30	16-Mar-22	23-Apr-22				
CON51170	Install glass & window @SYB-LT1	42	22-Mar-22	16-May-22				
CON52172	Construct R.C. desk P2 to LT1	48	22-Mar-22	23-May-22				
CON51930	Construct pier SYB-P4 (2 pour)	42	23-Mar-22	17-May-22				
CON51950	Construct pier SYB-P6 (3 pour)	72	23-Mar-22	22-Jun-22				
CON52650	ABWF works @ steel frame footbridge A1 to P8	72	30-Mar-22	29-Jun-22	1		1	
CON53230	Application for power supply & energization (SYB)	156	30-Mar-22	10-Oct-22	1			
CON52990	E&M works @ steel frame footbridge A1 to P8	60	30-Mar-22	15-Jun-22	1			

Actual Work

Remaining Work

♦ ♦ Milestone

NE/2017/03 Development of Anderson Road Quarry Site - Investigation Design & Construction Development of Anderson Road Quarry Site Road - Improvement Works & Pedestrian Connectivity Facilities Works Phase 2A 3-Month Rolling Programme

Page 3 of 3



Contract 4 (ED/2020/02)

2.1 2.1.02 2 2			C	_ · · ·	C1 .	Let the t	· ·					
2.1.02 2 2	Contract Period	1248d	Start 30/7/21	Finish 28/12/24	30/7/21	Finish 28/12/24	14%	e Float Od			28 5 1	<u>2 19 2</u>
22	Contract Duration	1247d	31/7/21	28/12/24	31/7/21	28/12/24	14%	0d	2FS+1d	4		
	Section of Works and Relevant Portions of Work	1248d	30/7/21	28/12/24	30/7/21	28/12/24	9%	0d				
2.2.01	Section of Works 1 - Portions 1a, 2a & 2b	836d	30/8/21	14/12/23	30/8/21	14/12/23	9%	0d				
2.2.01.005	Construction Duration for Portion 2a	836d	30/8/21	13/12/23	30/8/21	13/12/23	17%	0d	10	12		
2.2.01.007	Access date for Portion 2b	0d	14/12/21	14/12/21	14/12	14/12/21	100%	0d	2	14,367	•	14/12
2.2.01.008	Construction Duration for Portion 2b	730d	14/12/21	13/12/23	14/12	13/12/23	5%	0d	13	15		-
2.2.03	Section of Works 2 - Portion 8	730d	30/7/21	29/7/23	30/7/21	29/7/23	24%	0d				
2.2.03.002	Construction Duration for Portion 8	730d	30/7/21	29/7/23	30/7/21	29/7/23	24%	0d	21	23		
2.2.05	Section of Works 3 - Portions 1b, 3, 4, 5	731d	30/7/21	30/7/23	30/7/21	30/7/23	15%	0d				
2.2.05.013	PMI 003 & 004 issued	62d	29/9/21	29/11/21	29/9/21	29/11/21	100%	0d	32	34FS-1d,433FS-1d	♦ 29/11	
2.2.05.005	Construction Duration for Portion 3	609d	29/11/21	30/7/23	29/11	30/7/23	9%	0d	33FS-1d	35	_	
2.2.05.008	Construction Duration for Portion 4	670d	30/7/21	30/5/23	30/7/21	30/5/23	26%	0d	36	38		
2.2.05.010	Access date for Portion 5	0d	27/2/22	27/2/22	27/2/22	27/2/22	0%	0d	2	40,446		
2.2.05.011	Construction Duration for Portion 5	458d	27/2/22	30/5/23	27/2/22	30/5/23	0%	0d	39	41		
2.2.07	Section of Works 4 - Portions 6, 12	684d	30/7/21	13/6/23	30/7/21	13/6/23	15%	0d				
2.2.07.001	Access date for Portion 6	0d	29/1/22	29/1/22	29/1/22	29/1/22	0%	0d	2	48,458		
2.2.07.002	Construction Duration for Portion 6	501d	29/1/22	13/6/23	29/1/22	13/6/23	0%	0d	47	49		
2.2.07.005	Construction Duration for Portion 12	684d	30/7/21	13/6/23	30/7/21	13/6/23	26%	0d	50	52		
2.2.09	Section of Works 5A - Portions 9, 10	699d	30/7/21	28/6/23	30/7/21	28/6/23	22%	0d				
2.2.09.002	Construction Duration for Portion 9	638d	29/9/21	28/6/23	29/9/21	28/6/23	18%	0d	58	60	_	
2.2.09.005	Construction Duration for Portion 10	699d	30/7/21	28/6/23	30/7/21	28/6/23	25%	0d	61	63		
2.2.11	Section of Works 5B - Portion 11	487d	27/2/22	28/6/23	27/2/22	28/6/23	0%	0d				
2.2.11.001	Access date for Portion 11	0d	27/2/22	27/2/22	27/2/22	27/2/22	0%	0d	2	70,626		
2.2.11.002	Construction Duration for Portion 11	487d	27/2/22	28/6/23	27/2/22	28/6/23	0%	0d	69	71		
2.2.14	Section of Works 7A - Portions 13a, 14	669d	30/7/21	29/5/23	30/7/21	29/5/23	15%	0d				
2.2.14.001	Access date for Portion 13a	0d	29/1/22	29/1/22	29/1/22	29/1/22	0%	0d	2	82,646		
2.2.14.002	Construction Duration for Portion 13a	486d	29/1/22	29/5/23	29/1/22	29/5/23	0%	0d	81	83		
2.2.14.005	Construction Duration for Portion 14	669d	30/7/21	29/5/23	30/7/21	29/5/23	26%	0d	84	86		
2.2.16	Section of Works 7B - Portions 13b, 15	671d	27/2/22	29/12/23	27/2/22	29/12/23	0%	0d				
2.2.16.001	Access date for Portion 13b	0d	27/2/22	27/2/22	27/2/22	27/2/22	0%	0d	2	93,674		
2.2.16.002	Construction Duration for Portion 13b	671d	27/2/22	29/12/23	27/2/22	29/12/23	0%	0d	92	94		
2.2.16.004	Access date for Portion 15	0d	27/2/22	27/2/22	27/2/22	27/2/22	0%	0d	2	96		1
2.2.16.005	Construction Duration for Portion 15	671d	27/2/22	29/12/23	27/2/22	29/12/23	0%	0d	95	97		
2.2.20	Section of Works 9 - Portion 17	671d	27/2/22	29/12/23	27/2/22	29/12/23	0%	0d				
2.2.20.001	Access date for Portion 17	0d	27/2/22	27/2/22	27/2/22	27/2/22	0%	0d	2	112,720		1
2.2.20.002	Construction Duration for Portion 17	671d	27/2/22	29/12/23	27/2/22	29/12/23	0%	0d	111	113		
2.2.22	Section of Works 10 - All Tree Protection and Preservation Wo	orks 883d	30/7/21	29/12/23	30/7/21	29/12/23	20%	0d			H	
2.2.22.002	All Tree Protection and Preservation Work Duration for Section	10 883d	30/7/21	29/12/23	30/7/21	29/12/23	20%	0d	119	121		
2.3	Preliminaries	1248d	30/7/21	28/12/24	30/7/21	28/12/24	35%	0d				
2.2. 2.2. 2.2. 2.2. 2.2. 2.2. 2.2. 2.2	16.004 16.005 20.001 20.002 22.002 22.002 *: 30 July 20 y 2021	16.004 Access date for Portion 15 16.005 Construction Duration for Portion 15 20 Section of Works 9 - Portion 17 20.001 Access date for Portion 17 20.002 Construction Duration for Portion 17 22 Section of Works 10 - All Tree Protection and Preservation Work 22.002 All Tree Protection and Preservation Work Duration for Section Preliminaries *: 30 July 2021 Y 2021 Task	16.004 Access date for Portion 15 0d 16.005 Construction Duration for Portion 15 671d 20 Section of Works 9 - Portion 17 671d 20.001 Access date for Portion 17 0d 20.002 Construction Duration for Portion 17 0d 20.002 Section of Works 10 - All Tree Protection and Preservation Works 883d 22.002 All Tree Protection and Preservation Work Duration for Section 10 883d 22.002 All Tree Protection and Preservation Work Duration for Section 10 883d 22.002 Task Milestone Summ.	16.004Access date for Portion 150d27/2/2216.005Construction Duration for Portion 15671d27/2/2220Section of Works 9 - Portion 17671d27/2/2220.001Access date for Portion 170d27/2/2220.002Construction Duration for Portion 17671d27/2/2222Section of Works 10 - All Tree Protection and Preservation Works883d30/7/2122.002All Tree Protection and Preservation for Section 10883d30/7/2122.002All Tree Protection and Preservation for Section 10883d30/7/2122.002TaskMilestoneSummary	16.004 Access date for Portion 15 0d 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 29/12/23 16.005 Construction Duration for Portion 15 671d 27/2/22 29/12/23 29/12/23 20 Section of Works 9 - Portion 17 671d 27/2/22 29/12/23 20.001 Access date for Portion 17 0d 27/2/22 29/12/23 20.002 Construction Duration for Portion 17 671d 27/2/22 29/12/23 22 Section of Works 10 - All Tree Protection and Preservation Works 883d 30/7/21 29/12/23 22.002 All Tree Protection and Preservation Work Duration for Section 10 883d 30/7/21 29/12/23 22.002 All Tree Protection and Preservation Work Duration for Section 10 883d 30/7/21 29/12/23 22.002 All Tree Protection and Preservation Work Duration for Section 10 883d 30/7/21 29/12/23 248d 30/7/21 28/12/24 28/12/24 28/12/24 23.002 Task Milestone Summary	16.004 Access date for Portion 15 0d 21/2/22 21/2/23 21/2/22 21/2/23 21/2/23 21/2/23 21/2/23 30/7/21 29/12/23 30/7/21 29/12/23 30/7/21 29/12/23 30/7/21 29/12/23 30/7/21 29/12/23 30/7/21 29/12/23 30/7/21 22.002 All Tree Protection and Preservation Work Duration for Section 10 883d 30/7/21 28/12/24 30/7/21 29/12/23 <td>16.004 Access date for Portion 15 0d 2//2/22 2//2/23 2//2/23 2//2/23 2//2/23 3//2/1 2//2/23 3//2/1 2//2/2/2 2//2/23 3</td> <td>16.004 Access date for Portion 15 0d 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 29/12/23 0% 20 Section of Works 9 - Portion 17 671d 27/2/22 21/2/23 0% 20.002 Construction Duration for Portion 17 671d 27/2/22 29/12/23 30/7/21 29/12/23 30/7/21 29/12/23 0% 22.002 All Tree Protection and Preservation Work Duration for Section 10 883d 30/7/21 29/12/23 30/7/21 29/12/23 20% 22.002</td> <td>16.004 Access date for Portion 15 0d 2/1/2/22 2/1/2/23 0% 0d 20.001 Access date for Portion 17 0d 2/1/2/22 2/1/2/23 2/1/2/23 0% 0d 0d 2/1/2/23 2/1/2/23 0% 0d 22 Section of Works 10 - All Tree Protection and Preservation Work Duration for Section 10 883d 30/7/21 2/1/2/23 30/7/21 2/1/2/23 2/0/6</td> <td>16.004 Access date for Portion 15 0d 2/1/2/2 2/1/2/2 2/1/2/2 2/1/2/2 2/1/2/2 2/1/2/2 0% 0d 2 16.005 Construction Duration for Portion 15 671d 27/2/22 29/12/23 27/2/22 29/12/23 0% 0d 95 20 Section of Works 9 - Portion 17 0d 27/2/22 29/12/23 27/2/22 29/12/23 0% 0d 2 20.001 Access date for Portion 17 0d 27/2/22 29/12/23 27/2/22 29/12/23 0% 0d 2 20.002 Construction Duration for Portion 17 671d 27/2/22 29/12/23 27/2/22 29/12/23 0% 0d 111 22 Section of Works 10 - All Tree Protection and Preservation Works 883d 30/7/21 29/12/23 30/7/21 29/12/23 20% 0d 119 22.002 All Tree Protection and Preservation Work Duration for Section 10 883d 30/7/21 29/12/23 30/7/21 29/12/23 20% 0d 119 22.002 All Tree Protection and Preservation Work Duration for Section 10 883d</td> <td>16.004 Access date for Portion 15 0d 2/1/2/2 2/1/2/2 2/1/2/2 2/1/2/2 2/1/2/2 0% 0d 2 96 16.005 Construction Duration for Portion 15 671d 2/1/2/2 0/% 0d 112,720 20.002 Construction Duration for Portion 17 671d 2/1/2/2 2/1/2/2 2/1/2/2 0/% 0d 111 113 22.002 All Tree Protection and Preservation Work Duration for Section 10 883d 30/7/21 2/1/2/2 3/1/21 2/</td> <td>16.004 Access date for Portion 15 0d 2/12/22 2/12/22 2/12/22 2/12/22 2/12/22 0% 0d 2 96 16.005 Construction Duration for Portion 15 671d 2/12/22 29/12/23 0% 0d 95 97 20 Section of Works 9 - Portion 17 671d 2/12/22 29/12/23 27/2/22 29/12/23 0% 0d 2 112,720 20.001 Access date for Portion 17 0d 27/2/22 29/12/23 27/2/22 29/12/23 0% 0d 111 113 20.002 Construction Duration for Portion 17 671d 27/2/22 29/12/23 30/7/21 29/12/23 0% 0d 111 113 22 Section of Works 10 - All Tree Protection and Preservation Works 883d 30/7/21 29/12/23 30/7/21 29/12/23 20% 0d 119 121 22.002 All Tree Protection and Preservation Work Duration for Section 10 883d 30/7/21 29/12/23 30/7/21 29/12/24 35% 0d 119 121 22.002 All Tree Protection and Preserva</td>	16.004 Access date for Portion 15 0d 2//2/22 2//2/23 2//2/23 2//2/23 2//2/23 3//2/1 2//2/23 3//2/1 2//2/2/2 2//2/23 3	16.004 Access date for Portion 15 0d 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 21/2/22 29/12/23 0% 20 Section of Works 9 - Portion 17 671d 27/2/22 21/2/23 0% 20.002 Construction Duration for Portion 17 671d 27/2/22 29/12/23 30/7/21 29/12/23 30/7/21 29/12/23 0% 22.002 All Tree Protection and Preservation Work Duration for Section 10 883d 30/7/21 29/12/23 30/7/21 29/12/23 20% 22.002	16.004 Access date for Portion 15 0d 2/1/2/22 2/1/2/23 0% 0d 20.001 Access date for Portion 17 0d 2/1/2/22 2/1/2/23 2/1/2/23 0% 0d 0d 2/1/2/23 2/1/2/23 0% 0d 22 Section of Works 10 - All Tree Protection and Preservation Work Duration for Section 10 883d 30/7/21 2/1/2/23 30/7/21 2/1/2/23 2/0/6	16.004 Access date for Portion 15 0d 2/1/2/2 2/1/2/2 2/1/2/2 2/1/2/2 2/1/2/2 2/1/2/2 0% 0d 2 16.005 Construction Duration for Portion 15 671d 27/2/22 29/12/23 27/2/22 29/12/23 0% 0d 95 20 Section of Works 9 - Portion 17 0d 27/2/22 29/12/23 27/2/22 29/12/23 0% 0d 2 20.001 Access date for Portion 17 0d 27/2/22 29/12/23 27/2/22 29/12/23 0% 0d 2 20.002 Construction Duration for Portion 17 671d 27/2/22 29/12/23 27/2/22 29/12/23 0% 0d 111 22 Section of Works 10 - All Tree Protection and Preservation Works 883d 30/7/21 29/12/23 30/7/21 29/12/23 20% 0d 119 22.002 All Tree Protection and Preservation Work Duration for Section 10 883d 30/7/21 29/12/23 30/7/21 29/12/23 20% 0d 119 22.002 All Tree Protection and Preservation Work Duration for Section 10 883d	16.004 Access date for Portion 15 0d 2/1/2/2 2/1/2/2 2/1/2/2 2/1/2/2 2/1/2/2 0% 0d 2 96 16.005 Construction Duration for Portion 15 671d 2/1/2/2 0/% 0d 112,720 20.002 Construction Duration for Portion 17 671d 2/1/2/2 2/1/2/2 2/1/2/2 0/% 0d 111 113 22.002 All Tree Protection and Preservation Work Duration for Section 10 883d 30/7/21 2/1/2/2 3/1/21 2/	16.004 Access date for Portion 15 0d 2/12/22 2/12/22 2/12/22 2/12/22 2/12/22 0% 0d 2 96 16.005 Construction Duration for Portion 15 671d 2/12/22 29/12/23 0% 0d 95 97 20 Section of Works 9 - Portion 17 671d 2/12/22 29/12/23 27/2/22 29/12/23 0% 0d 2 112,720 20.001 Access date for Portion 17 0d 27/2/22 29/12/23 27/2/22 29/12/23 0% 0d 111 113 20.002 Construction Duration for Portion 17 671d 27/2/22 29/12/23 30/7/21 29/12/23 0% 0d 111 113 22 Section of Works 10 - All Tree Protection and Preservation Works 883d 30/7/21 29/12/23 30/7/21 29/12/23 20% 0d 119 121 22.002 All Tree Protection and Preservation Work Duration for Section 10 883d 30/7/21 29/12/23 30/7/21 29/12/24 35% 0d 119 121 22.002 All Tree Protection and Preserva



他国水利电力对外有限公司 China International Water & Electric Corp.

CEDD Contract No. ED/2020/02 Development of Anderson Road Quarry Site – Infrastructure, Greening and Landscape Works Revised Works Programme : January 2022

		A stirit News	D	Faul	Faul	1	1.444	0/	Tatel	Duesland	C		
טון	Activity Code	ACTIVITY NAME	Dur	Early Start	Early Finish	Late Start	Late Finish	% Comple	e Float	Predecesso	Successors	Dec '21 28 5 1	2 19 2
123	ED202.3.01	Establishment of Commercial/Organization	226d	30/7/21	12/3/22	30/7/21	4/6/22	81%	84d				
156	ED202.3.01.033	Video script for Project Video Film	180d	30/7/21	25/1/22	30/7/21	25/1/22	64%	0d	2			
157	ED202.3.01.034	Employment of Construction Industry Council's Graduates (min. 4 graduates)	180d	30/7/21	25/1/22	30/7/21	25/1/22	64%	0d	2			
158	ED202.3.01.035	Nomination of Treatment process specialist, Design Engineer, and Independent Checking Engineer (ICE)	30d	7/2/22	12/3/22	29/4/22	4/6/22	0%	69d	237SS	238	-	
180	ED202.3.03	Procurements of Major Materials	430d	15/2/22	20/4/23	20/3/22	7/11/23	0%	33d				
187	ED202.3.03.007	Procurement of Raise Planter Type A&B	90d	15/2/22	15/5/22	20/3/22	17/6/22	0%	33d	2SS+200d	188		
197	ED202.3.04	Programme	1239d	30/7/21	19/12/24	30/7/21	28/12/24	15%	9d				
203	ED202.3.04.006	Implementation of Programme Management and Monthly Reporting	1145d	1/11/21	19/12/24	1/11/21	28/12/24	7%	9d	202	4		
224	ED202.3.06	Contractor's Design	659d	30/7/21	19/5/23	30/7/21	4/10/23	13%	138d				
226	ED202.3.06.002	Internal Review & Submission Contractor's Design - Architectural & Structural	30d	28/10/21	26/11/21	28/10	26/11/21	100%	0d	225	227		
227	ED202.3.06.003	PM Review & AIP Contractor's Design - Architectural	30d	27/11/21	26/12/21	27/11	26/12/21	100%	0d	225,226	228		
228	ED202.3.06.004	Re-submission Contractor's Design - Architectural & Structural	90d	27/12/21	26/3/22	27/12	26/3/22	0%	0d	227	229		│
237	ED202.3.06.013	Prepare Contractor's Design - Underground Water Treatment Plant	90d	7/2/22	7/5/22	7/3/22	4/6/22	0%	28d	2SS+192d	239,238,158SS		
246	ED202.3.07	Contractor's Design [Enhancement on Architectural Design & Associated Works]	450d	30/7/21	22/10/22	30/7/21	27/10/22	27%	5d				
248	ED202.3.07.002	Prepare & Submission Preliminary Arch., Design	90d	28/9/21	26/12/21	28/9/21	31/12/21	70%	5d	247	249		
249	ED202.3.07.003	PM Review & AIP Preliminary Architectural Design	30d	27/12/21	25/1/22	1/1/22	30/1/22	0%	5d	248	250		±
250	ED202.3.07.004	Vetting of design through public engagement activities	60d	26/1/22	26/3/22	31/1/22	31/3/22	0%	5d	249	251		
255	ED202.3.08	Method Statements & Temporary Works	120d	30/7/21	26/11/21	30/7/21	1/9/22	58%	279d				
262	ED202.3.08.007	Preparation & submission of generic method statement of elevated walkway construciton	120d	30/7/21	26/11/21	5/5/22	1/9/22	0%	279d	2	679		
267	ED202.3.09	BIM Deliverable	1248d	30/7/21	28/12/24	30/7/21	28/12/24	17%	0d				
272	ED202.3.09.005	Nomination of staff or subcontractor to attend BIM skill training courses under the pre approved list of the CITF managed by the CIC	120d	30/7/21	26/11/21	31/8/24	28/12/24	0%	1128d	2			
273	ED202.3.09.006	Collaboration and Model Sharing	60d	28/10/21	26/12/21	28/10	22/1/22	50%	27d	269FS+30d	274		
274	ED202.3.09.007	Monthly Coordination meeting & Submission of monthly BIM progress reports & Submission of 4D Simulation	1098d	27/12/21	28/12/24	27/12	28/12/24	2%	0d	273	275FS-60d,4,276FS-4	۷	
280	ED202.4	Work Area	1248d	30/7/21	28/12/24	30/7/21	28/12/24	11%	0d				
283	ED202.4.03	CRE Site office Construction Works	90d	28/9/21	26/12/21	28/9/21	23/1/22	90%	28d	282	285,284		
284	ED202.4.04	Completion of CRE Site office Construction Works	0d	24/1/22	24/1/22	24/1/22	24/1/22	0%	0d	283	285		
285	ED202.4.05	CRE Site office Mobilization & Maintenance	1050d	24/1/22	8/12/24	13/2/22	28/12/24	0%	20d	283,284	4,288		
287	ED202.4.07	Maintenance Duration for Works Area	1247d	31/7/21	28/12/24	31/7/21	28/12/24	14%	0d	286FS+1d	288		
289	ED202.4.09	Setting up Contractor's Project office	90d	28/9/21	26/12/21	28/9/21	26/12/21	100%	0d	2	290	_	
290	ED202.4.10	Contractor Site office Maintenance	1050d	24/1/22	8/12/24	24/1/22	8/12/24	0%	0d	289	4,288		
291	ED202.5	Construction Works	1039d	30/7/21	28/12/24	30/7/21	28/12/24	6%	0d				
292	ED202.5.01	Section of Works 1 - Portions 1a, 1b, 2b	697d	30/8/21	13/12/23	30/8/21	13/12/23	3%	0d				
293	ED202.5.01.001	Portion 1a	556d	17/2/22	13/12/23	17/2/22	13/12/23	0%	0d	-			
294	ED202.5.01.001.001	Preparation & submission of MS, Temp., works, associated plans & docs	42d	30/7/21	17/9/21	17/2/22	7/4/22	0%	0d	2	295		
316	ED202.5.01.002	Portion 2a	697d	30/8/21	13/12/23	30/8/21	13/12/23	3%	0d				
320	ED202.5.01.002.004	Engineer's AIP of MS, Temp., works, plans & associated docs	18d	11/11/21	1/12/21	11/11	1/12/21	100%	0d	319	321,324,322		
Project Data D	t Start Date: 30 July 2021 ate: 30 July 2021	Task Milestone ♦	Summ	ary 🛡		-	Critical Ta	sk 🗾					
	0.00						D						



中国水利电力对外有限公司 CTG China International Water & Electric Corp.

CEDD Contract No. ED/2020/02 Development of Anderson Road Quarry Site – Infrastructure, Greening and Landscape Works Revised Works Programme : January 2022

ID	Activity Code	Activity Name	Dur	Early	Early	Late	Late	% Compl	Total	Predecesso	Successors	Dec '21
321	ED202.5.01.002.005	Excavation and Construction Drainage System	90d	2/12/21	19/3/22	15/12	1/4/22	0%	11d	318,320,260	323FS-30d,322FS-60	
322	ED202.5.01.002.006	Excavation and Construction of Catchpits + U channel	90d	8/1/22	25/4/22	21/1/22	9/5/22	0%	11d	318,320,260	0323FS-30d,324	
323	ED202.5.01.002.007	CCTV inspection, testing and commissioning of Drainage Lines	42d	21/3/22	10/5/22	2/4/22	23/5/22	0%	11d	321FS-30d,	327	
364	ED202.5.01.003	Portion 2b	666d	2/10/21	8/12/23	2/10/21	13/12/23	7%	4d			
366	ED202.5.01.003.002	Engineer's AIP of MS, Temp., works, plans & associated docs	18d	22/11/21	11/12/21	22/11	11/12/21	100%	0d	365	367	
367	ED202.5.01.003.003	Provision of site access [137 days after starting date as per Contract]	j 6d	14/12/21	20/12/21	14/12	20/12/21	100%	0d	13,366	368	
368	ED202.5.01.003.004	Mobilization & Site Clearance	12d	21/12/21	5/1/22	21/12	5/1/22	100%	0d	367	369,372,371FS+26d	
369	ED202.5.01.003.005	Hard landscaping work for Island - placement of boulders, soil placement and planters construction	90d	6/1/22	22/4/22	6/1/22	27/4/22	5%	4d	368	370	
371	ED202.5.01.003.007	Construction of artificial lake	82d	7/2/22	14/5/22	1/4/22	9/7/22	0%	46d	368FS+26d	373,378	
389	ED202.5.03	Section of Works 2 - Portion 8	596d	30/7/21	17/7/23	30/7/21	29/7/23	10%	11d			
390	ED202.5.03.001	Portion 8	596d	30/7/21	17/7/23	30/7/21	29/7/23	10%	11d			
395	ED202.5.03.001.005	Excavation for Drainage Works	90d	2/11/21	17/2/22	2/11/21	21/3/22	40%	27d	392,394	397FS-30d,396FS-60	
396	ED202.5.03.001.006	Construction of Drainage Works	90d	7/12/21	24/3/22	7/12/21	7/4/22	30%	11d	392,394,39	5397FS-30d	
397	ED202.5.03.001.007	CCTV inspection, testing and commissioning of Drainage Works	60d	18/2/22	29/4/22	3/3/22	13/5/22	0%	11d	395FS-30d,	399,398	
418	ED202.5.05	Section of Works 3 - Portions 1b, 3, 4, 5	607d	30/7/21	29/7/23	29/11	29/7/23	3%	0d			
432	ED202.5.05.002	Portion 3	506d	29/11/21	29/7/23	29/11	29/7/23	7%	0d			
433	ED202.5.05.002.001	Provision of site access	6d	29/11/21	4/12/21	29/11	4/12/21	100%	0d	33FS-1d	434	
434	ED202.5.05.002.002	Mobilization & Site Clearance	12d	6/12/21	18/12/21	6/12/21	18/12/21	100%	0d	433	435	
435	ED202.5.05.002.003	Preparation & submission of MS, Temp., works, associated plans & docs	42d	20/12/21	9/2/22	20/12	9/2/22	67%	0d	434	436	· · · ·
436	ED202.5.05.002.004	Engineer AIP of MS, Temp., works, plans & associated docs	18d	10/2/22	2/3/22	10/2/22	2/3/22	0%	0d	435	437	
437	ED202.5.05.002.005	Installation of chain-link fencing + Provision of temporary drainage system	158d	3/3/22	7/9/22	3/3/22	7/9/22	0%	0d	436	438,443FS+2d	
441	ED202.5.05.003	Portion 4	529d	30/7/21	26/4/23	10/10	30/5/23	0%	28d			
445	ED202.5.05.004	Portion 5	381d	28/2/22	30/5/23	28/2/22	30/5/23	0%	0d			
446	ED202.5.05.004.001	Provision of site access [212 days after starting date as per Contract]	6d	28/2/22	5/3/22	28/2/22	5/3/22	0%	0d	39	447,448	
447	ED202.5.05.004.002	Installation of chain-link fencing + + Provision of temporary drainage system	135d	7/3/22	15/8/22	7/3/22	15/8/22	0%	0d	446	449,448FS-30d	
454	ED202.5.07	Section of Works 4 - Portions 6, 12	568d	30/7/21	13/6/23	30/7/21	13/6/23	8%	0d			
455	ED202.5.07.001	Portion 6	491d	1/11/21	13/6/23	1/11/21	13/6/23	7%	0d			
456	ED202.5.07.001.001	Preparation & submission of MS, Temp., works, associated plans & docs	42d	1/11/21	18/12/21	1/11/21	18/12/21	100%	0d	2	457	
457	ED202.5.07.001.002	Engineer's AIP of MS, Temp., works, plans & associated docs	18d	20/12/21	11/1/22	20/12	11/1/22	100%	0d	456	458	· · · · · · · · · · · · · · · · · · ·
458	ED202.5.07.001.003	Provision of site access [183 days after starting date as per Contract]	6d	29/1/22	5/2/22	29/1/22	5/2/22	0%	0d	47,457	459	
459	ED202.5.07.001.004	Mobilization & Site Clearance	12d	7/2/22	19/2/22	7/2/22	19/2/22	0%	0d	458	460	
460	ED202.5.07.001.005	Excavation and Construction of Drainage Works	90d	21/2/22	8/6/22	21/2/22	8/6/22	0%	0d	459	461FS-30d	
474	ED202.5.07.002	Portion 12	568d	30/7/21	13/6/23	30/7/21	13/6/23	8%	0d			
479	ED202.5.07.002.005	Excavation for Drainage Works	90d	2/11/21	17/2/22	2/11/21	17/2/22	5%	0d	476,478	481FS-24d,480FS-56	
480	ED202.5.07.002.006	Construction of Drainage Works	90d	11/12/21	29/3/22	11/12	29/3/22	0%	0d	476,478,479	3481FS-24d	
481	ED202.5.07.002.007	CCTV inspection, testing and commissioning of Drainage Works	60d	2/3/22	12/5/22	2/3/22	12/5/22	0%	0d	479FS-24d,	488,487	
482	ED202.5.07.002.008	Excavation and Construction of Waterlines for fresh water & flushing water and connection to existing tee-off	60d	2/11/21	12/1/22	16/2/22	27/4/22	0%	88d	476,478	483	
Projec Data D	t Start Date: 30 July 2021 Date: 30 July 2021	Task Milestone ♦	Summ	nary 🛡		-	Critical Ta	sk 🚃		_		
Update	ed on : 23 January 2022						Page 3/5					

Revision:0



Open Lina International Water & Electric Corp.

CEDD Contract No. ED/2020/02 Development of Anderson Road Quarry Site – Infrastructure, Greening and Landscape Works Revised Works Programme : January 2022

ID	Activity Code	Activity Name	Dur	Early	Early	Late	Late Einish	% Comple	Total	Predecesso	Successors	Dec '21
483	ED202.5.07.002.009	Testing and Commissioning of Waterlines for fresh water and flushing water	24d	13/1/22	10/2/22	28/4/22	26/5/22	0%	88d	482	485	20 3 12 19
484	ED202.5.07.002.020	Application for Irrigation system (WW0046 Part I & II)	30d	1/3/22	31/3/22	27/4/22	26/5/22	0%	57d		485	_
494	ED202.5.07.002.019	PMI 005 : Additional GI at Portion 12	12d	1/3/22	15/3/22	1/3/22	15/3/22	0%	0d			_
499	ED202.5.09	Section of Works 5A - Portions 9, 10	581d	30/7/21	28/6/23	30/7/21	28/12/24	16%	458d			
500	ED202.5.09.001	Portion 9 [Sitting Out Area C & R2-1 Footpath]	530d	29/9/21	28/6/23	29/9/21	28/6/23	10%	0d			
503	ED202.5.09.001.003	Preparation & submission of MS, Temp., works, associated plans & docs	42d	22/10/21	9/12/21	22/10	9/12/21	100%	0d	502	504	
504	ED202.5.09.001.004	Engineer AIP of MS, Temp., works, plans & associated docs	18d	10/12/21	31/12/21	10/12	31/12/21	100%	0d	503	505,508	
505	ED202.5.09.001.005	Excavation and construction of drainage line and catchpits	60d	3/1/22	14/3/22	10/1/22	21/3/22	0%	6d	502,504	506	
506	ED202.5.09.001.006	CCTV inspection, testing and commissioning of Drainage Lines	30d	15/3/22	19/4/22	22/3/22	26/4/22	0%	6d	505	510,509	
507	ED202.5.09.001.017	Application for Irrigation system (WW0046: Part I & II)	30d	11/12/21	10/1/22	11/12	10/1/22	0%	0d		508	
508	ED202.5.09.001.007	Excavation and construction of draw pits and ducting & Irrigation system	90d	10/1/22	26/4/22	10/1/22	26/4/22	0%	0d	502,504,507	7510,509,517	
518	ED202.5.09.002	Portion 10	581d	30/7/21	28/6/23	30/7/21	28/12/24	21%	458d			
522	ED202.5.09.002.004	Preparation & submission of MS, Temp., works, associated plans & docs	32d	16/11/21	22/12/21	16/11	22/1/22	50%	25d	521	524,523	
523	ED202.5.09.002.005	Time Risk Allowance	12d	23/12/21	7/1/22	23/12	7/1/22	100%	0d	522	524	
524	ED202.5.09.002.006	Engineer's AIP of MS, Temp., works, plans & associated docs	18d	8/1/22	28/1/22	8/1/22	31/1/22	72%	2d	522,523	571,570,526,527	
525	ED202.5.09.002.009	Slope Works at Feature No. 11NE-D/C998 (409m)	38d	29/1/22	15/3/22	29/1/22	28/12/24	<mark>42%</mark>	849d			
526	ED202.5.09.002.009.01	Construction of concrete maintenance staircase with hand railings	32d	29/1/22	8/3/22	29/1/22	20/12/24	50%	849d	521,524	527	
527	ED202.5.09.002.009.02	Installation of display sign for slope registration no. x2	6d	9/3/22	15/3/22	21/12	28/12/24	0%	849d	526,524,520	529	
528	ED202.5.09.002.012	Slope Works at Feature No. 11NE-D/FR657 (63m)	50d	16/3/22	14/5/22	16/3/22	28/12/24	<mark>24%</mark>	799d			
529	ED202.5.09.002.012.01	Demolition and removal of disused water pipe and sprinkler system	12d	16/3/22	29/3/22	16/3/22	29/3/22	100%	0d	527	530	
569	ED202.5.09.002.017	Slope Works at Feature No. 11NE-D/C979 (45m)	32d	29/1/22	8/3/22	2/2/22	10/3/22	0%	2d			
570	ED202.5.09.002.017.01	Time Risk Allowance	6d	29/1/22	5/2/22	2/2/22	8/2/22	0%	2d	521,524	571	
571	ED202.5.09.002.017.02	Demolition and removal of disused water pipe and sprinkler system	6d	7/2/22	12/2/22	9/2/22	15/2/22	0%	2d	521,524,570	572	
572	ED202.5.09.002.017.03	Construction of concrete berm	12d	14/2/22	26/2/22	16/2/22	1/3/22	0%	2d	571	573	
573	ED202.5.09.002.017.04	Installation of hand railings	6d	28/2/22	5/3/22	2/3/22	8/3/22	0%	2d	572	574	
574	ED202.5.09.002.017.05	Installation of display sign for slope registration no. x1	2d	7/3/22	8/3/22	9/3/22	10/3/22	0%	2d	573	576	
575	ED202.5.09.002.018	Slope Works at Feature No. 11NE-D/C947 (420m)	68d	9/3/22	28/5/22	11/3/22	31/5/22	0%	2d			
576	ED202.5.09.002.018.01	Demolition and removal of disused water pipe and sprinkler system	24d	9/3/22	6/4/22	11/3/22	8/4/22	0%	2d	574	577	
624	ED202.5.11	Section of Works 5B - Portion 11	391d	28/2/22	12/6/23	11/4/23	28/6/23	0%	14d			
625	ED202.5.11.001	Portion 11	391d	28/2/22	12/6/23	11/4/23	28/6/23	0%	14d			
626	ED202.5.11.001.001	Provision of site access [212 days after starting date as per Contract]	6d	28/2/22	5/3/22	11/4/23	17/4/23	0%	339d	69	627	
644	ED202.5.14	Section of Works 7A - Portions 13a, 14	556d	30/7/21	29/5/23	30/7/21	29/5/23	21%	0d			
645	ED202.5.14.001	Portion 13a	404d	29/1/22	29/5/23	29/1/22	29/5/23	0%	0d			
646	ED202.5.14.001.001	Provision of site access [183 days after starting date as per Contract]	6d	29/1/22	5/2/22	29/1/22	5/2/22	0%	0d	81,259	647	
647	ED202.5.14.001.002	Mobilization & Site Clearance	12d	7/2/22	19/2/22	7/2/22	19/2/22	0%	0d	646	648	
Project Data D	: Start Date: 30 July 2021 ate: 30 July 2021	Task Milestone ♦	Summ	ary 🛡			Critical Ta	sk 💼				
Update	ed on : 23 January 2022						Page 4/5					



	CEDD Contract No. ED/2020/02 Development of Anderson Road Quarry Site – Infrastructure, Greening and Landscape Works Revised Works Programme : January 2022												
ID	Activity Code	Activity Name	Dur	Early	Early	Late	Late	%	Total	Predecesso	Successors	Dec '21	
			00.1	Start	Finish	Start	Finish	Compl	Float	057.047.05		28 5 12 19 26	
648	ED202.5.14.001.003	(G.I Works) Geotechnical Instrumentation Installation	600	21/2/22	3/5/22	21/2/22	3/5/22	0%	Ua	057,047,05	651,649,650		
655	ED202.5.14.002	Portion 14	423d	30/7/21	20/12/22	30/7/21	29/5/23	36%	133d				
660	ED202.5.14.002.006	Time Risk Allowance	30d	2/11/21	6/12/21	2/11/21	6/12/21	100%	0d	659	661		
661	ED202.5.14.002.007	Cutting & filling of slopes to formation level {Site G-2}	90d	7/12/21	24/3/22	17/5/22	31/8/22	0%	133d	256,257,660	662	•	
667	ED202.5.14.002.013	PMI 001 : Additional GI at Portion 14	90d	15/10/21	31/1/22	15/10	31/1/22	93%	0d				
672	ED202.5.16	Section of Works 7B - Portions 13b, 15	560d	28/2/22	29/12/23	7/3/22	29/12/23	4%	0d				
673	ED202.5.16.001	Portion 13b & 15	560d	28/2/22	29/12/23	7/3/22	29/12/23	4%	0d				
674	ED202.5.16.001.001	Provision of site access [212 days after starting date as per Contract]	6d	28/2/22	5/3/22	7/3/22	12/3/22	0%	6d	92	675		
675	ED202.5.16.001.002	Mobilization & Site Clearance	18d	7/3/22	26/3/22	14/3/22	2/4/22	0%	6d	674	677,689,685,697,690		
716	ED202.5.20	Section of Works 9 - Portion 17	629d	1/12/21	23/12/23	1/12/21	29/12/23	4%	4d			•	
717	ED202.5.20.001	Portion 17	629d	1/12/21	23/12/23	1/12/21	29/12/23	4%	4d			•	
718	ED202.5.20.001.001	Preparation & submission of MS, Temp., works, associated plans & docs	42d	1/12/21	20/1/22	1/12/21	20/1/22	100%	0d	2	719		
719	ED202.5.20.001.002	Engineer's AIP of MS, Temp., works, plans & associated docs	18d	21/1/22	11/2/22	21/1/22	3/3/22	11%	17d	718	720		
720	ED202.5.20.001.003	Provision of site access [212 days after starting date as per Contract]	6d	28/2/22	5/3/22	4/3/22	10/3/22	0%	4d	111,719	721		
721	ED202.5.20.001.004	Slope inspection & assessment work & Tree Survey	20d	7/3/22	29/3/22	11/3/22	2/4/22	0%	4d	720	723,722		
812	ED202.5.22	Section of Works 10 - All Tree Protection and Preservation Works	736d	30/7/21	29/12/23	30/7/21	29/12/23	20%	0d				
814	ED202.5.22.002	All Tree Protection and Preservation Work Duration for Section 8	880d	30/7/21	26/12/23	30/7/21	29/12/23	20%	3d	813	815		

Project Start Date: 30 July 2021 Data Date: 30 July 2021	Task	Milestone 🔶	Summary	Critical Task
Updated on : 23 January 2022 Revision:0				Page 5/5





Contract 5 (NE/2019/02)

\\192.168.1.230\z\Jobs\2016\TCS00864 (CEDD)\600\EM&A Report Submission\Monthly EM&A Report\2022\February\R0535v2.docx

Contract No. ED/2019/02
Development of Anderson Road Quarry Site -
Remaining Pedestrian Connectivity Facilities Works

ID	Moc	Task Name	Duration	Start	Finish	Predecessors	Successors	1, 2021 Feb Mar	Qtr 2, 2021 Qtr 3, 202 Anr May Jun Jul Aug	1 Qtr 4, 2021 Qtr 1, 2022 Qtr 2, 2022 Qtr 3, Sep Oct Nov Dec Jan Feb Mar Apr May Jun Jul A	2022 Qtr 4, 2022 Qtr 1, 2023 Qtr 2, 20 ug Sep Oct Nov Dec Jan Feb Mar Apr May
1	- Micc	Development of Anderson Road Quarry Site - Remaining	1461 days	Tue 30/3/21	Sat 29/3/25			1 00 11141	Aprillay Juli Jul Aug I	sep oer nov bee san reolinar Aprimay san sar A	is sep oer nov bee san reo mar Aprimay
		Pedestrian Connectivity Facilities Works		T 00/0/01	m 000001						
2	*	Contract Starting Date	I day	Tue 30/3/21	Tue 30/3/21			6	•		
3	E .,	Possession of Site (Portion 1a, 2, 3a & 4b)	1 day	Tue 30/3/21	Tue 30/3/21	2	16,35,18,20,22,43,4,36,37,38,39,40,41,5,6,7,8,9,10	6			
4		Possession of Site (Portion 1b)	I day	Fri 30/7/21	Fii 30///21	3	10,272		e		
5	2	Possession of Site (Portion 3b)	I day	Fri 30///21	Fri 30/7/21	3	222				
6	E	Possession of Site (Portion 4a)	I day	Fri 30///21	Fri 30///21	3	244	1	•		
1		Construction Period of Section 1	1009 days	Wed 31/3/21	Wed 3/1/24	3	11	1			
8	-	Construction Period of Section 2	1009 days	Wed 31/3/21	Wed 3/1/24	3	12	1			
9		Construction Period of Section 3	1095 days	Wed 31/3/21	Fri 29/3/24	3	13	1			
10	-	Construction Period of Section 4	1095 days	Wed 31/3/21	Fri 29/3/24	3	14	1			Constant sector and the sector sector and the sector secto
11	->	Construction Period of Section 1A	365 days	Thu 4/1/24	Thu 2/1/25	7					
12		Construction Period of Section 2A	365 days	Thu 4/1/24	Thu 2/1/25	8					
13	-	Construction Pperiod of Section 3A	365 days	Sat 30/3/24	Sat 29/3/25	9					
14	-	Construction Period of Section 4A	365 days	Sat 30/3/24	Sat 29/3/25	10					
15	-	Preliminary Work	310 days	Wed 31/3/21	Thu 3/2/22					1	
16	-	Mobilization of Site Accommodation	12 days	Wed 31/3/21	Sun 11/4/21	3	62,119,174,209,240,243,24,64		I		
17	-	Major Sub-contractor Submission	250 days	Wed 31/3/21	Sun 5/12/21			1	e		
18		Submit Proposed Landscaping Sub-contractor	7 days	Wed 31/3/21	Tue 6/4/21	3	19	1	€		
19		Accept Proposed Landscaping Sub-contractor	7 days	Wed 7/4/21	Tue 13/4/21	18	46,49		<u>\$</u>		
20	1	Submit Proposed Traffic Consultant	7 days	Wed 31/3/21	Tue 6/4/21	3	21	1	€ <u>`</u>		
21	1	Accept Proposed Traffic Consultant	7 days	Wed 7/4/21	Tue 13/4/21	20	178		<u></u>		
22		Submit Proposed Independent Checking Engineer	14 days	Wed 31/3/21	Tue 13/4/21	3	23		€ <u>1</u>		
23	-	Accept Proposed Independent Checking Engineer	14 days	Wed 14/4/21	Tue 27/4/21	22)		
24	1	Submit Proposed Ground Investigation Sub-contractor	14 days	Mon 12/4/21	Sun 25/4/21	16	25		<u>و ا</u>		
25	1	Accept Proposed Ground Investigation Sub-contractor	14 days	Mon 26/4/21	Sun 9/5/21	24	26,52		Q.		
26	100 A	Submit Proposed Piling Sub-contractor	28 days	Mon 10/5/21	Sun 6/6/21	25	27				
27	1	Accept Proposed Piling Sub-contractor	14 days	Mon 7/6/21	Sun 20/6/21	26	55,28,29		<u>ě</u>		
28	-	Submit & Accept Proposed E&M Sub-contractor	56 days	Mon 21/6/21	Sun 15/8/21	27	58) è h		
29		Submit & Accept Proposed Lift/Escalator Sub-contractor	56 days	Mon 21/6/21	Sun 15/8/21	27	30,31,58		é en la companya de l		
30		Submit & Accept Bearing Sub-contractor	56 days	Mon 16/8/21	Sun 10/10/21	29	59				
31	-	Submit & Accept Proposed Movement Joint Sub-contractor	r 56 days	Mon 16/8/21	Sun 10/10/21	29	32,33,34,59		Š		
32		Submit & Accept Proposed Steelwork Sub-contractor	56 days	Mon 11/10/21	Sun 5/12/21	31	60				
33		Submit & Accept Proposed Waterproofing Sub-contractor	56 days	Mon 11/10/21	Sun 5/12/21	31					
34	-	Submit & Accept Proposed Road Marking Sub-contractor	56 days	Mon 11/10/21	Sun 5/12/21	31					
35	-	Contractural Submission	45 days	Wed 31/3/21	Fri 14/5/21	3			<u>ě</u>		
36	-	Initial Photo Record	7 days	Wed 31/3/21	Tue 6/4/21	3			T		
37	10P	Noise Mitigation Plan	7 days	Wed 31/3/21	Tue 6/4/21	3			T		
38	-	Safety Management Plan	30 days	Wed 31/3/21	Thu 29/4/21	3					
39	-	Environmental Managenet Plan	30 days	Wed 31/3/21	Thu 29/4/21	3					
40	-	Waste Management Plan	30 days	Wed 31/3/21	Thu 29/4/21	3					
41	-	Initial Condition Survey	45 days	Wed 31/3/21	Fri 14/5/21	3	65,121,177,245		<u>ا</u>		
42	1	Technical Submission	310 days	Wed 31/3/21	Thu 3/2/22				•		
43	199	Prepare Method Statement of Initial Survey	14 days	Wed 31/3/21	Tue 13/4/21	3	44				
44	100	Review & Resubmit MS of Initial Survey	6 days	Wed 14/4/21	Mon 19/4/21	43	45		8		
45	100	Acceptance of MS of Inijal Survey	7 days	Tue 20/4/21	Mon 26/4/21	44	63,120,176,242		¥.		
46		Prepare Method Statement of Tree Felling	14 days	Wed 14/4/21	Tue 27/4/21	19	47		ă.		
47		Review & Resubmit MS of Tree Felling	7 days	Wed 28/4/21	Tue 4/5/21	46	48				
48		Acceptance of MS of Tree Felling	14 days	Wed 5/5/21	Tue 18/5/21	47	66 122 179 246 273		¥		
49		Prenare Method Statement of Tree Transplanting	14 days	Wed 14/4/21	Tue 27/4/21	19	50		<u> </u>		
50		Review & Resubmit MS of Tree Transplanting	14 days	Wed 28/4/21	Tue 11/5/21	49	51				
51	300	Acceptance of MS of Tree Transplanting	14 days	Wed 12/5/21	Tue 25/5/21	50	123				
52		Prenare Method Statement of Ground Investigation	14 days	Mon 10/5/21	Sun 23/5/21	25	53				
53		Review & Resubmit MS of Ground Investigation	14 days	Mon 24/5/21	Sun 6/6/21	52	54				
54		Acceptance of MS of Ground Investigation	14 dave	Mon 7/6/21	Sun 20/6/21	53	70.127.185.248			4 11 1	
55		Prepare Method Statement of Piling Works	28 dave	Mon 21/6/21	Sun 18/7/21	27	56				
56		Review & Resubmit MS of Piling Works	14 dave	Mon 19/7/21	Sun 1/8/21	55	57				
57		Acceptance of MS of Piling Works	14 days	Mon 2/8/21	Sun 15/8/21	56	129.186.72		¥	44	
58		Submit & Accept of Lift & E&M Submission	60 days	Mon 16/8/21	Thu 14/10/21	28.29	87.142.191.218.253.277				
59		Submit & Accept bearing & MI Submission	60 days	Mon 11/10/21	Thu 9/12/21	30.31	89.144.192.220.257.281		I I I I I I I I I I I I I I I I I I I	T T T	
60		Submit & Accept Steelwork submission	60 davs	Mon 6/12/21	Thu 3/2/22	32	98.153.222.283				
61		Section 1 - E5 Escalator (Portion 1a & 1b)	997 dave	Mon 12/4/21	Wed 3/1/24						
62		Site Clearance	30 dave	Mon 12/4/21	Tue 11/5/21	16			100%		
63		Initial Survey	21 dave	Tue 27/4/21	Mon 17/5/21	45	65		100%		
64		Coordination with Housing Authority for Access	36 dave	Mon 12/4/21	Mon 17/5/21	16	65		100%		
65	1 - 3	Erection of Site Hoarding	21 days	Tue 18/5/01	Mon 7/6/21	63 41 64	66		100%		
66	1	Tree Felling	50 dave	Tue 8/6/01	Thu 5/8/21	65.48	67		100%	00%	
67	1-3	Trial Dit Excavation	7 days	Tuo 6/0/21	Mon 12/7/21	66	68 60				
60	1-3	Ital Fit Excavation	7 days	Tue 0///21	Mar 2/9/21	67	70.71		1009	log .	
00	1 ->	Unities Diversion	21 days	Tue 13/7/21	Non 2/8/21	07	/0,/1		10	0%	
09	1	Installation of Monitoring & Instrumentation Point	21 days	Tue 13/7/21	Mon 2/8/21	0/			10	.0%	
/0	15	Ground Investigation & install piezometer	45 days	Tue 3/8/21	Thu 16/9/21	68,54,4				<u>₽</u> 100%	
71	-	Fell Additional Trees (EWN001)	45 days	Tue 3/8/21	Thu 16/9/21	68	72		Í		
72	-	Form piling platform on Existing slope	102 days	Fri 17/9/21	Mon 27/12/2	1 71,57	74			With the second s	
73		Piling Works	190 days	Tue 28/12/21	Tue 5/7/22					Ţ1	
74	-	At Pile Cap E5-PC3 (12 nrs of 610mm PSH Piles)	50 days	Tue 28/12/21	Tue 15/2/22	72	75,79			in the second seco	
75	-	At Pile Cap E5-PC2 (16 nrs of 610mm PSH Piles)	70 days	Wed 16/2/22	Tue 26/4/22	74	76,80			a a a a a a a a a a a a a a a a a a a	
76	23	At Pile Cap E5-PC1 (16 nrs of 610mm PSH Piles)	70 days	Wed 27/4/22	Tue 5/7/22	75	77				
Projo	t Com	atract No. ED/2019/02 Task	Summary		Ir	active Milestone	Duration-only	S	tart-only	. External Milestone 🗇	Manual Progress
Date	Tue 2	1/8/21 Split	Project Summa	ry 📔	1 Ir	active Summary	Manual Summary Rollup	Fi	inish-only] Deadline 🐣	
Date.	ruc J	Milestone 🔶	Inactive Task		N	Ianual Task	Manual Summary	E	xternal Tasks	Progress	
					A*-						
]	Page 1			



Contract No. ED/2019/02

Development of Anderson Road Quarry Site -Remaining Pedestrian Connectivity Facilities Works

First Programme

ID	Tasl Ta	ask Name	Duration	Start	Finish	Predecessors	Successors	1, 2021 Qtr 2, 2021 Qtr 3, 2021 Qtr 4, 202	1 Qtr 1, 2022 Qtr 2, 2022 Qtr 3, 2022 Qtr 4, 2022	Qtr 1, 2023 Qtr 2, 2023
77	Moc	Loading Test of Piling	30 days	Wed 6/7/22	Thu 4/8/22	76	81	Feb Mar Apr May Jun Jul Aug Sep Oct Nov I	Dec Jan Feb Mar Apr May Jun Jul Aug Sep Oct Nov De	c Jan Feb Mar Apr May Ju
78		Excavation	230 days	Wed 16/2/22	Mon 3/10/22	10				
79	-	For Pile Cap E5-PC3	75 days	Wed 16/2/22	Sun 1/5/22	74	83			
80		For Pile Cap E5-PC2	75 days	Wed 27/4/22	Sun 10/7/22	75	84			
81		For Pile Cap E5-PC1	60 days	Fri 5/8/22	Mon 3/10/22	77	85		and the second se	
82	*	Pile Cap Construction	205 days	Mon 2/5/22	Tue 22/11/22	70	01			
84		For Pile Cap E5-PC3	60 days	Mon 11/7/22	Thu 30/6/22	79	91		*******	
85		For Pile Cap E5-PC1	50 days	Tue 4/10/22	Tue 22/11/22	81	88			
86	1	Construction of Piers	135 days	Fri 9/9/22	Sat 21/1/23					
87		For Pier E5-P2	42 days	Fri 9/9/22	Thu 20/10/22	84,58	91			
88	-	For Pier E5-P1	60 days	Wed 23/11/22	Sat 21/1/23	85	89			
89	-	Installation of Bearing	7 days	Sun 22/1/23	Sat 28/1/23	88,59	92			The second se
90	*	Construction of Escalator Trough	160 days	Fri 21/10/22	Wed 29/3/23	07.02	05			1
92		From $PC2 = PC1$	60 days	Sun 20/1/22	Wed 29/3/23	87,85	95		1,220 Mar	
93		Installation of Escalator	285 days	Sat 23/7/22	Wed 3/5/23	07	<i>)</i> 0		P	
94	-	Procument & Delivery of Escalator Material	150 days	Sat 23/7/22	Tue 20/12/22	95SF				
95		From PC3 - PC2	35 days	Tue 20/12/22	Mon 23/1/23	91	98,94SF			
96	10 A	From PC2 - PC1	35 days	Thu 30/3/23	Wed 3/5/23	92	98,106,101			1 Alexandre
97	E -3	Ordering of steel frame, rooting panels & fall arrest system	120 days	Thu 5/1/23	Thu 4/5/23	06.05.60.07	98			
90		Design Submission and Approval of A & A Works	60 days	Fri 5/5/23	Mon 3/7/23	96,95,60,97	109			
100	12 mg	Connection of Existing lift tower	60 days	Wed 1/3/23	Sat 29/4/23	99	100			
101		Installation of Movement Joint	14 days	Thu 4/5/23	Wed 17/5/23	96,100	103			
102	E ang	Ordering of balustrades, barriers & architectural features	120 days	Wed 18/1/23	Wed 17/5/23		103			
103	-	Finishing Work	90 days	Thu 18/5/23	Tue 15/8/23	101,102	107,110,111,104			
104	-	Remove existing soil nail	50 days	Wed 16/8/23	Wed 4/10/23	103	105			
105	-	Backfill pile caps & Reinstate existing Slope & Retaining wall	90 days	Thu 5/10/23	Tue 2/1/24	104	113			
106		Telemetry & Power Supply System	180 days	Thu 4/5/23	Mon 30/10/23	96	112			
107	->	Construction of Pillar Box	21 days	Wed 16/8/23	Tue 5/9/23	103	109,110,111			
100	-	F & M Installation & Lighting Installation	150 days	Sun 9/4/23	Wed 6/9/23	109SF	112 108SE			
110	-	Drainage & Misc. Road Works	120 days	Wed 6/9/23	Wed 3/1/24	107 103	112,1003F			
111		Landscaping Works	120 days	Wed 6/9/23	Wed 3/1/24	107,103	113			
112		Testing & Commissioning	60 days	Sun 5/11/23	Wed 3/1/24	109,106	113			
113	-	Section 1 Completion	0 days	Wed 3/1/24	Wed 3/1/24	112,110,105,111	115			
114		Section 1A - Establishment Works (Portion 1a & 1b)	365 days	Thu 4/1/24	Thu 2/1/25					
115	-	Establishment Works	365 days	Thu 4/1/24	Thu 2/1/25	113	116			
116		Section IA Completion	0 days	Thu 2/1/25	Thu 2/1/25	115				
117	+	Section 2 - E6 Escalator (Portion 2)	007 dava	Mon 12/4/21	Wed 2/1/24					
119		Site Clearance	30 days	Mon 12/4/21	Tue 11/5/21	16		100%		
120		Initial Survey	18 days	Tue 27/4/21	Fri 14/5/21	45	121.124	100%		
121		Erection of Site Hoarding	24 days	Sat 15/5/21	Mon 7/6/21	120,41	122.123	100%		
122	1	Tree Felling	21 days	Tue 8/6/21	Mon 28/6/21	121,48	125	100%		
123	1 884	Tree Transplanting	88 days	Tue 8/6/21	Fri 3/9/21	121,51	127	100%		
124	1	Coordination with HD for access & facilities relocation	45 days	Sat 15/5/21	Mon 28/6/21	120	125	100%		
125	1 mg	Take up park facilities & Furniture	21 days	Tue 29/6/21	Mon 19/7/21	122,124	126	100%		
126	1	Installation of Monitoring & Instrumentation Point	12 days	Tue 20/7/21	Sat 31/7/21	125		i 100%		
127	1	Ground Investigation	45 days	Sat 4/9/21	Mon 18/10/21	123,54	129	1009	6	
120		At Dile Can E6. DC3 (12 nrs of 610mm DSH Diles)	200 days	Tue 19/10/21	Fn 0/5/22	107 57	130 134			
130		At Pile Cap E6-PC2 (16 nrs of 610mm PSH Piles)	80 days	Sat 18/12/21	Mon 7/3/22	127,57	130,134	A CONTRACTOR		
131		At Pile Cap E6-PC1 (16 nrs of 610mm PSH Piles)	60 days	Tue 8/3/22	Fri 6/5/22	130	132			
132	-	Loading Test of Piling	30 days	Sat 7/5/22	Sun 5/6/22	131	136			
133		Excavation	230 days	Sat 18/12/21	Thu 4/8/22				1	
134	-	For Pile Cap E6-PC3	60 days	Sat 18/12/21	Tue 15/2/22	129	138			
135	-	For Pile Cap E6-PC2	15 days	Tue 8/3/22	Sat 21/5/22	130	139			
137		Pile Can Construction	220 days	Wed 16/2/22	Fri 23/0/22	132	140			
138		For Pile Cap E5-PC3	50 days	Wed 16/2/22	Wed 6/4/22	134	146			
139	-	For Pile Cap E5-PC2	50 days	Sun 22/5/22	Sun 10/7/22	135	142		*	
140	-	For Pile Cap E5-PC1	50 days	Fri 5/8/22	Fri 23/9/22	136	143		The second	
141	-	Construction of Piers	135 days	Mon 11/7/22	Tue 22/11/22				8	
142		For Pier E5-P2	42 days	Mon 11/7/22	Sun 21/8/22	139,58	146		HERRIC	
143		For Pier E5-P1	60 days	Sat 24/9/22	Tue 22/11/22	140	144		alone second	
144	-	Installation of Bearing	/ days	Wed 23/11/22	Tue 29/11/22	143,59	147		I III	
145	-	From PC3 - PC2	60 days	Mor 22/8/22	Jai 20/1/23	142 139	150			
147		From PC2 - PC1	60 days	Wed 30/11/22	Sat 28/1/23	142,100	150			
148		Installation of Escalator	285 days	Tue 24/5/22	Sat 4/3/23				P	
149	-	Procument & Delivery of Escalator Material	150 days	Tue 24/5/22	Fri 21/10/22	150SF				
150	-	From PC3 - PC2	35 days	Fri 21/10/22	Thu 24/11/22	146	153,149SF		Gilleman	+
151	-	From PC2 - PC1	35 days	Sun 29/1/23	Sat 4/3/23	147	153,156,163			
152	E	Ordering of steel trame, roofing panels & fall arrest system	120 days	Sat 5/11/22	Sat 4/3/23		153			
		Tack	Cummer	(merona and a second		ativa Milastan -	Duration only	Plant colu	Fatamel Milesters A	Marriel Deser
Project	: Contra	act No. ED/2019/02	Summary Project Summ		l Ina	cuve Milestone	Duration-only	Start-only	External Milestone	Manual Progress
Date: 7	ue 31/8	//21 Spin Milestone	Inactive Teel	y U	d ina	nual Task	Manual Summary Kollup	Fillish-only	Progress	
		Whiestone V	mactive Task		Ma	nual IdSK	ivialitiai Sutiitiiai y	EAUCHIAL LASKS	Received Linking	
								Page 2		



Contract No. ED/2019/02 Development of Anderson Road Quarry Site -Remaining Pedestrian Connectivity Facilities Works

D	Tasl Tas	k Name	Duration	Start	Finish	Predecessors	Successors	1, 2021 Qtr 2, 2021 Qtr 3, 2021 Qtr 4, 2021 Qtr 1, 2022 Qtr 2, 2022 Qtr 3, 2022 Qtr 4, 2022 Qtr 1, 2023 Qtr 2, 2023
153	Moc	Erection of Conony	60 daria	Sum 5/2/22	Wed 215/22	151 60 150 150	162	Feb Mar Apr May Jun Jul Aug Sep Oct Nov Dec Jan Feb Mar Apr May Jun Jul Aug Sep Oct Nov Dec Jan Feb Mar Apr May Jun
154		Design Submission and Approval of A & A Works	200 days	Sull 3/3/23	Wed 5/5/25	151,00,150,152	105	
155	E	Connection of Existing lift towar	500 days	Wed 20/10/21	Mon 15/8/22	154	155	
155		Installation of Movement Loint	00 days	Tue 10/8/22	FIT 14/10/22	154	150	
150		Ordering of heliustrades, herriers & architectural features	14 days	Sun 3/3/23	Sat 18/3/23	151,155	158	
157	E	Finishing West	120 days	Sat 19/11/22	Sat 18/3/23	156 157	158	
150		Finishing work	90 days	Sun 19/3/23	Fri 10/0/23	150,157	159,100	
159	-	Backfill pile caps	60 days	Sat 17/6/23	Tue 15/8/23	158	161	
160		Telemetry & Power Supply System	180 days	Sat 17/6/23	Wed 13/12/23	158		
161		Construction of Pillar Box	21 days	Wed 16/8/23	Tue 5/9/23	159	163,164	
162		Procument & Delivery of E&M Material	150 days	Sun 9/4/23	Wed 6/9/23	163SF		
163	1	E & M Installation & Lighting Installation	60 days	Wed 6/9/23	Sat 4/11/23	151,161,153	167,162SF	
164		Drainage & Misc. Road Works	60 days	Wed 6/9/23	Sat 4/11/23	161	165,166	
165		Reinstatement of park facilities	60 days	Sun 5/11/23	Wed 3/1/24	164	168	
166	-	Landscaping Works	60 days	Sun 5/11/23	Wed 3/1/24	164	168	
167		Testing & Commissioning	60 days	Sun 5/11/23	Wed 3/1/24	163	168	
168	-	Section 2 Completion	0 days	Wed 3/1/24	Wed 3/1/24	165,167,166	170	
169	100	Section 2A - Establishment Work (Portion 2)	365 days	Thu 4/1/24	Thu 2/1/25	,,,		
170		Establishment Works	365 days	Thu 4/1/24	Thu 2/1/25	168	171	
171	197	Section 2A Completion	0 days	Thu 2/1/25	Thu 2/1/25	170		
172			0 000,0					
173		Section 3 - E7 Bridge (Portion 3a & 3b)	1083 days	Mon 12/4/21	Fri 29/3/24			
174		Site Clearance	15 days	Mon 12/4/21	Mon 26/4/21	16	176	1007
175	a	F7 L ift Tower	1081 dave	Wed 14/4/21	Fri 20/3/24	10	170	
176	· · · · · · · · · · · · · · · · · · ·	Initial Survey	18 days	Tue 27/4/21	Fri 14/5/21	174.45	177	1000
177	1 mg	Erection of Site Hearding	21 days	Fat 15/5/21	Eri 1/6/01	174,45	177	
170	1=3	TTA for Site Fotorer & Der Stern Dalaret	ZI days	Sat 15/5/21	FII 4/0/21	170,41	179,180	
170		T A for Site Entrance & Bus Stop Relocation	52 days	wed 14/4/21	Fri 4/6/21	21	179	100%
1/9	E S	The Felling	95 days	Sat 5/6/21	Sun 5/9/21	1/7,48,178	18277	· · · · · · · · · · · · · · · · · · ·
180	1 - 5	Trial Pit Excavation	18 days	Sat 5/6/21	Tue 22/6/21	177	181	<u> </u>
181	E	Installation of Monitoring & Instrumentation Point	100 days	Wed 23/6/21	Thu 30/9/21	180	187	◆ 50%
182	E	Fell Additional Trees (P-T00260; PMI No.8)	42 days	Mon 26/7/21	Sun 5/9/21	179FF	185FF+5 days,183FF+5 days,184FF+5 days	
183	107	Street Light Relocation	42 days	Sat 31/7/21	Fri 10/9/21	182FF+5 days	186	
184	10 T	Diversion of existing staircase	42 days	Sat 31/7/21	Fri 10/9/21	182FF+5 days		
185		Installation Piezometer & Ground Investigation	35 days	Sat 7/8/21	Fri 10/9/21	54,182FF+5 days	186	
186	-	Form piling platform on Existing slope	60 days	Sat 11/9/21	Tue 9/11/21	57,183,185	187	
187	100	Piling Work (68 nrs of 323mm Mini-piles)	180 days	Wed 10/11/21	Sun 8/5/22	186,181	188	
188		Loading Test	30 days	Mon 9/5/22	Tue 7/6/22	187	189	
189	100	Excavation of pile cap	90 days	Wed 8/6/22	Mon 5/9/22	188	190	
190	100	Pile Cap Construction	45 days	Tue 6/9/22	Thu 20/10/22	189	191	
191		Construction of Lift Tower (9 Pours)	210 days	Fri 21/10/22	Thu 18/5/23	190 58	192 194SS+150 days 195	
192		Installation of Bearing	7 days	Fri 10/5/23	Thu 25/5/23	101 50	225	
103		Exprication of Lourwas & Glazing	150 days	Eri 21/10/22	Sun 10/3/23	171,57	104	
10/	12 mg	Installation of Lourves & Glazing	100 days	Man 20/2/22	Mon 17/7/22	10199 150 dava 102	194 108 20255 (60 days 200 202	
104		This anaton of Lourves & Glazing	120 days	NION 20/5/25	Wion 17/7/25	19155+150 days,195	198,20255+60 days,200,205	
195		Telemetry & Power Supply System	180 days	Fri 19/5/23	Tue 14/11/23	191	196	
196		Construction of Pillar Box	21 days	Wed 15/11/23	Tue 5/12/23	195		
197		Procument & Delivery of Lift Material	150 days	Sat 18/2/23	Tue 18/7/23	198SF		
198		Lift Installation	150 days	Tue 18/7/23	Thu 14/12/23	194	207,197SF	
199		Procument & Delivery of E&M Material	150 days	Sat 18/2/23	Tue 18/7/23	200SF		
200	-	E & M Installation & Lighting Installation	196 days	Tue 18/7/23	Mon 29/1/24	194	207,199SF	
201	E	Ordering of balustrades, barriers & architectural features	120 days	Thu 19/1/23	Thu 18/5/23		202	
202	100	Finishing Work of Lift Tower	120 days	Fri 19/5/23	Fri 15/9/23	194SS+60 days,201	204	
203	197	Waterpoofing & Installation of Fall Arrest System	60 days	Tue 18/7/23	Fri 15/9/23	194		
204		Removal of scaffolding	46 days	Sat 16/9/23	Tue 31/10/23	202	205	
205	100	Backfill and Reinstate existing slope	90 days	Wed 1/11/23	Mon 29/1/24	204	206	
206	100	Underground drainage & water main works	60 days	Tue 30/1/24	Fri 29/3/24	205	234	
207		Testing & Commissioning	60 dave	Tue 30/1/24	Fri 20/3/24	200 198	234	
208		F7 Pier	1083 dave	Mop 12/4/21	Fri 20/3/24	200,170	22 T	
200		Prepare & Endorse TTA scheme by TMLC	60 dava	Mor 12/4/21	Thu 10/6/21	16	210	1000
210	1-3	Application of Execution Domit	180 dama	Eri 11/6/21	Tuo 7/12/21	200	210	
210		Application of Excavation Permit	100 days	FIL 11/0/21	Tue //12/21	209	211	30%
211		Implementation of 11A at carriageway	14 days	wed 8/12/21	Tue 21/12/21	210	212	
212	1	Installation of Monitoring & Instrumentation Point	/ days	Wed 22/12/21	Tue 28/12/21	211	213	
213		Irial Pit Excavation	21 days	Wed 29/12/21	Tue 18/1/22	212	214,215	
214		Relocation of street light post	21 days	Wed 19/1/22	Tue 8/2/22	213	216	
215	1	Utilities Diversion	150 days	Wed 19/1/22	Fri 17/6/22	213	216	
216	80 <u>3</u>	Excavation of footing	180 days	Sat 18/6/22	Wed 14/12/22	215,214	217	
217	-	Construction of Footing E7-F2	45 days	Thu 15/12/22	Sat 28/1/23	216	218	There are a second s
218	100	Construction of Pier E7-P1 (4 Poues)	90 days	Sun 29/1/23	Fri 28/4/23	217,58	220,222,219	
219		Allowable for achievement of concrete strength	27 days	Sat 29/4/23	Thu 25/5/23	218	225	Y
220		Installation of Bearing	7 days	Sat 29/4/23	Fri 5/5/23	218,59	225	
221		Submit & obtain BD's approval for A&A Works at Carpark	180 days	Mon 31/10/22	Sat 29/4/23	222SF		
222		Forming support for steel bridge at Camark	7 days	Sat 29/4/23	Fri 5/5/23	218.60 5	225.221SE	
223	Tr man	Ordering of steel frame roofing namels & fall arrest system	120 dave	Sat 26/11/22	Sat 25/2/22	210,00,5	223,22101	
220		Fabrication of Steel Bridge	60 dave	Mon 27/2/22	Eri 26/5/22	225SE 223	227	
224		Fraction of Steel Bridge	28 days	Fri 76/5/22	Thu 2015125	22301,223	226 224SE	
225		Construction of Consists alab	25 days	En 22/6/22	Thu 22/0/23	220,222,217,172	220,22+01	
220		Construction of Deefine State	SO James	FII 23/0/23	111u 27/7/23	223	228,221	
221		Construction of Koofing System	60 days	Fn 28/7/23	Mon 25/9/23	220	228,231	
Projec	t: Contrac	et No. ED/2019/02	Summary	1	Ina	ctive Milestone	Duration-only	Start-only External Milestone 🛇 Manual Progress
Date:	Tue 31/8/	/21 Split	Project Summa	ry 🛙	1 Ina	ctive Summary	Manual Summary Rollup	Finish-only Deadline
		Milestone 🔶	Inactive Task		Ma	nual Task	Manual Summary	External Tasks Progress
							~	2
							P	ago o



Contract No. ED/2019/02 Development of Anderson Road Quarry Site - Remaining Pedestrian Connectivity Facilities Works	<u>First Programme</u>							
D Tasl Task Name	Duration	Start	Finish	Predecessors	Successors	1, 2021 Qtr 2, 2021 Qtr 3, 2021 Qtr 4, 2021 Qtr 1, 2022 Qtr 2, 2022 Qtr 3		
228 E & M Installation & Lighting Installation	90 days	Tue 26/9/23	Sun 24/12/23	227	234	reo Mar Apr May Jun Jun Aug Sep Oct Nov Dec Jan Peo Mar Apr May Jun Jul J		
229 E	300 days	Sat 1/10/22	Thu 27/7/23		230			
230 Connection of Existing car park	60 days	Fri 28/7/23	Mon 25/9/23	226,229				
231 Installation of Movement Joint	7 days	Tue 26/9/23	Mon 2/10/23	227	232			
232 Finishing work of bridge deck	120 days	Tue 3/10/23	Tue 30/1/24	231	233			
233 Landscaping Works	59 days	Wed 31/1/24	Fri 29/3/24	232	234			
234 Section 3 Completion	0 days	Fri 29/3/24	Fri 29/3/24	206,207,228,233	236			
235 Section 3A - Establishment Works (Portion 3a & 3b)	365 days	Sat 30/3/24	Sat 29/3/25					
236 Establishment Works	365 days	Sat 30/3/24	Sat 29/3/25	234	237			
237 Section 3A Completion	0 days	Sat 29/3/25	Sat 29/3/25	236				
238								
239 section 4 - E10 Bridge (Portion 4a & 4b)	1083 days	Mon 12/4/21	Fri 29/3/24					
240 Site Clearance	30 days	Mon 12/4/21	Tue 11/5/21	16	242	100%		
241 E10 Lift Tower	1083 days	Mon 12/4/21	Fri 29/3/24					
242 Initial Survey	14 days	Wed 12/5/21	Tue 25/5/21	240,45		100%		
243 Prepare & Endorse TTA scheme by TMLG	60 days	Mon 12/4/21	Thu 10/6/21	16	244	100%		
244 Implement TTA to form site entrance	1 day	Thu 26/8/21	Thu 26/8/21	243,6	245	100%		
245 Erection of Site Hoarding	14 days	Fri 27/8/21	Thu 9/9/21	244,41	246	3		
246 Tree Felling	14 days	Fri 10/9/21	Thu 23/9/21	245,48	249SS,247SS+9 days,248SS			
247 Installation of Monitoring & Instrumentation Point	14 days	Sun 19/9/21	Sat 2/10/21	246SS+9 days				
248 Installation Piezometer & Ground Investigation	23 days	Fri 10/9/21	Sat 2/10/21	246SS,54				
249 Fell Additional Trees (EWN001)	23 days	Fri 10/9/21	Sat 2/10/21	246SS	250			
250 Excavation of Footing E10-FT1	240 days	Sun 3/10/21	Mon 30/5/22	249	251			
251 Construction of Footing	45 days	Tue 31/5/22	Thu 14/7/22	250	252	×		
252 Erection of Tower Crane	45 days	Fri 15/7/22	Sun 28/8/22	251	253	×		
253 Construction of Lift Tower (12 pours)	300 days	Mon 29/8/22	Sat 24/6/23	252.58	254SS+30 days 256SS+240 days 257			
254 Backfill of E10-PT1	60 days	Wed 28/9/22	Sat 26/11/22	25355+30 days	258			
255 Fabrication of Lourves & Glazing	150 days	Sat 26/11/22	Mon 24/4/23	25566+56 days	256			
256 Installation of Lourves & Glazing	120 days	Wed 26/4/23	Wed 23/8/23	25355+240 days 255	261 26588+60 days 263 266			
257 Installation of Bearing	7 days	Sun 25/6/23	Sat 1/7/23	253 59	286			
258 Telemetry & Power Supply System	180 days	Sun 27/11/22	Thu 25/5/23	254	259			
259 Construction of Pillar Box	21 days	Fri 26/5/23	Thu 15/6/23	258	263			
260 Procument & Delivery of Lift Material	150 days	Mon 27/3/23	Thu 24/8/23	250 261SE	205			
261 Lift Installation	90 days	Thu 24/8/23	Tue 21/11/23	256	267 260SF			
262 Procument & Delivery of F&M Material	150 days	Mon 27/3/23	Thu 24/8/23	263SE	201,20001			
263 E & M Installation & Lighting Installation	160 days	Thu 24/8/23	Tue 30/1/24	256 259	270.262SE			
264 Ordering of balustrades barriers & architectural features	120 days	Sat 25/2/23	Sat 24/6/23	200,200	265			
265 Finishing Work of Lift Tower	140 days	Sun 25/6/23	Sat 11/11/23	25688+60 days 264	265			
266 Waterpoofing & Installation of Fall Arrest System	60 days	Thu 24/8/23	Sun 22/10/22	256	207			
267 Removal of scaffolding	30 days	Wed 22/11/22	Thu 21/12/22	250	268			
268 Ground Level Drainage & water main laving	40 days	Fri 22/11/23	Tue 30/1/24	203,201	200			
260 Painetetement and Mise Poodwork	50 days	Wod 21/12/23	Fri 20/2/24	207	205			
207 Remstatement and Misc. Roadwork	J9 days	weu 31/1/24	FII 29/3/24	200	293			

Wed 31/1/24 Fri 29/3/24 263

Fri 29/3/24

Fri 11/3/22

Mon 8/8/22

Sat 9/7/22

Thu 29/12/22 Tue 17/1/23 281,60,277

Tue 2/5/23

Sun 2/7/23

Sat 29/7/23

Sat 2/9/23

Sat 2/9/23

Sun 3/3/24

Fri 29/3/24

Fri 29/3/24

Sat 29/3/25

Sat 29/3/25

Sat 29/3/25 Sat 29/3/25

Thu 22/12/22 Wed 28/12/22 277,59

Thu 28/10/21 4

Thu 11/11/21 272,48

Thu 22/9/22 275

Sun 10/4/22 274

Wed 21/12/22 276,58

Thu 29/12/22 283SF

Wed 1/11/23 287

Mon 19/2/24 288

Wed 1/11/23 287,290

Wed 8/11/23 288,291

273

274

278

279

286

292

293

295

297

286SF,284

280,281,283,257

269,270,289,294

Sat 31/7/21

Sat 31/7/21

Fri 29/10/21

Fri 12/11/21

Sat 12/3/22

Tue 9/8/22

Fri 23/9/22

Sat 12/3/22

Mon 11/4/22

Sat 2/7/22

Tue 3/1/23

Wed 3/5/23

Sun 2/7/23

Sun 30/7/23

Sun 3/9/23

Thu 2/11/23

Mon 7/11/22

Sun 3/9/23

Thu 2/11/23

Thu 9/11/23

Mon 4/3/24

Fri 29/3/24

Sat 30/3/24

Sat 30/3/24

Sun 10/7/22 Fri 5/8/22

59 days

973 days

90 days

14 days

120 days

150 days

45 days

90 days

30 days

90 days

27 days

7 days

20 days

60 days

28 days

35 days

60 days

110 days

300 days

60 days

7 days

116 days

26 days

0 days

365 days

365 days

0 days

Excavation of Footing E10-FT2

Excavation of Footing E10-FT3

Construction of Footing E10_FT3

Construction of Abutment on FT3

Construction of Footing E10-FT2

Installation of Bearing

Fabrication of Steel Bridge

Construction of Concrete slab

Construction of Roofing System

Installation of Movement Joint

Finishing work of bridge deck

Section 4A - Establishment Works (Portion 4a & 4b)

Landscaping Works

Section 4A Completion

Section 4 Completion

Erection of Steel Bridge

Construction of Pier E10-P1 (4 pours)

Allowable for achievement of concrete strength

Forming support for steel bridge at Podium

E & M Installation & Lighting Installation

Connection of Existing Estate Prodium

Design Submission and Approval of A&A Works

Submit & obtain BD's approval for A&A Works at Carpark 180 days

Ordering of steel frame, roofing panels & fall arrest system 120 days

Testing & Commisioning

Pier & Abutment

Tree Felling

Form Haul Road

288 289

291 292

293

294 -

295 296 297

-

-

22

-

-

 297
 =
 Establishment Works

 298
 =
 Section 4A Completion

Project: Contract No. ED/2019/02	Task		Summary		Inactive Milestone		Duration-only	1222	Start-only	E	External Milestone	\diamond	Manual Progress	*******
Date: Tue 31/8/21	Split		Project Summary	1	Inactive Summary	0 0	Manual Summary Rollup		Finish-only	3	Deadline	4		
	Milestone	•	Inactive Task		Manual Task		Manual Summary	·1	External Tasks		Progress	4815452555555555454555555555555555555555		

295

273

274

276

277

279

280

286

285

286,283

286,282SF

287,285SF

288,291

289,292

295

291

292

293

294

295

297

298

278,275

281,283





Appendix D

Monitoring Locations for Impact Monitoring



Monitoring Locations for Contract 1 (NE/2016/01)

















Monitoring Locations for Contract 3 (NE/2017/03)



inted by : 6/3/ ename : \\HK

2012





Appendix E

Calibration Certificate of Monitoring Equipment and HOKLAS-accreditation Certificate of the Testing Laboratory

TSP SAMPLER CALIBRATION CALCULATION SPREADSHEET


Location : Oi Tat House Date of Calibration: 31-Jan-22										
Location ID : AMS 5 Model: TISCH High Volume Air Sampler TE 5170							Next Calibra	ation Date: 31-Mar-22		
Model:TIS	SCH Hig	h Volum	e Air Sa	mpler TE-5	170		T	ſechnician: Mr. Fai So		
						COND	ITIONS			
	Se	a Level]	Pressure	(hPa)		1019.2]	Corrected Pressure (mm Hg) 764.	.4	
		Temŗ	perature	(°C)		14.6		Temperature (K) 28	;8	
				· · · _						
	CALIBRATION ORIFICE									
				Make->	TIS	сн	1	Octol Slope -> 1 9983	28	
				Model->	TE-	5025A	-	Ostd Intercept -> -0.0090	13	
				Serial # ->	194	1	1		<u> </u>	
ļ										
						CALIBI	RATION			
Plate	H20 (L)	H2O (R)	H20	Qstd		Ι	IC	LINEAR		
No.	(in)	(in)	(in)	(m3/min)	(c	hart)	corrected	REGRESSION		
18	6.4	6.4	12.8	1.832		53	54.11	Slope = 37.0824		
13	5.3	5.3	10.6	1.668		46	46.96	Intercept = -14.3889		
10	4	4	8	1.449		38	38.79	Corr. coeff. = 0.9992		
1	2.0 1 4	2.0 1.4	5.2 2.8	1.109		29 17	29.01 17.35			
	1.4	1.4	2.0	0.039		17	11.33			
Calculation	ns :					60.0	00	FLOW RATE CHART		
Qstd = 1/n	n[Sqrt(H	20(Pa/Ps	td)(Tstd/	/Ta))-b]						
IC = I[Sqr	t(Pa/Pstd	.)(Tstd/Ta	a)]							
O-t-l ata	Jand fla					50.0	00			
Qstd = stateIC = correction	ndard IIO	W rate	<u>مر</u>							
I = actual	chart rest	nonse	28			(2) 40.0	00			
m = calibr	ator Qstc	i slope				ouse				
b = calibra	ator Qstd	intercept	t			dsau 30.0	nn			
Ta = actua	al temper	ature dur	ing calil	oration (deg	g K	chart				
Pstd = actu	ual press	ure durin	g calibra	ation (mm I	Hg	tual c				
Ear subse	ouont ca	louistion	ofsami	nlar flaw:		¥ 20.0	00			
1/m((])[S	Guern Cart	Γ _{av})(Pav	01 sann (/760)]_h							
	lq1((270)).	Ιανχιαν	//00/]-0)		10.0	00			
m = sampl	ler slope									
b = sampl	ler interce	ept				0.0	00			
I = chart re	esponse						0.000	0.500 1.000 1.500 2.000 Standard Flow Rate (m3/min)	,	
Tav = dail	y average	e tempera	ature					Stahuaru i iow itale (inomini)		
Pav = dang	y average	e pressur	e							

Location : Hau Tat House							Date of C	alibration:	31-Jan-22		
Location 1	D :	AMS 6				Ν	Next Calibra	tion Date:	31-Mar-22		
Model:TIS	SCH Hig	h Volum	e Air Sa	mpler TE-51	170		T	echnician:	Mr. Fai So		
					C	ONDI	IONS				
	Se	a Level I	Pressure	(hPa)]	019.2		Correc	ted Pressure	(mm Hg)	764.4
		Temp	erature	(°C)		14.6		- -	Temperature	(K)	288
				C	ALIB	RATIO	N ORIFICE				
				Make->	FISC	H		Q	std Slope ->		1.99838
				Model->'	ГЕ-5	025A		Qstd	Intercept ->		-0.00903
				Serial # ->	1941						
					C	ALIBR/	ATION				
Plate	H20 (L)	H2O (R)	H20	Qstd		Ι	IC		LINE	EAR	
No.	(in)	(in)	(in)	(m3/min)	(ch	art)	corrected		REGRES	SSION	
18	6.2	6.2	12.4	1.803	5	51	52.06	Slope = 36.5402			2
13	5.4	5.4	10.8	1.683	L	46		-14.6237	7		
10	3.7	3.7	1.4	1.394	: -	5	35.73	С	corr. coeff. =	0.9980)
7 5	2.4	2.4 1.4	4.8	1.124	ے 1	6	27.30 16.33				
	1.1	1.1	2.0	0.057	د 	.0	10.55				
Calculatio	ons :							FLOW	RATE CHAR	т	
Qstd = 1/r	n[Sqrt(H	20(Pa/Ps	td)(Tstd	/Ta))-b]		60.00					
IC = I[Squ	t(Pa/Pstc	l)(Tstd/T	a)]								
Oatal ata	ndord fla					50.00					
Qsid = sid IC = correction	nuaru nu ected chai	ow rate	es								▲
I = actual	chart res	ponse	20		é	<u>2</u> 40 00					
m = calibi	ator Qst	l slope									
b = calibra	ator Qstd	intercep	t			spor					
Ta = actua	al temper	ature dur	ing calil	oration (deg	K.	20.00					
Pstd = act	ual press	ure durin	g calibra	ation (mm H	Ig :						
For subsequent calculation of sampler flow:						20.00					
1/m((I)[Sqrt(298/Tav)(Pav/760)]-b)									•		
	<u> </u>		· · · ·	-		10.00					
m = samp	ler slope										
b = samp	ler interc	ept									
I = chart r	esponse					0.00 ().000	0.500	1.000	1.500	2.000
Tav = dai	ly averag	e temper	ature					Standard	Flow Rate (m3/	min)	
Pav = aan	y averag	e pressur	C								

т.,		<u>т 1</u>	7.11					1 1·1 /·	21 1 00		
Location :	Ma Yau	long	Village			N	Date of C	alibration:	31-Jan-22		
Location J	D: A	MS /	C .		170	N		ation Date:	31-Mar-22		
Model: 11	SCH HIgh	volum	e All Sa		1/0				Ivii. Fai 50		
					CO	וטאי	TIONS				
	Sea I	[evel]	Dreccure	(hPa)	101	10.2		Correc	ted Pressure (m	m Hg) 764 A	
	5041	Temr	erature	(III a)	101	17.2		COILCE	Temperature (K)	(1112) 704.4	
		romp	Ciature	(\mathbf{C})	1	17.0) 200	
				C	ALIBR	ATIC	N ORIFIC	E			
				Make->	TISCH			Q	std Slope ->	1.99838	
				Model->	TE-502	25A		Qstd	Intercept ->	-0.00903	
				Serial # ->	1612						
					C A I						
					CAL	LIDK	ATION				
Plate	H20 (L)H2	20 (R)	H20	Qstd	Ι		IC		LINEAF	2	
No.	No. (in) (in) (in) (m $3/min$) (char				(char	t)	corrected		REGRESSI	ION	
18	6.6	6.6	13.2	1.861	53		54.11		Slope = 37.4739		
13	5.6	5.6	11.2	1.714	48	49.00			Intercept = -15.4081		
10	3.7	3.7	7.4	1.394	37		37.77	С	Corr. coeff. = 0.9982		
7	2.9	2.9	5.8	1.235	29		29.61				
5	1.7	1.7	3.4	0.946	20		20.42				
	ons :	VD- /D-	د. ۱) (T-+ 1	/1.1.1	Ē						
Qsta = 1/1 IC = IIS at	n[Sqrt(H20 #(Do/Dotd)/	/(Pa/PS	a)]	/1a))-0]		6	i0.00	FLO	W RATE CHAR	<u> </u>	
IC = I[Sql	II(Pa/Psid)(I SLU/ I	a)]								
Ostd – sta	ndard flow	rate									
$Q_{SIG} = SIG$ IC = corre	ected chart r	respon	es			5	0.00				
I = actual	chart respo	nse									
m = calibr	rator Qstd s	lope				<u></u> 94	0.00				
b = calibra	ator Qstd in	itercep	t			onse			/	*	
Ta = actua	al temperatu	ure dur	ing calil	oration (de	gK)	odsa 3	0.00				
Pstd = act	ual pressure	e durin	g calibra	ation (mm	Hg)	artr					
						al ch					
For subsequent calculation of sampler flow:							.0.00		•		
1/m((I)[Sqrt(298/Tav)(Pav/760)]-b)											
						1	0.00				
m = samp	ler slope										
b = samp	ler intercep	t					0.00				
I = chart r	esponse		- 4				0.000	0.500	1.000	1.500 2.000	
1 av = dat	ly average t	emper	ature					Standa	ard Flow Rate (m3/n	nin)	
rav = uall	iy average [JIESSUI	C								



RECALIBRATION DUE DATE:

December 27, 2022

Cal Data:	Deservices	27 2021	Calibration	Certificatio	on Informat	ion –	205	91/
Cal. Date:	Uecember	27, 2021	ROOTS	meter S/N:	438320	Ia:	295	ĸ
Operator: Calibration	Model #:	TE-5025A	Cali	brator S/N:	1612	Pa:	/40.4	mm Hg
	Run	Vol. Init (m3)	Vol. Final	ΔVol. (m3)	ΔTime (min)	ΔP (mm Hg)	ΔH (in H2O)	
	1	1	2	1	1.3890	3.2	2.00	1
	2	3	4	1	0.9760	6.4	4.00	1
	3	5	6	1	0.8740	7.9	5.00	1
	4	7	8	1	0.8320	8.8	5.50]
	5	9	10	1	0.6870	12.7	8.00	
				Data Tabula	tion]
	Vstd	Qstd	$\sqrt{\Delta H \left(\frac{Pa}{Pstd}\right)}$)(<u>Tstd</u>) Ta)		Qa	$\sqrt{\Delta H(Ta/Pa)}$	
	(m3)	(x-axis)	(y-ax	(y-axis)		(x-axis)	(y-axis)	
	0.9799	0.7055	1.40	29	0.9957	0.7168	0.8927	
	0.9756	0.9996	1.98	41	0.9914	1.0157	1.2624	
	0.9736	1.1140	2.21	83	0.9893	1.1320	1.4114	
	0.9724	1.1088	2.32	50	0.9881	1.18/6	1.4803	
	0.5075	m=	1.998	338	0.9626	1.4300 m=	1 25135	-
	QSTD	b= r=	-0.00	903	QA	b= r=	-0.00574	
				Calculation	ns]
	Vstd=	∆Vol((Pa-∆P))/Pstd)(Tstd/T	a)	Va=	ΔVol((Pa-Δl	P)/Pa)]
	Qstd=	Vstd/∆Time	ana ka mana ka mana ka mana ka mana ka mana ka mana ka ma		Qa=	Va/∆Time		
		//	For subsequ	ent flow rat	te calculatio	ns:	<u>_</u> \	
	Qstd=	1/m((√∆H(Pa <u>Tstd</u> Pstd Ta	-))-b)	Qa=	1/m((√∆⊦	l(Та/Ра))-b)	
	Standard	Conditions		_				
Tstd:	298.15	°K				RECA	LIBRATION	
Psta:	1 760 K	mm Hg Key			US EPA reco	ommends a	nnual recalibratio	on per 199
1H: calibrat	or manomet	er reading (i	n H2O)		40 Code	of Federal I	Regulations Part	50 to 51,
Ter lettral a	hsolute tem	eter reading	(mm Hg)		Appendix I	3 to Part 50	, Reference Meth	nod for the
Pa: actual h	arometric nr	essure (mm	Hg)		Determinat	ion of Susp	ended Particulat	e Matter i
b: intercept		23000 0 (1111)			th	e Atmosphe	ere, 9.2.17, page	30
m: slone				L				

Tisch Environmental, Inc.

145 South Miami Avenue

Village of Cleves, OH 45002

<u>www.tisch-env.com</u> TOLL FREE: (877)263-7610 FAX: (513)467-9005



Sun Creation Engineering Limited

Calibration & Testing Laboratory

Certificate of Calibration 校正證書

Certificate No. : C216478 證書編號

ITEM TESTED / 送檢項	頁目	(Job No./序引編號:IC21-2189)	Date of Receipt / 收件日期: 25 October 2021
Description / 儀器名稱	:	Sound Calibrator (EQ087)	
Manufacturer / 製造商	:	Rion	
Model No. / 型號	:	NC-74	
Serial No. / 編號	:	34657231	
Supplied By / 委託者	:	Action-United Environmental Services an	d Consulting
		Unit A, 20/F., Gold King Industrial Build	ing,
		35-41 Tai Lin Pai Road, Kwai Chung, N.	Г.

TEST CONDITIONS / 測試條件

Temperature / 溫度 : (23 ± 2)°C Line Voltage / 電壓 : --- Relative Humidity / 相對濕度 : (50 ± 25)%

TEST SPECIFICATIONS / 測試規範

Calibration check

DATE OF TEST / 測試日期 : 9 November 2021

TEST RESULTS / 測試結果

The results apply to the particular unit-under-test only. The results do not exceed manufacturer's specification. The results are detailed in the subsequent page(s).

The test equipment used for calibration are traceable to National Standards via :

- The Government of The Hong Kong Special Administrative Region Standard & Calibration Laboratory
- Agilent Technologies / Keysight Technologies

:

- Fluke Everett Service Center, USA

Tested By 測試

K P Cheuk

Project Engineer

K C/Lee Engineer

Certified By 核證 Date of Issue 簽發日期 :

10 November 2021

The test equipment used for calibration is traceable to the National Standards as specified in this certificate. This certificate shall not be reproduced except in full, without the prior written approval of this laboratory.

本證書所載校正用之測試器材均可溯源至國際標準。局部複印本證書需先獲本實驗所書面批准。



Sun Creation Engineering Limited

Calibration & Testing Laboratory

Certificate of Calibration 校正證書

Certificate No. : C216478 證書編號

- 1. The unit-under-test (UUT) was allowed to stabilize in the laboratory for over 12 hours before the commencement of the test.
- 2. The results presented are the mean of 3 measurements at each calibration point.
- 3. Test equipment :

Description	Certificate No.
Universal Counter	C213954
Multifunction Acoustic Calibrator	AV210017
Measuring Amplifier	C201309
	<u>Description</u> Universal Counter Multifunction Acoustic Calibrator Measuring Amplifier

- 4. Test procedure : MA100N.
- 5. Results :
- 5.1 Sound Level Accuracy

UUT	Measured Value	Mfr's Spec.	Uncertainty of Measured Value
Nominal Value	(dB)	(dB)	(dB)
94 dB, 1 kHz	94.1	± 0.3	± 0.2

5.2 Frequency Accuracy

UUT Nominal Value	Measured Value	Mfr's	Uncertainty of Measured Value
(kHz)	(kHz)	Spec.	(Hz)
1	1.001	1 kHz ± 1 %	± 1

Remark : The uncertainties are for a confidence probability of not less than 95 %.

Note :

Only the original copy or the laboratory's certified true copy is valid.

The values given in this Certificate only relate to the values measured at the time of the test and any uncertainties quoted will not include allowance for the equipment long term drift, variations with environment changes, vibration and shock during transportation, overloading, mis-handling, or the capability of any other laboratory to repeat the measurement. Sun Creation Engineering Limited shall not be liable for any loss or damage resulting from the use of the equipment.

本證書所載校正用之測試器材均可溯源至國際標準。局部複印本證書需先獲本實驗所書面批准。

The test equipment used for calibration is traceable to the National Standards as specified in this certificate. This certificate shall not be reproduced except in full, without the prior written approval of this laboratory.



Sun Creation Engineering Limited

Calibration & Testing Laboratory

Certificate of Calibration 校正證書

Certificate No. : C216480 證書編號

ITEM TESTED / 送檢I	項目	(Job No. / 序引編號:IC21-2189)	Date of Receipt / 收件日期: 25 October 2021
Description / 儀器名稱	:	Sound Level Meter (EQ015)	
Manufacturer / 製造商	:	Rion	
Model No. / 型號	:	NL-52	
Serial No. / 編號	:	00142581	
Supplied By / 委託者	:	Action-United Environmental Services an	d Consulting
		Unit A, 20/F., Gold King Industrial Build	ing,
		35-41 Tai Lin Pai Road, Kwai Chung, N.	Г.
Supplied By / 委託者	:	Action-United Environmental Services an Unit A, 20/F., Gold King Industrial Build 35-41 Tai Lin Pai Road, Kwai Chung, N.	nd Consulting ing, T.

TEST CONDITIONS / 測試條件

Temperature / 溫度 : (23 ± 2)°C Line Voltage / 電壓 : --- Relative Humidity / 相對濕度 : (50 ± 25)%

TEST SPECIFICATIONS / 測試規範

Calibration

DATE OF TEST / 測試日期 : 9 November 2021

TEST RESULTS / 測試結果

The results apply to the particular unit-under-test only. The results do not exceed manufacturer's specification. (after adjustment) The results are detailed in the subsequent page(s).

The test equipment used for calibration are traceable to National Standards via :

- The Government of The Hong Kong Special Administrative Region Standard & Calibration Laboratory
- Agilent Technologies / Keysight Technologies
- Fluke Everett Service Center, USA

Tested By 測試

K P Cheuk Project Engineer

K 🛛 Lee Engineer

Certified By 核證

Date of Issue 簽發日期

:

10 November 2021

The test equipment used for calibration is traceable to the National Standards as specified in this certificate. This certificate shall not be reproduced except in full, without the prior written approval of this laboratory.

本證書所載校正用之測試器材均可溯源至國際標準。局部複印本證書需先獲本實驗所書面批准。

Sun Creation Engineering Limited – Calibration & Testing.Laboratory c/o 4/F, 1 Hing On Lane, Tuen Mun, New Territories, Hong Kong 輝創工程有限公司 - 校正及檢測實驗所 c/o 香港新界屯門興安里一號四樓 Tel/電話: (852) 2927 2606 Fax/傳真: (852) 2744 8986 E-mail/電郵: callab@suncreation.com Website/網址: www.suncreation.com Page 1 of 4



Sun Creation Engineering Limited

Calibration & Testing Laboratory

Certificate of Calibration 校正證書

Certificate No. : C216480 證書編號

- 1. The unit-under-test (UUT) was allowed to stabilize in the laboratory for over 12 hours, and switched on to warm up for over 10 minutes before the commencement of the test.
- 2. Self-calibration using the internal standard (After Adjustment) was performed before the test 6.1.1.2 to 6.3.2.
- 3. The results presented are the mean of 3 measurements at each calibration point.
- 4. Test equipment :

- 5. Test procedure : MA101N.
- 6. Results :
- 6.1 Sound Pressure Level
- 6.1.1 Reference Sound Pressure Level
- 6.1.1.1 Before Adjustment

	UUT	Setting		Applie	Applied Value		IEC 61672
Range	Function	Frequency	Time	Level	Freq.	Reading	Class 1 Spec.
(dB)		Weighting	Weighting	(dB)	(kHz)	(dB)	(dB)
30 - 130	L _A	Α	Fast	94.00	1	* 96.3	± 1.1
* Out of IEC	61672 Class	1 Smaa				•	•

* Out of IEC 61672 Class 1 Spec.

6.1.1.2 After Adjustment

	UUT	Setting		Applie	d Value	UUT	IEC 61672
Range	Function	Frequency	Time	Level	Freq.	Reading	Class 1 Spec.
(dB)		Weighting	Weighting	(dB)	(kHz)	(dB)	(dB)
30 - 130	L _A	A	Fast	94.00	1	94.0	± 1.1

6.1.2 Linearity

	UU	Γ Setting	Applied	d Value	UUT	
Range	Function	Frequency Time		Level	Freq.	Reading
(dB)		Weighting	Weighting	(dB)	(kHz)	(dB)
30 - 130	L _A	Α	Fast	94.00	1	94.0 (Ref.)
				104.00		104.0
				114.00		114.0

IEC 61672 Class 1 Spec. : \pm 0.6 dB per 10 dB step and \pm 1.1 dB for overall different.

本證書所載校正用之測試器材均可溯源至國際標準。局部複印本證書需先獲本實驗所書面批准。

Sun Creation Engineering Limited – Calibration & Testing Laboratory c/o 4/F, 1 Hing On Lane, Tuen Mun, New Territories, Hong Kong 輝創工程有限公司 - 校正及檢測實驗所 c/o 香港新界屯門興安里一號四樓 Tel/電話: (852) 2927 2600 Fax/傳真: (852) 2744 8986 E-mail/電郵: callab@suncreation.com Website/網址: www.suncreation.com

The test equipment used for calibration is traceable to the National Standards as specified in this certificate. This certificate shall not be reproduced except in full, without the prior written approval of this laboratory.



Sun Creation Engineering Limited

Calibration & Testing Laboratory

Certificate of Calibration 校正證書

Certificate No. : C216480 證書編號

Time Weighting 6.2

		Applied Value		UUT	IEC 61672		
Range	Function	Frequency	Time	Level	Freq.	Reading	Class 1 Spec.
(dB)		Weighting	Weighting	(dB)	(kHz)	(dB)	(dB)
30 - 130	L _A	Α	Fast	94.00	1	94.0	Ref.
			Slow			94.0	± 0.3

6.3 **Frequency Weighting**

6.3.1 A-Weighting

UUT Setting				Applied Value		UUT	IEC 61672
Range	Function	Frequency	Time	Level	Freq.	Reading	Class 1 Spec.
(dB)		Weighting	Weighting	(dB)		(dB)	(dB)
30 - 130	L _A	А	Fast	94.00	63 Hz	67.8	-26.2 ± 1.5
					125 Hz	77.8	-16.1 ± 1.5
					250 Hz	85.4	-8.6 ± 1.4
					500 Hz	90.8	-3.2 ± 1.4
					1 kHz	94.0	Ref.
					2 kHz	95.3	$+1.2 \pm 1.6$
		-			4 kHz	95.1	$+1.0 \pm 1.6$
					8 kHz	93.0	-1.1 (+2.1 ; -3.1)
					16 kHz	86.1	-6.6 (+3.5 ; -17.0)

6.3.2 C-Weighting

UUT Setting			Applie	ed Value	UUT	IEC 61672	
Range	Function	Frequency	Time	Level	Freq.	Reading	Class 1 Spec.
(dB)		Weighting	Weighting	(dB)		(dB)	(dB)
30 - 130	L _C	С	Fast	94.00	63 Hz	93.2	-0.8 ± 1.5
					125 Hz	93.9	-0.2 ± 1.5
					250 Hz	94.0	0.0 ± 1.4
					500 Hz	94.1	0.0 ± 1.4
					1 kHz	94.0	Ref.
					2 kHz	93.9	-0.2 ± 1.6
					4 kHz	93.3	-0.8 ± 1.6
					8 kHz	91.1	-3.0 (+2.1 ; -3.1)
					16 kHz	84.2	-8.5 (+3.5 ; -17.0)

The test equipment used for calibration is traceable to the National Standards as specified in this certificate. This certificate shall not be reproduced except in full, without the prior 本證書所載校正用之測試器材均可溯源至國際標準。局部複印本證書需先獲本實驗所書面批准。



Certificate of Calibration 校正證書

Certificate No. : C216480 證書編號

Remarks : - UUT Microphone Model No. : UC-59 & S/N : 20044

- Mfr's Spec. : IEC 61672 Class 1

- Uncertainties of Applied Value :	94 dB : 63 Hz - 125 Hz	: ± 0.35 dB
	250 Hz - 500 Hz	$\pm 0.30 \text{ dB}$
	1 kHz	$\pm 0.20 \text{ dB}$
	2 kHz - 4 kHz	$\pm 0.35 \text{ dB}$
	8 kHz	$\pm 0.45 \text{ dB}$
	16 kHz	$\pm 0.70 \text{ dB}$
	104 dB : 1 kHz	$\pm 0.10 \text{ dB}$ (Ref. 94 dB)
	114 dB : 1 kHz	$\pm 0.10 \text{ dB}$ (Ref. 94 dB)

- The uncertainties are for a confidence probability of not less than 95 %.

Note :

Only the original copy or the laboratory's certified true copy is valid.

The values given in this Certificate only relate to the values measured at the time of the test and any uncertainties quoted will not include allowance for the equipment long term drift, variations with environment changes, vibration and shock during transportation, overloading, mis-handling, or the capability of any other laboratory to repeat the measurement. Sun Creation Engineering Limited shall not be liable for any loss or damage resulting from the use of the equipment.

本證書所載校正用之測試器材均可溯源至國際標準。局部複印本證書需先獲本實驗所書面批准。

The test equipment used for calibration is traceable to the National Standards as specified in this certificate. This certificate shall not be reproduced except in full, without the prior written approval of this laboratory.



Sun Creation Engineering Limited

Calibration & Testing Laboratory

Certificate of Calibration 校正證書

Certificate No. : C216692 證書編號

ITEM TESTED / 送檢項目		(Job No. / 序引編號: IC21-2303) Date of Receipt / 收件日期: 9 November 2021
Description / 儀器名稱	:	Integrating Sound Level Meter (EQ006)
Manufacturer / 製造商	:	Brüel & Kjær
Model No. / 型號	:	2238
Serial No. / 編號	:	2285762
Supplied By / 委託者	:	Action-United Environmental Services and Consulting
		Unit A, 20/F., Gold King Industrial Building,
		35-41 Tai Lin Pai Road, Kwai Chung, N.T.

TEST CONDITIONS / 測試條件

Temperature / 溫度 : (23 ± 2)°C Line Voltage / 電壓 : --- Relative Humidity / 相對濕度 : (50±25)%

TEST SPECIFICATIONS / 測試規範

Calibration check

DATE OF TEST / 測試日期 : 19 November 2021

TEST RESULTS / 測試結果

The results apply to the particular unit-under-test only. The results do not exceed manufacturer's specification. The results are detailed in the subsequent page(s).

The test equipment used for calibration are traceable to National Standards via :

- The Government of The Hong Kong Special Administrative Region Standard & Calibration Laboratory
- Agilent Technologies / Keysight Technologies

:

- Fluke Everett Service Center, USA

Tested By 測試

K P Cheuk

Project Engineer

K C Lee Engineer

Certified By 核證 Date of Issue 簽發日期 :

24 November 2021

The test equipment used for calibration is traceable to the National Standards as specified in this certificate. This certificate shall not be reproduced except in full, without the prior written approval of this laboratory.

本證書所載校正用之測試器材均可溯源至國際標準。局部複印本證書需先獲本實驗所書面批准。

Sun Creation Engineering Limited – Calibration & Testing Laboratory c/o 4/F, 1 Hing On Lane, Tuen Mun, New Territories, Hong Kong 輝創工程有限公司 - 校正及檢測實驗所 c/o 香港新界屯門興安里一號四樓 Tel/電話: (852) 2927 2606 Fax/傳真: (852) 2744 8986 E-mail/電郵: callab@suncreation.com Website/網址: www.suncreation.com



Sun Creation Engineering Limited

Calibration & Testing Laboratory

Certificate of Calibration 校正證書

Certificate No. : C216692 證書編號

- 1. The unit-under-test (UUT) was allowed to stabilize in the laboratory for over 12 hours, and switched on to warm up for over 10 minutes before the commencement of the test.
- 2. Self-calibration using laboratory acoustic calibrator was performed before the test from 6.1.1.2 to 6.4.
- 3. The results presented are the mean of 3 measurements at each calibration point.
- 4. Test equipment :

Equipment ID	Description	Certificate No.
CL280	40 MHz Arbitrary Waveform Generator	C210084
CL281	Multifunction Acoustic Calibrator	AV210017

- 5. Test procedure : MA101N.
- 6. Results :
- 6.1 Sound Pressure Level
- 6.1.1 Reference Sound Pressure Level
- 6.1.1.1 Before Self-calibration

,	UUT S	Setting	Applied	Value	UUT	
Range	Parameter	Frequency	Time	Level	Freq.	Reading
(dB)		Weighting	Weighting	(dB)	(kHz)	(dB)
50 - 130	50 - 130 L _{AFP} A F				1	94.3

6.1.1.2 After Self-calibration

		Applied Value		UUT	IEC 60651		
Range	Parameter	Frequency	Time	Level	Freq.	Reading	Type 1 Spec.
(dB)		Weighting	Weighting	(dB)	(kHz)	(dB)	(dB)
50 - 130	L _{AFP}	A	F	94.00	1	94.0	± 0.7

6.1.2 Linearity

	UU′	Γ Setting	Applie	d Value	UUT	
Range	Parameter	Frequency Time		Level	Freq.	Reading
(dB)		Weighting	Weighting	(dB)	(kHz)	(dB)
50 - 130	L _{AFP}	А	F	94.00	1	94.0 (Ref.)
				104.00		104.0
				114.00		114.0

IEC 60651 Type 1 Spec. : \pm 0.4 dB per 10 dB step and \pm 0.7 dB for overall different.

本證書所載校正用之測試器材均可溯源至國際標準。局部複印本證書需先獲本實驗所書面批准。

The test equipment used for calibration is traceable to the National Standards as specified in this certificate. This certificate shall not be reproduced except in full, without the prior written approval of this laboratory.



Sun Creation Engineering Limited

Calibration & Testing Laboratory

Certificate of Calibration 校正證書

Certificate No. : C216692 證書編號

6.2 Time Weighting

6.2.1 **Continuous Signal**

		Applied Value		UUT	IEC 60651		
Range	Parameter	Frequency	quency Time		Freq.	Reading	Type 1 Spec.
(dB)		Weighting	Weighting	(dB)	(kHz)	(dB)	(dB)
50 - 130	L _{AFP}	А	F	94.00	1	94.0	Ref.
	L _{ASP}		S			94.0	± 0.1
	L _{AIP}		Ι			94.1	± 0.1

6.2.2 Tone Burst Signal (2 kHz)

UUT Setting				Applied Value		UUT	IEC 60651
Range	Parameter	Frequency	Time	Level	Level Burst		Type 1 Spec.
(dB)		Weighting	Weighting	(dB)	Duration	(dB)	(dB)
30 - 110	L _{AFP}	А	F	106.0	Continuous	106.0	Ref.
	L _{AFMax}				200 ms	105.0	-1.0 ± 1.0
	L _{ASP}		S		Continuous	106.0	Ref.
	L _{ASMax}				500 ms	102.0	-4.1 ± 1.0

6.3 Frequency Weighting

6.3.1 A-Weighting

UUT Setting		Applied Value		UUT	IEC 60651		
Range	Parameter	Frequency	Time	Level	Freq.	Reading	Type 1 Spec.
(dB)		Weighting	Weighting	(dB)		(dB)	(dB)
50 - 130	L_{AFP}	А	F	94.00	31.5 Hz	55.1	-39.4 ± 1.5
					63 Hz	68.0	-26.2 ± 1.5
					125 Hz	77.9	-16.1 ± 1.0
					250 Hz	85.3	$\textbf{-8.6} \pm 1.0$
					500 Hz	90.8	-3.2 ± 1.0
					1 kHz	94.0	Ref.
					2 kHz	95.2	$+1.2 \pm 1.0$
					4 kHz	95.0	$+1.0 \pm 1.0$
					8 kHz	92.9	-1.1 (+1.5 ; -3.0)
					12.5 kHz	89.8	-4.3 (+3.0 ; -6.0)

The test equipment used for calibration is traceable to the National Standards as specified in this certificate. This certificate shall not be reproduced except in full, without the prior written approval of this laboratory. 本證書所載校正用之測試器材均可溯源至國際標準。局部複印本證書需先獲本實驗所書面批准。



Sun Creation Engineering Limited

Calibration & Testing Laboratory

Certificate of Calibration 校正證書

Certificate No. : C216692 證書編號

6.3.2 C-Weighting

UUT Setting				Applied Value		UUT	IEC 60651	
Range	Parameter	Frequency	Time	Level	Freq.	Reading	Type 1 Spec.	
(dB)		Weighting	Weighting	(dB)	_	(dB)	(dB)	
50 - 130	L _{CFP}	С	F	94.00	31.5 Hz	91.4	-3.0 ± 1.5	
					63 Hz	93.3	-0.8 ± 1.5	
					125 Hz	93.9	-0.2 ± 1.0	
					250 Hz	94.0	0.0 ± 1.0	
					500 Hz	94.0	0.0 ± 1.0	
					1 kHz	94.0	Ref.	
					2 kHz	93.8	-0.2 ± 1.0	
					4 kHz	93.2	$\textbf{-0.8} \pm 1.0$	
					8 kHz	91.0	-3.0 (+1.5 ; -3.0)	
					12.5 kHz	87.9	-6.2 (+3.0 ; -6.0)	

6.4

Time Averaging								
	UUT	Setting						
Range	Parameter	Frequency	Integrating	Frequency				
(dB)		Waighting	Time	(1/11-7)				

UUT Setting			Applied Value					UUT	IEC 60804	
Range	Parameter	Frequency	Integrating	Frequency	Burst	Burst	Burst	Equivalent	Reading	Type 1
(dB)		Weighting	Time	(kHz)	Duration	Duty	Level	Level	(dB)	Spec.
					(ms)	Factor	(dB)	(dB)		(dB)
30 - 110	L _{Aeq}	А	10 sec.	4	1	1/10	110.0	100	99.9	± 0.5
						$1/10^{2}$		90	89.5	± 0.5
			60 sec.			1/10 ³		80	79.1	± 1.0
			5 min.			1/104		70	69.2	± 1.0

Remarks : - UUT Microphone Model No. : 4188 & S/N : 2250447

- Mfr's Spec. : IEC 60651 Type 1 & IEC 60804 Type 1

Uncertainties of Applied Value :	94 dB : 31.5 Hz - 125 Hz	$\pm 0.35 \text{ dB}$
	250 Hz - 500 Hz	$\pm 0.30 \text{ dB}$
	1 kHz	$\pm 0.20 \text{ dB}$
	2 kHz - 4 kHz	$\pm 0.35 \text{ dB}$
	8 kHz	$\pm 0.45 \text{ dB}$
	12.5 kHz	$\pm 0.70 \text{ dB}$
	104 dB : 1 kHz	$\pm 0.10 \text{ dB}$ (Ref. 94 dB)
	114 dB : 1 kHz	$\pm 0.10 \text{ dB}$ (Ref. 94 dB)
	Burst equivalent level	$\pm 0.2 \text{ dB}$ (Ref. 110 dB)
		continuous sound level)

- The uncertainties are for a confidence probability of not less than 95 %.

Note :

Only the original copy or the laboratory's certified true copy is valid.

The values given in this Certificate only relate to the values measured at the time of the test and any uncertainties quoted will not include allowance for the equipment long term drift, variations with environment changes, vibration and shock during transportation, overloading, mis-handling, or the capability of any other laboratory to repeat the measurement. Sun Creation Engineering Limited shall not be liable for any loss or damage resulting from the use of the equipment.

本證書所載校正用之測試器材均可溯源至國際標準。局部複印本證書需先獲本實驗所書面批准。

The test equipment used for calibration is traceable to the National Standards as specified in this certificate. This certificate shall not be reproduced except in full, without the prior written approval of this laboratory

ALS Technichem (HK) Pty Ltd

ALS Laboratory Group

ANALYTICAL CHEMISTRY & TESTING SERVICES





	LIK2444245
WORK ORDER	- NK211134 5
SUB-BATCH	: 1
DATE RECEIVED	: 17-MAR-2021
DATE OF ISSUE	: 16-APR-2021
NO. OF SAMPLES	: 1
CLIENT ORDER	÷
	WORK ORDER SUB-BATCH DATE RECEIVED DATE OF ISSUE NO. OF SAMPLES CLIENT ORDER

General Comments

- Samples(s) was/ were submitted by client. Sample(s) arrived laboratory in ambient condition. The result(s) related only to the item(s) tested.
- Sample information (Project name, Sample ID, Sampling date/time, etc.) is provided by client.
- Calibration was subcontracted to and analysed by Action United Environmental Services & Consulting.

Signatories

This document has been signed by those names that appear on this report and are the authorised signatories

Signatories	Position
Kichard Jong.	
Richard Fung	Managing Director

This is the Final Report and supersedes any preliminary report with this batch number.

All pages of this report have been checked and approved for release.

ALS Technichem (HK) Pty Ltd Part of the ALS Laboratory Group

11/F. Chung Shun Knitting Centre 1 - 3 Wing Yip Street Kwai Chung N.T. Hong Kong Tel. +852 2610 1044 Fax. +852 2610 2021 www.alsglobal.com WORK ORDER SUB-BATCH

CLIENT PROJECT : HK2111345

: 1 : ACTION UNITED ENVIRONMENT SERVICES AND CONSULTING



 ALS Lab
 Client's Sample ID
 Sample
 Sample Date
 External Lab Report No.

 ID
 Type
 ID
 ID</t

Equipment Verification Report (TSP)

Equipment Calibrated:

Туре:	Laser Dust monitor
Manufacturer:	Sibata LD-3B
Serial No.	456662
Equipment Ref:	EQ118
Job Order	HK2111345

Standard Equipment:

Standard Equipment:	Higher Volume Sampler
Location & Location ID:	AUES office (calibration room)
Equipment Ref:	HVS 018
Last Calibration Date:	13 January 2021

Equipment Verification Results:

Verification Date:

12 March 2021

Hour	Time	Mean Temp °C	Mean Pressure (hPa)	Concentration in mg/m ³ (Standard Equipment)	Total Count (Calibrated Equipment)	Count/Minute (Total Count/60min)
2hr01min	09:30 ~ 11:31	22.0	1018.6	0.023	1758	14.5
2hr01min	11:35 ~ 11:36	22.0	1018.6	0.044	2411	19.9
2hr	11:40 ~ 13:40	22.0	1018.6	0.039	1946	16.2

591

591

0.05

0.045 0.04

0.035

0.03 0.025

0.02

0.015 0.01 0.005

0

0

5

10

(CPM)

(CPM)

4

15

γ = 0.0022x - 0.0012 R² = 0.9264

20

25

Sensitivity Adjustment Scale Setting (Before Calibration) Sensitivity Adjustment Scale Setting (After Calibration)



Slope (K-factor):	0.0022
Correlation Coefficient (R)	0.9625
Date of Issue	15 March 2021

Remarks:

1. **Strong** Correlation (R>0.8)

2. Factor 0.0022 should be apply for TSP monitoring

*If R<0.5, repair or re-verification is required for the equipment



Location ID : Calibration Room	ai Chung	Date of Calibration: 13-Jan-21 Next Calibration Date: 13-Apr-21
C	ONDITIONS	
Sea Level Pressure (hPa) 101 Temperature (°C) 1	<u>19.8</u> 13.4	Corrected Pressure (mm Hg)764.85Temperature (K)286
CALIBF	RATION ORIFICE	
Make-> TISC Model-> 5025 Calibration Date-> 7-Feb-	<u>CH</u> A -20	Qstd Slope ->2.03014Qstd Intercept ->-0.04616Expiry Date->7-Feb-21
CA	ALIBRATION	
Plate H20 (L)H2O (R) H20 Qstd I No. (in) (in) (in) (m3/min) (char	IC corrected	LINEAR REGRESSION
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	56.28 50.14 42.98 32.75 22.51	Slope = 39.9777 Intercept = -15.3902 Corr. coeff. = 0.9972
Calculations : Qstd = 1/m[Sqrt(H20(Pa/Pstd)(Tstd/Ta))-b] IC = I[Sqrt(Pa/Pstd)(Tstd/Ta)] Qstd = standard flow rate IC = corrected chart respones I = actual chart response m = calibrator Qstd slope b = calibrator Qstd intercept Ta = actual temperature during calibration (deg K) Pstd = actual pressure during calibration (mm Hg) For subsequent calculation of sampler flow: 1/m((I)[Sqrt(298/Tav)(Pav/760)]-b) m = sampler slope b = sampler intercept I = chart response	60.00 50.00 50.00 40.00 30.00 20.00 10.00 0.000	FLOW RATE CHART

Enviro		e n t	a I		Cal	ibra	RECA Di Febru	ALIBRATION UE DATE: Jary 7, 2021
			Calibration	Certificatio	on Informat	ion		
Cal. Date:	February 7,	2020	Rootsi	neter S/N:	438320	Ta:	295	°К
Operator:	Jim Tisch					Pa:	745.5	mm Hg
Calibration I	Model #:	TE-5025A	Calik	orator S/N:	1612			
L	Т							
		Vol. Init	Vol. Final	ΔVol.	ΔTime	ΔΡ	ΔΗ	
	Run	(m3)	(m3)	(m3)	(min)	(mm Hg)	(in H2O)	
	1	1	2	1	1.3730	3.2	2.00	
	2	3	4	1	0.9820	6.4	4.00	
	3	5	6	1	0.8780	8.0	5.00	
	4	7	8	1	0.8340	8.8	5.50	
l	2	9	101	1	0.6900	12.8	8.00	
			C	ata Tabula	ation			
	Vstd	Ostd	$\sqrt{\Delta H \left(\frac{Pa}{Pstd}\right)}$)(<u>Tstd</u>)		02	√∆H(Ta/Pa)	
	(m3)	(x-axis)	(v-ax	is)	Va	(x-axis)	(v-axis)	
	0.9866	0.7186	1.407	78	0.9957	0.7252	0.8896	
	0.9824	1.0004	1.990)9	0.9914	1.0096	1.2581	
	0.9802	1.1165	2.225	59	0.9893	1.1267	1.4066	
	0.9792	1.1741	2.334	15	0.9882	1.1849	1.4753	
	0.9739	1.4114	2.815	55	0.9828	1.4244	1.7792	
	OCTO		2.030	14		m=	1.27124	
	QSID	b=	-0.046	516	QA	b=	-0.02917	
l		r=	0.999	95		r=	0.99995	
				Calculatio	ns			
	Vstd=	$\Delta Vol((Pa-\Delta P))$	/Pstd)(Tstd/Ta	a)	Va=	ΔVol((Pa-ΔF	P)/Pa)	
	Qstd=	Vstd/∆Time			Qa= Va/ΔTime			
			For subsequ	ent flow ra	te calculatio	ns:		
	$\mathbf{Qstd=1/m}\left(\!\!\left(\sqrt{\Delta H\left(\frac{Pa}{Pstd}\right)\!\!\left(\frac{Tstd}{Ta}\right)}\right)\!\!\cdot\!\!b\right) \qquad \mathbf{Qa=1/m}\left(\!\!\left(\sqrt{\Delta H\left(Ta/Pa\right)}\right)\!\!\cdot\!\!b\right)$							
	Standard	Conditions						-
Tstd:	298.15	°K		[RECA	LIBRATION	
Pstd:	760	mm Hg			LIS EDA room	mmonde	anual recalibration	on nor 1000
All calibrate	r manomet	er reading /:	n H20)		AD Code	of Federal E		50 to 51
ΔP: rootsme	ter manomet	eter reading (I	(mm Hg)		Annendiv	B to Part 50	Reference Meth	and for the
Ta: actual ab	solute tem	perature (°K)			Determinat	tion of Susp	ended Particulat	e Matter in
Pa: actual ba	rometric pr	essure (mm	Hg)		the Atmosphere 9.2.17 page 30			
b: intercept							, o, page	
Im: slone			1					

Tisch Environmental, Inc. 145 South Miami Avenue Village of Cleves, OH 45002 <u>www.tisch-env.com</u> TOLL FREE: (877)263-7610 FAX: (513)467-9009

ALS Technichem (HK) Pty Ltd

ALS Laboratory Group

ANALYTICAL CHEMISTRY & TESTING SERVICES





CONTACT	: MR BEN TAM	WORK ORDER HK2111344					
CLIENT	ACTION UNITED ENVIRONMENT						
	SERVICES AND CONSULTING						
ADDRESS	: RM A 20/F., GOLD KING IND BLDG, NO. 35-41	SUB-BATCH : 1					
	TAI LIN PAI ROAD, KWAI CHUNG, N.T. HONG	DATE RECEIVED : 17-MAR-2021					
	KONG	DATE OF ISSUE : 16-APR-2021					
PROJECT	:	NO. OF SAMPLES : 1					
		CLIENT ORDER					

General Comments

- Samples(s) was/ were submitted by client. Sample(s) arrived laboratory in ambient condition. The result(s) related only to the item(s) tested.
- Sample information (Project name, Sample ID, Sampling date/time, etc.) is provided by client.
- Calibration was subcontracted to and analysed by Action United Environmental Services & Consulting.

Signatories

This document has been signed by those names that appear on this report and are the authorised signatories

Signatories	Position
Kichard Jong.	
Richard Fung	Managing Director

This is the Final Report and supersedes any preliminary report with this batch number.

All pages of this report have been checked and approved for release.

ALS Technichem (HK) Pty Ltd Part of the ALS Laboratory Group

11/F. Chung Shun Knitting Centre 1 - 3 Wing Yip Street Kwai Chung N.T. Hong Kong Tel. +852 2610 1044 Fax. +852 2610 2021 www.alsglobal.com WORK ORDER SUB-BATCH

CLIENT PROJECT : HK2111344

: 1 : ACTION UNITED ENVIRONMENT SERVICES AND CONSULTING



 ALS Lab
 Client's Sample ID
 Sample
 Sample Date
 External Lab Report No.

 ID
 Type
 ID
 ID</t

Equipment Verification Report (TSP)

Equipment Calibrated:

Туре:	Laser Dust monitor
Manufacturer:	Sibata LD-3B
Serial No.	456660
Equipment Ref:	EQ117
Job Order	HK2111344

Standard Equipment:

Standard Equipment:	Higher Volume Sampler
Location & Location ID:	AUES office (calibration room)
Equipment Ref:	HVS 018
Last Calibration Date:	13 January 2021

Equipment Verification Results:

Verification Date:

12 March 2021

Hour	Time	Mean Temp °C	Mean Pressure (hPa)	Concentration in mg/m ³ (Standard Equipment)	Total Count (Calibrated Equipment)	Count/Minute (Total Count/60min)
2hr01min	09:30 ~ 11:31	22.0	1018.6	0.023	1732	14.3
2hr01min	11:35 ~ 11:36	22.0	1018.6	0.044	2308	19.0
2hr	11:40 ~ 13:40	22.0	1018.6	0.039	1957	16.3

Sensitivity Adjustment Scale Setting (Before Calibration) Sensitivity Adjustment Scale Setting (After Calibration)



٠

15

y = 0.0022x - 0.0014

 $R^2 = 0.9275$

20

0.05 0.045

0.04 0.035

0.03 0.025

0.02

0.015

0.01

0.005 -0 <

0

5

10

Linear Regression of Y or X

Slope (K-factor):	0.0022
Correlation Coefficient (R)	0.9631
Date of Issue	15 March 2021

Remarks:

1. **Strong** Correlation (R>0.8)

2. Factor 0.0022 should be apply for TSP monitoring

*If R<0.5, repair or re-verification is required for the equipment



Location ID : Calibration Room	Date of Calibration: 13-Jan-21 Next Calibration Date: 13-Apr-21	
C	ONDITIONS	
Sea Level Pressure (hPa) 101 Temperature (°C) 1	<u>19.8</u> 13.4	Corrected Pressure (mm Hg)764.85Temperature (K)286
CALIBF	RATION ORIFICE	
Make-> TISC Model-> 5025 Calibration Date-> 7-Feb-	<u>CH</u> A -20	Qstd Slope ->2.03014Qstd Intercept ->-0.04616Expiry Date->7-Feb-21
CA	ALIBRATION	
Plate H20 (L)H2O (R) H20 Qstd I No. (in) (in) (in) (m3/min) (char	IC corrected	LINEAR REGRESSION
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	56.28 50.14 42.98 32.75 22.51	Slope = 39.9777 Intercept = -15.3902 Corr. coeff. = 0.9972
Calculations : Qstd = 1/m[Sqrt(H20(Pa/Pstd)(Tstd/Ta))-b] IC = I[Sqrt(Pa/Pstd)(Tstd/Ta)] Qstd = standard flow rate IC = corrected chart respones I = actual chart response m = calibrator Qstd slope b = calibrator Qstd intercept Ta = actual temperature during calibration (deg K) Pstd = actual pressure during calibration (mm Hg) For subsequent calculation of sampler flow: 1/m((I)[Sqrt(298/Tav)(Pav/760)]-b) m = sampler slope b = sampler intercept I = chart response	60.00 50.00 50.00 40.00 30.00 20.00 10.00 0.000	FLOW RATE CHART

Enviro		e n t	a I		Cal	ibra	RECA Di Febru	ALIBRATION UE DATE: Jary 7, 2021
			Calibration	Certificatio	on Informat	ion		
Cal. Date:	February 7,	2020	Rootsi	neter S/N:	438320	Ta:	295	°К
Operator:	Jim Tisch					Pa:	745.5	mm Hg
Calibration I	Model #:	TE-5025A	Calik	orator S/N:	1612			
L	Т							
		Vol. Init	Vol. Final	ΔVol.	ΔTime	ΔΡ	ΔΗ	
	Run	(m3)	(m3)	(m3)	(min)	(mm Hg)	(in H2O)	
	1	1	2	1	1.3730	3.2	2.00	
	2	3	4	1	0.9820	6.4	4.00	
	3	5	6	1	0.8780	8.0	5.00	
	4	7	8	1	0.8340	8.8	5.50	
l	2	9	101	1	0.6900	12.8	8.00	
			C	ata Tabula	ation			
	Vstd	Ostd	$\sqrt{\Delta H \left(\frac{Pa}{Pstd}\right)}$)(<u>Tstd</u>)		02	√∆H(Ta/Pa)	
	(m3)	(x-axis)	(v-ax	is)	Va	(x-axis)	(v-axis)	
	0.9866	0.7186	1.407	78	0.9957	0.7252	0.8896	
	0.9824	1.0004	1.990)9	0.9914	1.0096	1.2581	
	0.9802	1.1165	2.225	59	0.9893	1.1267	1.4066	
	0.9792	1.1741	2.334	15	0.9882	1.1849	1.4753	
	0.9739	1.4114	2.815	55	0.9828	1.4244	1.7792	
	OCTO		2.030	14		m=	1.27124	
	QSID	b=	-0.046	516	QA	b=	-0.02917	
l		r=	0.999	95		r=	0.99995	
				Calculatio	ns			
	Vstd=	$\Delta Vol((Pa-\Delta P))$	/Pstd)(Tstd/Ta	a)	Va=	ΔVol((Pa-ΔF	P)/Pa)	
	Qstd=	Vstd/∆Time			Qa= Va/ΔTime			
			For subsequ	ent flow ra	te calculatio	ns:		
	$\mathbf{Qstd=1/m}\left(\!\!\left(\sqrt{\Delta H\left(\frac{Pa}{Pstd}\right)\!\!\left(\frac{Tstd}{Ta}\right)}\right)\!\!\cdot\!\!b\right) \qquad \mathbf{Qa=1/m}\left(\!\!\left(\sqrt{\Delta H\left(Ta/Pa\right)}\right)\!\!\cdot\!\!b\right)$							
	Standard	Conditions						-
Tstd:	298.15	°K		[RECA	LIBRATION	
Pstd:	760	mm Hg				mmonde	anual recalibration	on nor 1000
All calibrate	r manomet	er reading /:	n H20)		AD Code	of Federal E		50 to 51
ΔP: rootsme	ter manomet	eter reading (I	(mm Hg)		Annendiv	B to Part 50	Reference Meth	and for the
Ta: actual ab	solute tem	perature (°K)			Determinat	tion of Susp	ended Particulat	e Matter in
Pa: actual ba	rometric pr	essure (mm	Hg)		the Atmosphere 9.2.17 page 30			
b: intercept							, o, page	
Im: slone			1					

Tisch Environmental, Inc. 145 South Miami Avenue Village of Cleves, OH 45002 <u>www.tisch-env.com</u> TOLL FREE: (877)263-7610 FAX: (513)467-9009

ALS Technichem (HK) Pty Ltd

ALS Laboratory Group

ANALYTICAL CHEMISTRY & TESTING SERVICES





CONTACT	: MR BEN TAM	WORK ORDER HK2111343				
CLIENT	ACTION UNITED ENVIRONMENT					
	SERVICES AND CONSULTING					
ADDRESS	: RM A 20/F., GOLD KING IND BLDG, NO. 35-41	SUB-BATCH : 1				
	TAI LIN PAI ROAD, KWAI CHUNG, N.T. HONG	DATE RECEIVED : 17-MAR-2021				
	KONG	DATE OF ISSUE : 16-APR-2021				
PROJECT	:	NO. OF SAMPLES : 1				
		CLIENT ORDER				

General Comments

- Samples(s) was/ were submitted by client. Sample(s) arrived laboratory in ambient condition. The result(s) related only to the item(s) tested.
- Sample information (Project name, Sample ID, Sampling date/time, etc.) is provided by client.
- Calibration was subcontracted to and analysed by Action United Environmental Services & Consulting.

Signatories

This document has been signed by those names that appear on this report and are the authorised signatories

Signatories	Position
Kichard Jong.	
Richard Fung	Managing Director

This is the Final Report and supersedes any preliminary report with this batch number.

All pages of this report have been checked and approved for release.

ALS Technichem (HK) Pty Ltd Part of the ALS Laboratory Group

11/F. Chung Shun Knitting Centre 1 - 3 Wing Yip Street Kwai Chung N.T. Hong Kong Tel. +852 2610 1044 Fax. +852 2610 2021 www.alsglobal.com WORK ORDER SUB-BATCH : HK2111343

:

: 1 : ACTION UNITED ENVIRONMENT SERVICES AND CONSULTING



CLIENT PROJECT

ALS Lab ID	Client's Sample ID	Sample Type	Sample Date	External Lab Report No.
HK2111343-001	S/N: 456659	AIR	17-Mar-2021	S/N: 456659

Equipment Verification Report (TSP)

Equipment Calibrated:

Туре:	Laser Dust monitor
Manufacturer:	Sibata LD-3B
Serial No.	456659
Equipment Ref:	EQ116
Job Order	HK2111343

Standard Equipment:

Standard Equipment:	Higher Volume Sampler
Location & Location ID:	AUES office (calibration room)
Equipment Ref:	HVS 018
Last Calibration Date:	13 January 2021

Equipment Verification Results:

Verification Date:

12 March 2021

Hour	Time	Mean Temp °C	Mean Pressure (hPa)	Concentration in mg/m ³ (Standard Equipment)	Total Count (Calibrated Equipment)	Count/Minute (Total Count/60min)
2hr01min	09:30 ~ 11:31	22.0	1018.6	0.023	1477	12.2
2hr01min	11:35 ~ 11:36	22.0	1018.6	0.044	2559	21.1
2hr	11:40 ~ 13:40	22.0	1018.6	0.039	1987	16.6

Sensitivity Adjustment Scale Setting (Before Calibration) Sensitivity Adjustment Scale Setting (After Calibration)



0.05 0.045 0.04 0.035 0.03 0.025 ٠ 0.02 y = 0.0022x - 0.0005 0.015 $R^2 = 0.9784$ 0.01 0.005 0 5 10 15 20 0 25

Linear Regression of Y or X

Slope (K-factor):	0.0022
Correlation Coefficient (R)	0.9891
Date of Issue	15 March 2021

Remarks:

1. **Strong** Correlation (R>0.8)

2. Factor 0.0022 should be apply for TSP monitoring

*If R<0.5, repair or re-verification is required for the equipment



Location ID : Calibration Room	Date of Calibration: 13-Jan-21 Next Calibration Date: 13-Apr-21	
C	ONDITIONS	
Sea Level Pressure (hPa) 101 Temperature (°C) 1	<u>19.8</u> 13.4	Corrected Pressure (mm Hg)764.85Temperature (K)286
CALIBF	RATION ORIFICE	
Make-> TISC Model-> 5025 Calibration Date-> 7-Feb-	<u>CH</u> A -20	Qstd Slope ->2.03014Qstd Intercept ->-0.04616Expiry Date->7-Feb-21
CA	ALIBRATION	
Plate H20 (L)H2O (R) H20 Qstd I No. (in) (in) (in) (m3/min) (char	IC corrected	LINEAR REGRESSION
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	56.28 50.14 42.98 32.75 22.51	Slope = 39.9777 Intercept = -15.3902 Corr. coeff. = 0.9972
Calculations : Qstd = 1/m[Sqrt(H20(Pa/Pstd)(Tstd/Ta))-b] IC = I[Sqrt(Pa/Pstd)(Tstd/Ta)] Qstd = standard flow rate IC = corrected chart respones I = actual chart response m = calibrator Qstd slope b = calibrator Qstd intercept Ta = actual temperature during calibration (deg K) Pstd = actual pressure during calibration (mm Hg) For subsequent calculation of sampler flow: 1/m((I)[Sqrt(298/Tav)(Pav/760)]-b) m = sampler slope b = sampler intercept I = chart response	60.00 50.00 50.00 40.00 30.00 20.00 10.00 0.000	FLOW RATE CHART

Enviro		e n t	a I		Cal	ibra	RECA Di Febru	ALIBRATION UE DATE: Jary 7, 2021
			Calibration	Certificatio	on Informat	ion		
Cal. Date:	February 7,	2020	Rootsi	neter S/N:	438320	Ta:	295	°К
Operator:	Jim Tisch					Pa:	745.5	mm Hg
Calibration I	Model #:	TE-5025A	Calik	orator S/N:	1612			
L	Т							
		Vol. Init	Vol. Final	ΔVol.	ΔTime	ΔΡ	ΔΗ	
	Run	(m3)	(m3)	(m3)	(min)	(mm Hg)	(in H2O)	
	1	1	2	1	1.3730	3.2	2.00	
	2	3	4	1	0.9820	6.4	4.00	
	3	5	6	1	0.8780	8.0	5.00	
	4	7	8	1	0.8340	8.8	5.50	
l	2	9	101	1	0.6900	12.8	8.00	
			C	ata Tabula	tion			
	Vstd	Ostd	$\sqrt{\Delta H \left(\frac{Pa}{Pstd}\right)}$)(<u>Tstd</u>)		02	√∆H(Ta/Pa)	
	(m3)	(x-axis)	(v-ax	is)	Va	(x-axis)	(v-axis)	
	0.9866	0.7186	1.407	78	0.9957	0.7252	0.8896	
	0.9824	1.0004	1.990)9	0.9914	1.0096	1.2581	
	0.9802	1.1165	2.225	59	0.9893	1.1267	1.4066	
	0.9792	1.1741	2.334	15	0.9882	1.1849	1.4753	
	0.9739	1.4114	2.815	55	0.9828	1.4244	1.7792	
	OCTO		2.030	14		m=	1.27124	
	QSID	b=	-0.046	516	QA	b=	-0.02917	
l		r=	0.999	95		r=	0.99995	
				Calculatio	ns			
	Vstd=	$\Delta Vol((Pa-\Delta P))$	/Pstd)(Tstd/Ta	a)	Va=	ΔVol((Pa-ΔF	P)/Pa)	
	Qstd=	Vstd/∆Time			Qa=	Va/∆Time		
			For subsequ	ent flow ra	te calculatio	ns:		
	$\mathbf{Qstd} = 1/m\left(\left(\sqrt{\Delta H\left(\frac{Pa}{Pstd}\right)\left(\frac{Tstd}{Ta}\right)}\right) - b\right) \qquad \qquad \mathbf{Qa} = 1/m\left(\left(\sqrt{\Delta H\left(Ta/Pa\right)}\right) - b\right)$							
	Standard	Conditions						-
Tstd:	298.15	°K		[RECA	LIBRATION	
Pstd:	760	mm Hg				mmonde	anual recalibration	on nor 1000
All calibrate	r manomet	er reading /:	n H20)		AD Code	of Federal F		50 to 51
ΔP: rootsme	ter manomet	eter reading (I	(mm Hg)		Annendiv	B to Part 50	Reference Meth	and for the
Ta: actual ab	Ta: actual absolute temperature (°K)						ended Particulat	e Matter in
Pa: actual ba	rometric pr	essure (mm	Hg)		th	e Atmosnhe	re 9,2,17 nage	30
b: intercept							, o, page	
Im: slone			1					

Tisch Environmental, Inc. 145 South Miami Avenue Village of Cleves, OH 45002 <u>www.tisch-env.com</u> TOLL FREE: (877)263-7610 FAX: (513)467-9009

ALS Technichem (HK) Pty Ltd

ALS Laboratory Group

ANALYTICAL CHEMISTRY & TESTING SERVICES





WORK ORDER HK2111342						
SUB-BATCH : 1						
DATE RECEIVED : 17-MAR-2021						
DATE OF ISSUE : 16-APR-2021						
NO. OF SAMPLES : 1						
CLIENT ORDER						

General Comments

- Samples(s) was/ were submitted by client. Sample(s) arrived laboratory in ambient condition. The result(s) related only to the item(s) tested.
- Sample information (Project name, Sample ID, Sampling date/time, etc.) is provided by client.
- Calibration was subcontracted to and analysed by Action United Environmental Services & Consulting.

Signatories

This document has been signed by those names that appear on this report and are the authorised signatories

Signatories	Position
Kichard Jong.	
Richard Fung	Managing Director

This is the Final Report and supersedes any preliminary report with this batch number.

All pages of this report have been checked and approved for release.

ALS Technichem (HK) Pty Ltd Part of the ALS Laboratory Group

11/F. Chung Shun Knitting Centre 1 - 3 Wing Yip Street Kwai Chung N.T. Hong Kong Tel. +852 2610 1044 Fax. +852 2610 2021 www.alsglobal.com WORK ORDER SUB-BATCH

CLIENT PROJECT : HK2111342

: 1 : ACTION UNITED ENVIRONMENT SERVICES AND CONSULTING



 ALS Lab
 Client's Sample ID
 Sample
 Sample Date
 External Lab Report No.

 ID
 Type
 ID
 ID</t

Equipment Verification Report (TSP)

Equipment Calibrated:

Туре:	Laser Dust monitor
Manufacturer:	Sibata LD-3B
Serial No.	456658
Equipment Ref:	EQ115
Job Order	HK2111342

Standard Equipment:

Standard Equipment:	Higher Volume Sampler
Location & Location ID:	AUES office (calibration room)
Equipment Ref:	HVS 018
Last Calibration Date:	13 January 2021

Equipment Verification Results:

Verification Date:

12 March 2021

Hour	Time	Mean Temp °C	Mean Pressure (hPa)	Concentration in mg/m ³ (Standard Equipment)	Total Count (Calibrated Equipment)	Count/Minute (Total Count/60min)
2hr01min	09:30 ~ 11:31	22.0	1018.6	0.023	1711	14.1
2hr01min	11:35 ~ 11:36	22.0	1018.6	0.044	2311	19.1
2hr	11:40 ~ 13:40	22.0	1018.6	0.039	2001	16.7

Sensitivity Adjustment Scale Setting (Before Calibration) Sensitivity Adjustment Scale Setting (After Calibration)





Linear Regression of Y or X

0.0022
0.9683
15 March 2021

Remarks:

1. **Strong** Correlation (R>0.8)

2. Factor 0.0022 should be apply for TSP monitoring

*If R<0.5, repair or re-verification is required for the equipment



Location ID : Calibration Room	ai Chung	Date of Calibration: 13-Jan-21 Next Calibration Date: 13-Apr-21		
C	ONDITIONS			
Sea Level Pressure (hPa) 101 Temperature (°C) 1	19.8 13.4	Corrected Pressure (mm Hg)764.85Temperature (K)286		
CALIBF	RATION ORIFICE			
Make-> TISC Model-> 5025. Calibration Date-> 7-Feb-	CH 5A -20	Qstd Slope ->2.03014Qstd Intercept ->-0.04616Expiry Date->7-Feb-21		
CA	ALIBRATION			
Plate H20 (L)H2O (R) H20 Qstd I No. (in) (in) (in) (m3/min) (char	IC corrected	LINEAR REGRESSION		
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	56.28 50.14 42.98 32.75 22.51	Slope = 39.9777 Intercept = -15.3902 Corr. coeff. = 0.9972		
Calculations : Qstd = 1/m[Sqrt(H20(Pa/Pstd)(Tstd/Ta))-b] IC = I[Sqrt(Pa/Pstd)(Tstd/Ta)] Qstd = standard flow rate IC = corrected chart respones I = actual chart response m = calibrator Qstd slope b = calibrator Qstd intercept Ta = actual temperature during calibration (deg K) Pstd = actual pressure during calibration (mm Hg) For subsequent calculation of sampler flow: 1/m((I)[Sqrt(298/Tav)(Pav/760)]-b) m = sampler slope b = sampler intercept I = chart response	60.00 50.00 40.00 0.00 0.00 0.000	FLOW RATE CHART		

Enviro		e n t	a I		Cal	ibra	RECA Di Febru	ALIBRATION UE DATE: Jary 7, 2021
			Calibration	Certificatio	on Informat	ion		
Cal. Date:	February 7,	2020	Rootsi	neter S/N:	438320	Ta:	295	°К
Operator:	Jim Tisch				Pa: 745.5		745.5	mm Hg
Calibration I	Model #:	TE-5025A	Calik	orator S/N:	1612			
L	Т							
		Vol. Init	Vol. Final	ΔVol.	ΔTime	ΔΡ	ΔΗ	
	Run	(m3)	(m3)	(m3)	(min)	(mm Hg)	(in H2O)	
	1	1	2	1	1.3730	3.2	2.00	
	2	3	4	1	0.9820	6.4	4.00	
	3	5	6	1	0.8780	8.0	5.00	
	4	7	8	1	0.8340	8.8	5.50	
l	2	9	101	1	0.6900	12.8	8.00	
			C	ata Tabula	tion			
	Vote $\sqrt{\Delta H \left(\frac{Pa}{Pstd}\right) \left(\frac{Tstd}{Ta}\right)}$)(<u>Tstd</u>)		02	√∆H(Ta/Pa)	
	(m3)	(x-axis)	(v-ax	is)	Va	(x-axis)	(v-axis)	
	0.9866	0.7186	1.407	78	0.9957	0.7252	0.8896	
	0.9824	1.0004	1.990)9	0.9914	1.0096	1.2581	
	0.9802	1.1165	2.225	59	0.9893	1.1267	1.4066	
	0.9792	1.1741	2.334	15	0.9882	1.1849	1.4753	
	0.9739	1.4114	2.815	55	0.9828	1.4244	1.7792	
	OCTO		2.030	14		m=	1.27124	
	QSID	b=	-0.046	516	QA	b=	-0.02917	
l		r=	0.999	95	r:		0.99995	
				Calculatio	ns			
	Vstd=	$\Delta Vol((Pa-\Delta P))$	/Pstd)(Tstd/Ta	a)	Va= ΔVol((Pa-ΔP)/Pa)			
	Qstd=	Vstd/∆Time			Qa= Va/ATime			
			For subsequ	ent flow ra	te calculatio	ns:		
	Qstd= $1/m\left(\left(\sqrt{\Delta H\left(\frac{Pa}{Pstd}\right)\left(\frac{Tstd}{Ta}\right)}\right)-b\right)$			Qa= $1/m\left(\left(\sqrt{\Delta H(Ta/Pa)}\right)-b\right)$				
	Standard	Conditions						-
Tstd:	Tstd: 298.15 °K Pstd: 760 mm Hg Key				RECA	LIBRATION		
Pstd:				LIS EDA room	mmonde	anual recalibration	on nor 1000	
All calibrate					US EPA recommends annual recalibration per 1998			
ΔP: rootsme	ан: callbrator manometer reading (In H2O)				40 Code of rederal Regulations Part 50 to 51, Annendix B to Part 50, Beference Mothod for the			
Ta: actual ab	Ta: actual absolute temperature (°K)				Determinat	tion of Susp	ended Particulat	e Matter in
Pa: actual ba	Pa: actual barometric pressure (mm Hg)				the Atmosphere, 9,2,17, page 30			
b: intercept	b: intercept							
Im: slone			1					

Tisch Environmental, Inc. 145 South Miami Avenue Village of Cleves, OH 45002 <u>www.tisch-env.com</u> TOLL FREE: (877)263-7610 FAX: (513)467-9009



Appendix F

Event and Action Plan

\\192.168.1.230\z\Jobs\2016\TCS00864 (CEDD)\600\EM&A Report Submission\Monthly EM&A Report\2022\February\R0535v2.docx

Event /	Action	Plan	for	construction	dust
---------	--------	------	-----	--------------	------

Enort	Action							
Event	ET	IEC	ER	Contractor				
Action Level exceedance for one sample	 Identify source, investigate the causes of exceedance and propose remedial measures; Inform IEC, ER and Contractor; Repeat measurement to confirm finding; and Increase monitoring frequency to daily. 	 Check monitoring data submitted by ET; Check Contractor's working method; and Review and advise the ET and ER on the effectiveness of the proposed remedial measures. 	1. Notify Contractor.	 Identify source, investigate the causes of exceedance and propose remedial measures; Rectify any unacceptable practice and implement remedial measures; and Amend working methods agreed with ER if appropriate. 				
Action Level exceedance for two or more consecutive samples	 Identify source, investigate the causes of exceedance and propose remedial measures; Inform IEC, ER and Contractor; Advise the ER and Contractor on the effectiveness of the proposed remedial measures; Repeat measurements to confirm findings; Increase monitoring frequency to daily; Discuss with IEC, ER and Contractor on remedial actions required; If exceedance continues, arrange meeting with IEC and ER; and If exceedance stops, cease additional monitoring. 	 Check monitoring data submitted by ET; Check Contractor's working method; Discuss with ET and Contractor on possible remedial measures; Advise the ET and ER on the effectiveness of the proposed remedial measures; and Supervise Implementation of remedial measures. 	 Confirm receipt of notification of failure in writing; Notify Contractor; and Supervise and ensure remedial measures properly implemented. 	 Identify source, investigate the causes of exceedance and propose remedial measures; Submit proposals for remedial actions to ER with a copy to ET and IEC within 3 working days of notification; Implement the agreed proposals; and Amend proposal if appropriate. 				
Limit Level exceedance for one sample	 Identify source, investigate the causes of exceedance and propose remedial measures; Inform ER, Contractor, IEC and EPD; Repeat measurement to confirm finding; Increase monitoring frequency to daily; and Assess effectiveness of Contractor's remedial actions and keep IEC, EPD and ER informed of the results. 	 Check monitoring data submitted by ET; Check Contractor's working method; Discuss with ET, ER and Contractor on possible remedial measures; Advise the ER and ET on the effectiveness of the proposed remedial measures; and Supervise implementation of remedial measures. 	 Confirm receipt of notification of failure in writing; Notify Contractor; and Supervise and ensure remedial measures properly implemented. 	 Identify source, investigate the causes of exceedance and propose remedial measures; Take immediate action to avoid further exceedance; Submit proposals for remedial actions to ER with a copy to ET and IEC within 3 working days of notification; Implement the agreed proposals; and Amend proposal if appropriate. 				
Limit Level exceedance for two or more consecutive samples	 Notify IEC, ER, Contractor and EPD; Identify source; Repeat measurement to confirm findings; Increase monitoring frequency to daily; Carry out analysis of Contractor's working procedures to determine possible mitigation to be implemented; Arrange meeting with IEC, Contractor and ER to discuss the remedial actions to be taken; Assess effectiveness of Contractor's remedial actions and keep IEC, EPD and ER informed of the results; and If exceedance stops, cease additional monitoring. 	 Check monitoring data submitted by ET; Check Contractor's working method; Discuss amongst ER, ET, and Contractor on the potential remedial actions; Review Contractor's remedial actions whenever necessary to assure their effectiveness and advise the ER accordingly; and Supervise the implementation of remedial measures. 	 Confirm receipt of notification of failure in writing; Notify Contractor; In consultation with the ET and IEC, agree with the Contractor on the remedial measures to be implemented; Supervise and ensure remedial measures properly implemented; and If exceedance continues, consider what portion of the work is responsible and instruct the Contractor to stop that portion of work until the exceedance is abated. 	 Identify source, investigate the causes of exceedance and propose remedial measures; Take immediate action to avoid further exceedance; Submit proposals for remedial actions to ER with a copy to ET and IEC within 3 working days of notification; Implement the agreed proposals; Resubmit proposals if problem still not under control; and Stop the relevant portion of works as determined by the ER until the exceedance is abated. 				


Event and Action Plan for Construction Noise

Evont	Action			
Lvent	ET	IEC	ER	Contractor
Action Level Exceedance	 Notify IEC, ER and Contractor; Carry out investigation; Report the results of investigation to the IEC, ER and Contractor; Discuss with the Contractor and formulate remedial measures; and Increase monitoring frequency to check mitigation effectiveness. 	 Review the analysed results submitted by the ET; Review the proposed remedial measures by the Contractor and advise the ER accordingly; and Supervise the implementation of remedial measures. 	 Confirm receipt of notification of failure in writing; Notify Contractor; Require Contractor to propose remedial measures for the analysed noise problem; and Ensure remedial measures are properly implemented. 	 Submit noise mitigation proposals to IEC and ER; and Implement noise mitigation proposals.
Limit Level Exceedance	 Identify source; Inform IEC, ER, EPD and Contractor; Repeat measurements to confirm findings; Increase monitoring frequency; Carry out analysis of Contractor's working procedures to determine possible mitigation to be implemented; Inform IEC, ER and EPD the causes and actions taken for the exceedances; Assess effectiveness of Contractor's remedial actions and keep IEC, EPD and ER informed of the results; and If exceedance stops, cease additional monitoring. 	 Discuss amongst ER, ET, and Contractor on the potential remedial actions; Review Contractors remedial actions whenever necessary to assure their effectiveness and advise the ER accordingly; and Supervise the implementation of remedial measures. 	 Confirm receipt of notification of failure in writing; Notify Contractor; Require Contractor to propose remedial measures for the analysed noise problem; Ensure remedial measures properly implemented; and If exceedance continues, consider what portion of the work is responsible and instruct the Contractor to stop that portion of work until the exceedance is abated. 	 Take immediate action to avoid further exceedance; Submit proposals for remedial actions to IEC within 3 working days of notification; Implement the agreed proposals; Resubmit proposals if problem still not under control; and Stop the relevant portion of works as determined by the ER until the exceedance is abated.



Appendix G

Impact Monitoring Schedule

		NOISE MONITORING	AIR QUALITY	MONITORING
	Date	(0700 – 1900)	1-HOUR TSP	24-HOUR TSP
Tue	1-Feb-22			
Wed	2-Feb-22			
Thu	3-Feb-22			
Fri	4-Feb-22			\checkmark
Sat	5-Feb-22	CN1, CN2, CN3 and NMS8	\checkmark	
Sun	6-Feb-22			
Mon	7-Feb-22			
Tue	8-Feb-22			√
Wed	9-Feb-22	NMS2, NMS3, NMS-4a, NMS5, NMS6 and NMS7	\checkmark	
Thu	10-Feb-22			
Fri	11-Feb-22	CN1, CN2, CN3 and NMS8		
Sat	12-Feb-22			
Sun	13-Feb-22			
Mon	14-Feb-22			✓
Tue	15-Feb-22	NMS2, NMS3, NMS-4a, NMS5, NMS6 and NMS7	\checkmark	
Wed	16-Feb-22			
Thu	17-Feb-22	CN1, CN2, CN3 and NMS8		
Fri	18-Feb-22			
Sat	19-Feb-22			✓
Sun	20-Feb-22			
Mon	21-Feb-22	NMS2, NMS3, NMS-4a, NMS5, NMS6 and NMS7	\checkmark	
Tue	22-Feb-22			
Wed	23-Feb-22	CN1, CN2, CN3 and NMS8		
Thu	24-Feb-22			
Fri	25-Feb-22			✓
Sat	26-Feb-22		\checkmark	
Sun	27-Feb-22			
Mon	28-Feb-22			

Impact Monitoring Schedule for the Reporting Period

\checkmark	Monitoring Day
	Sunday or Public Holiday

		NOISE MONITORING	AIR QUALITY	MONITORING
	Date	(0700 – 1900)	1-HOUR TSP	24-HOUR TSP
Tue	1-Mar-22	CN1, CN2, CN3 and NMS8		
Wed	2-Mar-22			
Thu	3-Mar-22			√
Fri	4-Mar-22	NMS2, NMS3, NMS-4a, NMS5, NMS6 and NMS7	\checkmark	
Sat	5-Mar-22			
Sun	6-Mar-22			
Mon	7-Mar-22			
Tue	8-Mar-22			
Wed	9-Mar-22			✓
Thu	10-Mar-22	NMS2, NMS3, NMS-4a, NMS5, NMS6 and NMS7	\checkmark	
Fri	11-Mar-22			
Sat	12-Mar-22	CN1, CN2, CN3 and NMS8		
Sun	13-Mar-22			
Mon	14-Mar-22			
Tue	15-Mar-22			✓
Wed	16-Mar-22	NMS2, NMS3, NMS-4a, NMS5, NMS6 and NMS7	\checkmark	
Thu	17-Mar-22			
Fri	18-Mar-22	CN1, CN2, CN3 and NMS8		
Sat	19-Mar-22			
Sun	20-Mar-22			
Mon	21-Mar-22	NIME2 NIME2 NIME 40 NIME5		v
Tue	22-Mar-22	NMS2, NMS5, NMS54a, NMS5, NMS5, NMS6 and NMS7	\checkmark	
Wed	23-Mar-22			
Thu	24-Mar-22	CN1, CN2, CN3 and NMS8		
Fri	25-Mar-22			
Sat	26-Mar-22	CN1, CN2, CN3 and NMS8		√
Sun	27-Mar-22			
Mon	28-Mar-22	NMS2, NMS3, NMS-4a, NMS5, NMS6 and NMS7	1	
Tue	29-Mar-22			
Wed	30-Mar-22	CN1, CN2, CN3 and NMS8		
Thu	31-Mar-22			

Impact Monitoring Schedule for next Reporting Period

\checkmark	Monitoring Day
	Sunday or Public Holiday

Appendix H

Database of Monitoring Result



24-HOUR TSP MONITORING RESULT DATABASE

24-hour TSI	P Monitoring	g Data for .	AMS1a												
DATE	SAMPLE	ELA	APSED TIM	1E	CHAI	RT REA	DING	AVG TEMP	AVG AIR PRESS	STANDARD FLOW RATE	AIR VOLUME	FILTER W	EIGHT (g)	DUST WEIGHT COLLECTED	24-hr TSP
	NUMBER	INITIAL	FINAL	(min)	MIN	MAX	AVG	(°C)	(hPa)	(m ³ /min)	(std m ³)	INITIAL	FINAL	(g)	$(\mu g/m^3)$
4-Feb-22	27840	24499.76	24523.76	1440	30	30	30	16.2	1020	1.27	1834	2.7152	2.7335	0.0183	10
8-Feb-22	27908	24523.76	24547.76	1440	34	35	34.5	16.9	1019	1.39	2004	2.789	2.8176	0.0286	14
14-Feb-22	27912	24547.76	24571.77	1441	34	35	34.5	17.4	1018	1.39	2003	2.7685	2.7947	0.0262	13
19-Feb-22	27957	24571.77	24595.77	1440	34	35	34.5	16.9	1018.7	1.39	2004	2.7834	2.8073	0.0239	12
25-Feb-22	27964	24595.77	24619.77	1440	36	38	37	17.8	1018	1.46	2097	2.7529	2.7904	0.0375	18
24-hour TSI	P Monitoring	g Data for .	AMS-5						•		•				
DATE	SAMPLE	ELA	APSED TIM	ſE	CHAI	RT REA	DING	AVG TEMP	AVG AIR PRESS	STANDARD FLOW RATE	AIR VOLUME	FILTER W	EIGHT (g)	DUST WEIGHT COLLECTED	24-hr TSP
	NUMBER	INITIAL	FINAL	(min)	MIN	MAX	AVG	(°C)	(hPa)	(m ³ /min)	(std m ³)	INITIAL	FINAL	(g)	$(\mu g/m^3)$
4-Feb-22	27873	11712.17	11736.17	1440.00	36	37	36.5	16.2	1020	1.39	2002	2.7037	2.7412	0.0375	19
8-Feb-22	27839	11736.17	11760.17	1440.00	36	37	36.5	16.9	1019	1.39	2000	2.7122	2.7472	0.0350	18
14-Feb-22	27914	11760.17	11784.18	1440.60	36	37	36.5	17.4	1018	1.39	1999	2.7752	2.8136	0.0384	19
19-Feb-22	27960	11784.18	11808.18	1440.00	36	37	36.5	16.9	1018.7	1.39	2000	2.7755	2.8183	0.0428	21
25-Feb-22	27961	11808.18	11832.18	1440.00	36	37	36.5	17.8	1018	1.39	1997	2.7618	2.7862	0.0244	12
24-hour TSI	P Monitoring	g Data for A	AMS-6												
DATE	SAMPLE	14 11760.17 11784.18 1440.60 36 37 3 50 11784.18 11808.18 1440.00 36 37 3 51 11808.18 11832.18 1440.00 36 37 3 51 11808.18 11832.18 1440.00 36 37 3 51 11808.18 11832.18 1440.00 36 37 3 51 11808.18 11832.18 1440.00 36 37 3 51 Elex ELAPSED TIME CHART READ ER INITIAL FINAL (min) MIN MAX A				DING	AVG TEMP	AVG AIR PRESS	STANDARD FLOW RATE	AIR VOLUME	FILTER W	EIGHT (g)	DUST WEIGHT COLLECTED	24-hr TSP	
	NUMBER	INITIAL	FINAL	(min)	MIN	MAX	AVG	(°C)	(hPa)	(m ³ /min)	(std m ³)	INITIAL	FINAL	(g)	$(\mu g/m^3)$
4-Feb-22	27874	16856.09	16880.09	1440.00	36	37	36.5	16.2	1020	1.42	2041	2.6920	2.7176	0.0256	13
8-Feb-22	27838	16880.09	16904.09	1440.00	36	37	36.5	16.9	1019	1.42	2039	2.7246	2.7853	0.0607	30
14-Feb-22	27915	16904.09	16928.10	1440.60	36	37	36.5	17.4	1018	1.41	2038	2.7886	2.8567	0.0681	33
19-Feb-22	27959	16928.10	16952.10	1440.00	36	37	36.5	16.9	1018.7	1.42	2039	2.7730	2.8405	0.0675	33
25-Feb-22	27962	16952.10	16976.10	1440.00	36	37	36.5	16	1018	1.42	2040	2.7663	2.8926	0.1263	62
24-hour TSI	P Monitoring	g Data for A	AMS-7												
DATE	SAMPLE	ELA	APSED TIN	1E	CHAI	RT REA	DING	AVG TEMP	AVG AIR PRESS	STANDARD FLOW RATE	AIR VOLUME	FILTER W	EIGHT (g)	DUST WEIGHT COLLECTED	24-hr TSP
	NUMBER	INITIAL	FINAL	(min)	MIN	MAX	AVG	(°C)	(hPa)	(m ³ /min)	(std m ³)	INITIAL	FINAL	(g)	$(\mu g/m^3)$
4-Feb-22	27904	12192.26	12216.26	1440.00	34	35	34.5	16.2	1020	1.35	1942	2.7917	2.8185	0.0268	14
8-Feb-22	27909	12216.26	12240.26	1440.00	34	35	34.5	16.9	1019	1.35	1940	2.7882	2.8523	0.0641	33
14-Feb-22	27913	12240.26	12264.27	1440.60	34	35	34.5	17.4	1018	1.35	1939	2.7747	2.8291	0.0544	28
19-Feb-22	27958	12264.27	12288.27	1440.00	34	35	34.5	16.9	1018.7	1.35	1940	2.7791	2.8363	0.0572	29
25-Feb-22	27965	12288.27	12312.27	1440.00	28	28	28.0	17.8	1018	1.17	1684	2.7480	2.7677	0.0197	12



NOISE MONITORING RESULT DATABASE FOR CONTRACT 1

Noise Measu	uremer	nt Resu	lts (dB)	of NMS2	2																
	Stant	1st	t Leq (51	min)	2nd	Leq (5	min)	3rd	Leq (51	nin)	4th	Leq (5r	nin)	5th	Leq (51	nin)	6th	Leq (5r	nin)	Lag20min	Limit
Date	Start	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	dR(A)	Level
	1 mie	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	uD(A)	dB(A)
9-Feb-22	15:37	60.5	61.3	57.5	61.4	62.5	58.1	60.5	62.3	57.4	56.5	59.4	55.7	59.5	61.6	57.4	61.5	62.8	58.5	60	70
15-Feb-22	15:49	62.8	65.2	61	63.7	67.8	60.5	62.9	65.9	60	60.8	63.8	58.6	61.9	64.9	59.9	61.5	64.6	59.8	62	70
21-Feb-22	15:38	63.8	65.5	61.6	64.4	67.1	60	63.6	65.1	60.1	63.9	66.1	61	64.8	67.1	62.5	62.4	65.4	60.6	64	70

Noise Measu	uremei	nt Resu	lts (dB)) of NM	S3																
	Stant	1st	Leq (5r	nin)	2nd	Leq (5	min)	3rd	Leq (51	min)	4th	Leq (51	nin)	5th	Leq (51	nin)	6th	Leq (51	min)	Lag20min	Limit
Date	Start	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	$d\mathbf{R}(\mathbf{A})$	Level
	Time	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	uD(A)	dB(A)
9-Feb-22	9:27	58.9	60.1	56.9	58.8	60.5	56.7	57.9	59.4	55.5	59.9	61.6	56.7	58.4	60.4	56.8	59.4	61.4	56.9	59	75
15-Feb-22	9:40	62.6	65.3	59.4	64.8	67.6	59.1	63.9	66.1	59.0	62.5	65.4	59.4	64.0	66.9	60.5	64.4	67.6	60.5	64	75
21-Feb-22	9:32	60.6	62.9	58.0	60.4	62.6	58.0	60.5	62.1	58.6	59.5	61.0	57.4	58.3	60.7	57.0	60.1	61.5	57.0	60	75

Noise Meas	sureme	ent Resu	ılts (dB) of NM	[S4a																
	Stant	1st Leq (5min) 2nd Leq (5min) Leq. L10. L90. Leq. L10. L/10.						3rd	Leq (51	min)	4th	Leq (51	nin)	5th	Leq (5r	nin)	6th	Leq (51	nin)	Log20min	Limit
Date	Start	Leq,	L10,	L90,	$\begin{array}{c c} \hline & \hline & \hline \\ 0, & Leq, & L10, & L9 \\ \hline \\ A & B & B \\ \hline \end{array}$		L90,	Leq,	L10,	L90,	dR(A)	Level									
	Time	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	uD(A)	dB(A)
9-Feb-22	14:08	67.7	69.3	63.4	65.6	68.6	62.6	66.5	68.3	63.5	66.5	69.2	63.5	67.7	69.1	64.5	66.9	68.1	63.5	67	75
15-Feb-22	14:21	63.5	62.7	60.2	61.3	62.4	60	63.4	65.2	61.1	64.6	66	62.7	66.6	68	65	64.5	66.8	63.4	64	75
21-Feb-22	14:15	71.5	72.1	66.2	68.5	71.1	64.8	69.2	71.7	65.6	68.6	70.8	64.7	69.5	71.9	65.1	68.5	70.9	64.2	69	75

Noise Measu	urement	t Result	ts (dB) o	of NMS	5																
	Stant	1st	Leq (5r	nin)	2nd	Leq (5	min)	3rd	Leq (51	min)	4th	Leq (51	nin)	5th	Leq (51	nin)	6th	Leq (5	min)	Lag20min	Limit
Date	Start	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	dR(A)	Level
	Ime	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	uD(A)	dB(A)
9-Feb-22	14:51	66.9	67.1	64.3	65.8	67.4	63.4	67.9	68.1	63.1	66.6	66.6	63.1	66	68.5	64.6	66.1	66.6	62.4	67	75
15-Feb-22	15:05	67.4	69.3	64.8	68.1	69.8	65.4	68.6	70.2	66.5	69.5	70.9	66	68.7	69.6	65.4	68.6	69.5	65	69	75
21-Feb-22	14:56	69.2	71.7	66.5	68.2	69.7	66.4	68.5	70	66.5	69.6	71.9	66.5	69.9	70.7	66.6	68.9	70.5	66.4	69	75

Noise Meas	uremei	nt Resu	lts (dB)	of NMS	56																
	Stant	1st	Leq (5n	nin)	2nd	Leq (5)	min)	3rd	Leq (5)	min)	4th	Leq (5r	nin)	5th	Leq (51	min)	6th	Leq (5r	nin)	Lag20min	Limit
Date	Start	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	dR(A)	Level
	Time	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	uD(A)	dB(A)
9-Feb-22	10:10	67.6	69.5	64.4	66.6	68.4	63.6	66.5	68.6	63.4	67.8	69.1	64.7	67.7	69	64.5	68.7	69	64.6	68	75

 $\label{eq:linear} $$ 1.230\z\bel{loss} $$ 016\TCS00864\CEDD\bel{loss} $$ 00\EM\&A\ Report\ Submission\Monthly\ EM\&A\ Report\2022\February\R0535v2.dox $$ 0.10\TCS00864\ CEDD\bel{loss} $$ 00\EM\&A\ Report\ Submission\Monthly\ EM\&A\ Report\2022\February\R0535v2.dox $$ 0.10\TCS00864\ CEDD\bel{loss} $$ 00\EM\&A\ Report\ Submission\Monthly\ EM\&A\ Report\2022\February\R0535v2.dox $$ 0.10\TCS00864\ CEDD\bel{loss} $$ 00\EM\&A\ Report\ Submission\Monthly\ EM\&A\ Report\2022\February\R0535v2.dox $$ 0.10\TCS00864\ CEDD\bel{loss} $$ 0.10\EM\&A\ Report\ Submission\Monthly\ EM\&A\ Report\ Submission\ Submis$



15-Feb-22	10:21	68.7	71.4	63.3	68.5	71.4	63.5	69.7	72.4	64.3	69.4	72.8	65.5	69.6	72.6	64.8	68.3	71.8	63.7	69	75
21-Feb-22	10:14	65.8	66.3	62.6	65.9	67.3	63.6	64.8	66.6	62	64.4	66.4	62	65.6	67.1	63.5	66.5	67.3	62.6	66	75

Noise Measu	uremer	nt Resul	lts (dB)	of NMS	S 7																
	Stant	1st	Leq (5n	nin)	2nd	Leq (5)	min)	3rd	Leq (51	nin)	4th	Leq (5r	nin)	5th	Leq (5r	nin)	6th	Leq (5r	nin)	Log20min	Limit
Date	Start	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	dP(A)	Level
	1 mie	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	uD(A)	dB(A)
9-Feb-22	10:54	64.8	66	61	65.5	68.5	62.7	66.3	68	61	65.4	67.5	61.6	65.5	68.7	62.9	65.5	68.7	62.9	66	75
15-Feb-22	11:04	67.8	70.6	63	66.4	69	62.4	67.3	70.4	63	68.6	71.6	63.5	67.5	70	62.6	64.9	66	60.8	67	75
21-Feb-22	10:57	64.5	66.6	61	65.3	68.4	61.3	66.3	68.4	62.1	64.3	66.7	61.5	65	68.5	62.4	64.1	66.1	61.9	65	75

Noise Measu	iremer	nt Resul	lts (dB)	of NMS	58																
	Start	1st	Leq (5r	nin)	2nd	Leq (5	min)	3rd	Leq (51	min)	4th	Leq (5)	min)	5th	Leq (51	nin)	6th	Leq (51	nin)	Lag20min	Limit
Date	Start	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	dB(A)	Level
	1 mie	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	uD(A)	dB(A)
5-Feb-22	15:37	69	72.5	62.5	68.7	71.5	62.5	64.7	67	61	64.9	67	61.5	69.8	72.5	63.5	68.7	71.5	62.5	68	75
11-Feb-22	9:14	67.1	69	65	68	70.2	65.1	68.3	70.8	65.6	68.4	72	64.4	71.5	75	63.8	68.3	71.3	63.7	69	75
17-Feb-22	11:26	64.2	67	58.7	65	67.7	59.5	63.7	66.6	58.3	63.1	66.5	55.9	64.5	67.7	58.7	65.8	67.3	59.4	64	75
23-Feb-22	13:00	65.2	66.1	58.2	62.1	64	57.1	61.6	64.1	56.7	64.4	65.8	57.6	63.8	64.4	56.1	60.4	62.5	55.6	63	75



NOISE MONITORING RESULT DATABASE FOR CONTRACT 3

Noise Measu	uremer	nt Resu	lts (dB)	of CN1	l																
	Stort	1st	Leq (5n	nin)	2nd	Leq (5	min)	3rd	Leq (51	min)	4th	Leq (5r	nin)	5th	Leq (5r	nin)	6th	Leq (5n	nin)	Log30min	Limit
Date	Time	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	$d\mathbf{B}(\Lambda)$	Level
	TIME	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	UD(A)	dB(A)
5-Feb-22	13:04	63.0	64.5	60.2	62.4	63.3	61.3	62.0	63.4	60.6	61.2	62.2	59.5	60.6	62.0	58.9	62.0	62.7	61.0	62	70
11-Feb-22	11:30	61.2	64	58.5	62	64	59.5	64	65.5	61.5	63.1	64	61.5	62.8	64	59	66.5	67.5	63	64	70
17-Feb-22	9:04	62.7	61	53.9	60.9	66.6	57.3	63.5	65.5	58.7	60	61.7	55.9	62.6	67.1	57.5	58.3	60.3	54.2	62	70
23-Feb-22	15:29	63.1	64.3	61.9	65.3	66.7	63.4	62.6	63.7	61.2	63.3	65.1	61.3	62.5	64	61.1	63.9	65.4	61.8	64	70

Noise Measu	uremer	nt Resu	lts (dB)	of CN2	2																
	Start	1st	Leq (5r	nin)	2nd	Leq (5	min)	3rd	Leq (5)	min)	4th	Leq (51	min)	5th	Leq (5)	min)	6th	Leq (5)	min)	Lag20min	Limit
Date	Start	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	$d\mathbf{R}(\mathbf{A})$	Level
	Time	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	uD(A)	dB(A)
5-Feb-22	13:47	62.6	63.9	58.2	60.5	62.8	57.5	64.2	65.7	58.7	63.2	65.2	57.6	66.7	66	59.9	64.2	64.2	58	64	70
11-Feb-22	10:56	61.9	67.3	57.7	60.8	65.4	58.9	61.3	64.7	60.1	61.9	67.8	59.1	61.4	66.6	59.2	62.3	66.2	61.2	62	70
17-Feb-22	9:46	63.3	66.2	59.9	62.7	65.8	60.1	61.6	64.9	59.6	64.1	66.9	61.3	65.1	68.4	61.8	62.6	64.9	60.1	63	70
23-Feb-22	14:38	63.5	65	61.5	64.4	66	61	66.2	68	62	66.4	69.5	63	66.9	70	63.5	67.5	69	65	66	70

Noise Measu	uremei	nt Resu	lts (dB)	of CN3	3																
	Start	1st	Leq (5r	nin)	2nd	Leq (5	min)	3rd	Leq (5	min)	4th	Leq (51	min)	5th	Leq (51	nin)	6th	Leq (51	nin)	Lag20min	Limit
Date	Start	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	Leq,	L10,	L90,	dP(A)	Level
	Time	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	uD(A)	dB(A)
5-Feb-22	14:36	69.6	72.1	66.1	69.8	71.9	66.6	69.6	71.7	67	68.6	70.6	66.5	69.3	71.2	67.3	66.5	67.5	65.4	69	75
11-Feb-22	10:19	67.2	73.6	61.6	67.7	72.9	62.9	65.2	69.8	61.8	64.2	69.9	60.7	64.5	68.5	59.6	66.1	70.5	60.4	66	75
17-Feb-22	10:27	64.9	66.5	56	60.3	63.5	55.5	59.1	61.5	56	60.7	65	57.5	63.3	67.5	57	60.7	64.5	57	62	75
23-Feb-22	13:54	60.1	63.9	57.9	64.9	67.2	58.9	63.1	65.5	58.7	64.4	66.1	58.1	61.3	64.1	59.2	59.6	63.6	58.3	63	75

Appendix I

Graphical Plots for Monitoring Result



Air Quality – 1-hour TSP









TSP (ug/m³) Graphical Plot for 1-hour TSP Monitoring Result at AMS-5









Air Quality – 24-hour TSP













Noise

























Monthly Environmental Monitoring & Audit Report (February 2022)







Appendix J

Meteorological Data



			Total	Kwun Tong Station	Kai Tal	k Station	King's Park Station
Date		Weather	Rainfall (mm)	Mean Air Temp. (°C)	Wind Speed (km/h)	Wind Direction	Mean Relative Humidity (%)
1-Feb-22	Tue	Mainly cloudy. Bright periods during the day.	1.2	13.3	10	N/NW	82
2-Feb-22	Wed	Moderate to fresh northeasterly winds.	1	14.6	8.5	N/NW	79.5
3-Feb-22	Thu	Mainly cloudy. Sunny intervals tomorrow.	1	12.8	7.5	N/NW	78
4-Feb-22	Fri	Moderate to fresh easterly winds.	0	15.2	9.2	W/NW	68.2
5-Feb-22	Sat	Moderate to fresh northerly winds	0	14.3	10.5	Е	69
6-Feb-22	Sun	Mainly cloudy. Sunny intervals tomorrow.	0	15	14	Е	71.5
7-Feb-22	Mon	Moderate to fresh northeasterly winds.	Trace	15.6	13.5	Е	86
8-Feb-22	Tue	Occasionally strong offshore and on high ground at first.	Trace	15.6	10	E/SE	76.7
9-Feb-22	Wed	Moderate to fresh northerly winds	0	15.6	10	E/SE	77.5
10-Feb-22	Thu	Rain will be more frequent at times.	0	16.8	8.7	E/SE	79.5
11-Feb-22	Fri	Sunny periods. Moderate to fresh easterly winds.	0	18.1	11.7	E/SE	77.5
12-Feb-22	Sat	Moderate to fresh easterly winds.	0	18.2	10.5	W/NW	79
13-Feb-22	Sun	Moderate to fresh northerly winds	1.2	15.8	8.7	W/NW	81.2
14-Feb-22	Mon	Rain will be more frequent at times.	1.2	17.7	9.5	W/SW	70.7
15-Feb-22	Tue	Fresh easterly winds, occasionally strong offshore and on high ground.	0	18	11.2	E/SE	73.7
16-Feb-22	Wed	Mainly cloudy. Sunny intervals in the afternoon.	0	15.6	17	Е	76.5
17-Feb-22	Thu	Moderate to fresh easterly winds.	4	14.8	16.5	E	87
18-Feb-22	Fri	Moderate to fresh northerly winds	Trace	14.7	19.7	E	83.5
19-Feb-22	Sat	Rain will be more frequent at times.	21.3	11.9	12.7	E	85
20-Feb-22	Sun	Moderate to fresh northerly winds	43.4	8	7.5	N/NE	91.5
21-Feb-22	Mon	It will be cold. Cloudy to overcast with rain.	43.4	8	8.7	W/NW	93
22-Feb-22	Tue	Mainly cloudy. Sunny intervals tomorrow.	43.3	8.5	8	W/NW	76.5
23-Feb-22	Wed	Moderate to fresh easterly winds.	11	12.2	13.2	N/NW	76.5
24-Feb-22	Thu	Moderate to fresh northerly winds	0	13.1	13.7	SE	66.7
25-Feb-22	Fri	Mainly cloudy. Sunny intervals tomorrow.	0	15.7	12.5	W/NW	65.7
26-Feb-22	Sat	Moderate to fresh northeasterly winds.	0	17.2	10.7	SE	67
27-Feb-22	Sun	Occasionally strong offshore and on high ground at first.	0	17.2	11.2	N/NW	71
28-Feb-22	Mon	Moderate to fresh northerly winds	0	18.5	10.8	N/NW	70.5

Appendix K

Waste Flow Table

		Actual Quan	tities of Inert C&I	O Materials Genera	ted Monthly			Actual Quantities	of C&D Wastes C	enerated Monthly	
Month	Total Quantity Generated	Hard Rock and Large Broken Concrete	Reused in the Contract (see Note 6)	Reused in other Projects (see Note 8)	Disposed as Public Fill	Imported Fill	Metals (see Note 9)	Paper/ cardboard packaging	Plastics (see Note 3)	Chemical Waste (see Note 5)	Others, e.g. general refuse
	(in '000m ³)	(in '000m ³)	(in '000m ³)	(in '000m ³)	(in '000m ³)	(in '000m ³)	(in '000 kg)	(in '000kg)	(in '000kg)	(in '000kg)	(in '000m ³)
Jan	2.871	0.000	2.517	0.000	0.354	0.000	0.000	0.000	0.015	0.000	0.082
Feb	1.372	0.000	1.187	0.000	0.185	0.000	0.000	0.000	0.000	0.000	0.102
Mar	0.000										
Apr	0.000										
May	0.000										
Jun	0.000										
Sub-total	4.243	0.000	3.704	0.000	0.539	0.000	0.000	0.000	0.015	0.000	0.185
Jul	0.000										
Aug	0.000										
Sep	0.000										
Oct	0.000										
Nov	0.000										
Dec	0.000										
Total	4.243	0.000	3.704	0.000	0.539	0.000	0.000	0.000	0.015	0.000	0.185

Monthly Summary Waste Flow Table for 2022 (year)

Notes:

(1) The performance targets are given in PS Clause 1.119 (14).

(2) The waste flow table shall also include C&D materials that are specified in the Contract to be imported for use at the Site.

(3) Plastics refer to plastic bottles/containers, plastic sheets/foam from packaging material and waste will be collected by recycler for recycling.

(4) Use the conversion factor, density of general refuse (1 t/m^3) and inert C&D materials (2 t/m^3) .

(5) Use the conversion factor for chemical waste (0.88kg/L).

(6) Assume a dump truck delivers 7.5 m^3 material in 1 trip.

(7) The cut-off date of this summary is 20^{th} of each month.

(8) The Inert C&D materials of reused in other Projects including glass materials.

(9) The C&D waste generation of metal including rechargable battery recycling.

Remarks: refer to Rock and AHM Record (Z:\04 SUPPORT WORK FOLDERS\F. ENVIRONMENTAL\4 - Implementation and Operation\4.4 - Documentation and its Control\11 - WFT, ULSD & Timber\Waste Flow Table\2017-07)

Name of Department : CEDD

Contract No. : NE/2016/05

Monthly Summary Waste Flow Table for 2022 (year) IDE CI 1 1 201

	1					ause 1.129					
		Actual Quanti	ties of Inert C&	&D Materials G	enerated Mont	hly	Act	ual Quantities o	f C&D Wastes	Generated Mo	onthly
Month	Total Quantity Generated	Hard Rock & Large Broken Concrete	Reused in the Contract	Reused in other Projects	Disposed as Public Fill	Imported Fill	Metals	Paper/ cardboard packaging	Plastics (see Note 3)	Chemicals Waste	Others, e.g. general refuse
	$(in `000 m^3)$	$(in '000 m^3)$	$(in '000 m^3)$	(in '000 m ³)	(in '000 m ³)	(in '000 m ³)	(in '000 kg)	(in '000 kg)	(in '000 kg)	(in '000 kg)	(in '000 m ³)
Jan	0.02	0	0	0	0.02	0	0	0	0	0	0.05
Feb	0.01	0	0	0	0.01	0	0	0	0	0	0.05
Mar											
Apr											
May			ſ						· · · · · · · · · · · · · · · · · · ·		
June									· · · · · · · · · · · · · · · · · · ·		
Sub-total	0. 03	0	0	0	0.03	0	0	0	0	0	0.10
July		-			ann an ta			and and the second s			
Aug								······································			
Sept											
Oct											
Nov											
Dec									· · · · · · · · · · · · · · · · · · ·	- 10 - 10 - 10 - 10 - 10 - 10 - 10 - 10	
Total											······································

(1)The performance targets are given in PS Clause 6.14 Notes:

(2)The waste flow table shall also include C&D materials that are specified in the Contract to be imported for use at the Site.

(3)

Plastics refer to plastic bottles/containers, plastic sheets/foam from packaging material. The Contractor shall also submit the latest forecast of the total amount of C&D materials expected to be generated from the Works. Together with a breakdown of the nature (4) where the total amount of C&D materials expected to be generated from the Works is equal to or exceeding 50,000 m³.

Development of Anderson Road Quarry Site - Road Improvement Works and Pedestrian Connectivity Facilities Works Phase 2A

		Actual Quan	tities of Inert C&I	D Materials Genera	ted Monthly			Actual Quantities	of C&D Wastes O	Generated Monthly	
Month	Total Quantity Generated	Hard Rock and Large Broken Concrete	Reused in the Contract (see Note 6)	Reused in other Projects (see Note 6)	Disposed as Public Fill	Imported Fill	Metals	Paper/ cardboard packaging	Plastics (see Note 3)	Chemical Waste (see Note 5)	Others, e.g. general refuse
	(in '000m ³)	(in '000m ³)	(in '000m ³)	(in '000m ³)	(in '000m ³)	(in '000m ³)	(in '000 kg)	(in '000kg)	(in '000kg)	(in '000kg)	(in '000m ³)
Jan	2.028	0.000	0.882	0.000	1.146	0.000	0.003	0.000	0.003	0.000	0.052
Feb	2.078	0.000	0.400	0.000	1.678	0.000	0.000	0.000	1.694	0.000	0.016
Mar											
Apr											
May											
Jun											
Sub-total	4.106	0.000	1.282	0.000	2.824	0.000	0.003	0.000	1.697	0.000	0.068
Jul											
Aug											
Sep											
Oct											
Nov											
Dec											
Total	4.106	0.000	1.282	0.000	2.824	0.000	0.003	0.000	1.697	0.000	0.068

Monthly Summary Waste Flow Table for <u>2022</u> (year)

Notes:

(1) The performance targets are given in PS Clause 1.129 (4).

(2) The waste flow table shall also include C&D materials that are specified in the Contract to be imported for use at the Site.

(3) Plastics refer to plastic bottles/containers, plastic sheets/foam from packaging material and waste will be collected by recycler for recycling.

(4) Use the conversion factor, density of general refuse (1 t/m^3) and inert C&D materials (2 t/m^3) .

(5) Use the conversion factor for chemical waste (0.88kg/L).

(6) Assume a dump truck delivers 7.5 m^3 material in 1 trip.

	Ac	tual Quantities	s of Inert C&E	Materials Ge	nerated Mont	hly	Actua	al Quantities o	f C&D Wastes	Generated M	onthly
Month	Total Quantity of Materials Generated	Hard Rock, Large Broken Concrete	Reused in the Contract	Reused in other Projects	Disposed as Public Fill	Imported Fill	Metals	Paper/ cardboard packaging	Plastics (see Note 3)	Chemical Waste	Others, e.g. general refuse
	(in '000 m ³)	(in '000 m ³)	(in '000 m ³)	(in '000 m ³)	(in '000 m ³)	(in '000 m ³)	(in '000 kg)	(in '000 kg)	(in '000 kg)	(in '000 kg)	(in '000 m ³)*
2021 Total	608.254	394.831	0.000	0.000	213.423	0.000	0.000	0.000	0.000	0.000	0.044
2022											
Jan	25.019	11.495	0.000	0.000	13.524	0.000	0.000	0.000	0.000	0.000	0.019
Feb	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.015
Mar	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Apr	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
May	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
June	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
July	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Aug	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sep	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Oct	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Nov	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Dec	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Accumulated Total (2021-2022)	633.273	406.326	0.000	0.000	226.947	0.000	0.000	0.000	0.000	0.000	0.078

Monthly Summary Waste Flow Table

*Remarks: Conversion factor for general refuse, 1 tonne = 2m³

Wing Lee – Univic Joint Venture	Rev. No.	11
ED/2019/02 - Environmental Management Plan	Issue Data	28 Eab 2022
Appendices - Appendix 13	Issue Date	20-FED-2022

Name of Department : <u>CEDD</u>

Contract No. : ______ED/2019/02

Monthly Summary Waste Flow Table for 2022 (year)

;											
		Annual Quanti	ities of Inert Ca	&D Materials G	enerated Mont	thly	Annu	al Quantities of	C&D Material	s Generated N	Ionthly
Month	Total Quantity Generated	Hard Rock & Large Broken Concrete	Reused in the Contract	Reused in other Projects	Disposed as Public Fill	Imported Fill	Metals	Paper/ cardboard packaging	Plastics (see Note 2)	Chemicals Waste	Others, e.g. general refuse
	(in '000 m ³)	(in '000 m ³)	(in '000 m ³)	(in '000 m ³)	(in '000 m ³)	(in '000 m ³)	(in '000 kg)	(in '000 kg)	(in '000 kg)	(in '000 kg)	(in '000 m ³)
Jan	0.18	0	0	0	0.18	0	0	0	0	0	0.02
Feb	0.02	0	0	0	0.02	0	0	0	0	0	0
Mar											
Apr											
May											
June											
Sub-total	0.20	0	0	0	0.20	0	0	0	0	0	0.02
July											
Aug											
Sept											
Oct											
Nov											
Dec											
Total	0.20	0	0	0	0.20	0	0	0	0	0	0.02

Notes: (1) The waste flow table shall also include C&D materials that are specified in the Contract to be imported for use at the Site.

(2) Plastics refer to plastic bottles/containers, plastic sheets/foam from packaging material.

Appendix L

Implementation Schedule for Environmental Mitigation Measures

		Objectives of the Recommended Measures & Main Concern to Address	Who to implement the measures?	Location of the	Implementation Status					
EM&A	Recommended Mitigation Measures									
Ket.	8			measure	Contract	Contract	Contract	Contract	Contract	
	Dust Impact (Contraction I	(hage)				2	3	4	5	
\$472 to	Mitigation manufaction form of regular watering under a	Minimizo dust impost	Contractor	All construction	V	V	V	V	V	
S4.7.5	good site practice should be adopted. Watering under a good site practice should be adopted. Watering once per hour on exposed worksites and haul road is proposed to achieve dust removal efficiency of 91.7%. While the above watering frequencies are to be followed, the extent of watering may vary depending on actual site conditions but should be sufficient to maintain an equivalent intensity of no less than 1.75 L/m^2 to achieve the respective dust removal efficiencies.	at the nearby sensitive receivers	Contractor	sites	v	v	v	v	v	
S4.7.6	The Contractor shall follow the procedures and requirements given in the Air Pollution Control (Construction ion Dust) Regulation.	Minimize dust impact at the nearby sensitive receivers	Contractor	All construction sites	V	V	V	V	V	
S4.7.6	 Following dust suppression measures should also be incorporated by the Contractor to control the dust nuisance throughout the construction phase: Any excavated or stockpile of dusty material should be covered entirely by impervious sheeting or sprayed with water to maintain the entire surface wet and then removed or backfilled or reinstated where practicable within 24 hours of the excavation or unloading; Any dusty materials remaining after a stockpile is removed should be wet ted with water and cleared from the surface of roads; A stockpile of dusty material should not be extend beyond the pedestrian barriers, fencing or traffic cones; The load of dusty materials on a vehicle leaving a construction ion site should be covered entirely by impervious sheeting to ensure that the dusty materials do not leak from the vehicle; Where practicable, vehicle washing facilities with high pressure water jet should be provided at every discernible or designated vehicle exit point. The area where vehicle washing tacilities and the exit point should be paved with concrete, bituminous materials or hardcores; When there are open excavation and reinstatement 	Minimize dust impact at the nearby sensitive receivers	Contractor	All construction sites	@	@	@	@	@	



	Recommended Mitigation Measures	Objectives of the Recommended Measures & Main Concern to Address	Who to implement the measures?	Location of the	Implementation Status					
EM&A										
Ref.				measure	Contract 1	Contract 2	Contract 3	Contract 4	Contract 5	
Ref.	 works, hoarding of not less than 2.4m high should be provided as far as practicable along the site boundary with provision for public crossing. Good site practice shall also be adopted by the Contractor to ensure the conditions of the hoardings are properly maintained throughout the construction ion period. The port ion of any road leading only to construction ion site that is within 30m of a vehicle entrance or exit should be kept clear of dusty materials; Surfaces where any pneumatic or power-driven drilling, cutting, polishing or other mechanical breaking operation takes place should be sprayed with water or a dust suppression chemical continuously; Any area that involves demolition activities should be sprayed with water or a dust suppression chemical immediately prior to, during and immediately after the activities so as to maintain the entire surface wet; Where a scaffolding is erected around the perimeter of a building under construction, effective dust screens, sheeting or netting should be provided to enclose the scaffolding from the ground floor level of the building; Any skip hoist for material transport should be totally enclosed by impervious sheeting; Every stock of more than 20 bags of cement or dry pulverised fuel ash (PFA) should be covered entirely by impervious sheeting or placed in an area 	Measures & Main Concern to Address	measures?	measure	Contract	Contract 2	Contract 3	Contract 4	Contract 5	
	 pulverised fuel ash (PFA) should be covered entirely by impervious sheeting or placed in an area sheltered on the top and the 3 sides; Cement or dry PFA delivered in bulk should be stored in a closed silo fit ted with an audible high level alarm which is interlocked with the material filling line and no overfilling is allowed; and Exposed earth should be properly treated by compact ion, turfing, hydroseeding, vegetation planting or acaling with later wind bitmered. 									



EM&A Ref.	Recommended Mitigation Measures Objectives Measures Concern to	Objectives of the Recommended	Who to implement the measures?	Location of the measure	Implementation Status					
		Measures & Main Concern to Address			Contract 1	Contract 2	Contract 3	Contract 4	Contract 5	
	shortcrete or other suitable surface stabiliser within six months after the last construction activity on the construction site or part of the construction site where the exposed earth lies.									
S4.7.7	Implement regular dust monitoring under EM&A programme during the Construction phase.	Control construction airborne noise	Selected Representative dust monitoring station	All construction sites where practicable	V	N/A	V	N/A	N/A	
	Noise Impact (Contraction	Phase)								
S5.6.9	 Implement the following good site management practices: only well-maintained plant should be operated on-site and plant should be serviced regularly during the construction ion programme; machines and plant (such as trucks, cranes) that may be in intermittent use should be shut down between work periods or should be throttled down to a minimum; plant known to emit noise strongly in one direct ion, where possible, be orientated so that the noise is directed away from nearby NSRs; silencers or mufflers on construction ion equipment should be properly fit ted and maintained during the construction ion works; mobile plant should be sited as far away from NSRs as possible and practicable; and material stockpiles, mobile container site office and other structures should be effectively utilised, where practicable, to screen noise from on-site construction activities. 	Control construction ion airborne noise	Contractor	All construction sites where practicable	@	V	V	(Construction) (Construction)	@	
\$5.6.11 to \$5.6.13	Use of "Quiet" Plant and Working Methods.	Reduce the noise levels of plant items	Contractor	All construction sites where practicable	V	N/A	N/A	N/A	N/A	
\$5.6.14	Install temporary site hoarding (approx 2.5m high) located on the site boundaries between noisy construction activities and NSRs. The conditions of the hoardings shall be properly maintained throughout the construction period.	Reduce the construction ion noise levels at low-level zone of NSRs through partial screening.	Contractor	All construction sites where practicable	V	V	V	V	V	
\$5.6.15 to \$5.6.18	Install movable noise barriers, full enclosure and acoustic mat, screen the noisy plants including air compressor and generator.	Screen the noisy plant items to be used at all construction sites	Contractor	All construction ion sites where practicable	V	V	N/A	V	N/A	
S5.6.19	Sequencing operation of construction plants equipment.	Operate sequentially	Contractor	All construction	V	V	N/A	N/A	N/A	

 $\label{eq:linear} $$ 1.230\z\bel{loss} $$ 016\TCS00864\CEDD\bel{loss} $$ 00\EM\&A\ Report\ Submission\Monthly\ EM\&A\ Report\2022\February\R0535v2.docx $$ 0.16\TCS00864\ CEDD\bel{loss} $$ 00\EM\&A\ Report\ Submission\Monthly\ EM\&A\ Report\2022\February\R0535v2.docx $$ 0.16\TCS00864\ CEDD\bel{loss} $$ 00\EM\&A\ Report\ Submission\Monthly\ EM\&A\ Report\2022\February\R0535v2.docx $$ 0.16\TCS00864\ CEDD\bel{loss} $$ 00\EM\&A\ Report\ Submission\Monthly\ EM\&A\ Report\ Submission\ Submissio$



EM&A	Recommended Mitigation Measures	Objectives of the Recommended Measures & Main Concern to AddressWho to implement the measures?	Who to	Location of the measure	Implementation Status				
Ref.			measures?		Contract 1	Contract 2	Contract 3	Contract 4	Contract 5
		within the same work site to reduce the construction airborne noise		ion sites where practicable					
\$5.6.34	Implement temporary noise barrier along Road L4.	Further reduce the construction ion airborne noise	Contractor	Road L4 of ARQ	N/A	N/A	N/A	N/A	N/A
\$5.6.35	Implement a noise monitoring under EM&A programme.	Monitor the construction noise levels at the selected representative locations	Contractor	Selected Representative Noise monitoring stations	V	N/A	V	N/A	N/A
В	Water Quality Impact (Con	traction Phase)							
S6.6.3	 <u>Construction Runoff</u> In accordance with the Practice Note for Professional Persons on Construction ion Site Drainage, Environmental Protect ion Department , 1994 (ProPECC PN 1/94), best management practices should be implemented as far as practicable as below: At the start of site establishment , perimeter cut -off drains to direct off-site water around the site should be constructed with internal drainage works. Channels (both temporary and permanent drainage pipes and culverts), earth bunds or sand bag barriers should be provided on site to direct stormwater to silt removal facilities. Diversion of natural stormwater should be provided as far as possible. The design of temporary on-site drainage should prevent runoff going through site surface, construction machinery and equipment in order to avoid or minimize polluted runoff. Sediment at ion tanks with sufficient capacity, constructed from preformed individual cells of approximately 6 to 8 m³ capacities, are recommended as a general mitigation measure which can be used for set t ling surface runoff prior to disposal. The system capacity shall be flexible and able to handle multiple inputs from a variety of sources and suited to applications where the influent is pumped. 	Control construction runoff	Contractor	All construction sites	©	(C)	æ	œ	V



	Recommended Mitigation Measures	Objectives of the	Who to implement the measures?	Location of the measure	Implementation Status					
EM&A		Recommended								
Ref.		Measures & Main			Contract	Contract	Contract	Contract	Contract	
		Concern to Address			1	2	3	4	5	
	• The dikes or embankments for flood protect ion									
	should be implemented around the boundaries of									
	earthwork areas. Temporary ditches should be									
	provided to facilitate the runoff discharge into an									
	appropriate watercourse, through a silt /sediment t									
	rap. The silt /sediment t raps should be incorporated									
	in the permanent drainage channels to enhance									
	deposit ion rates.									
	• The design of efficient silt removal facilities should									
	be based on the guidelines in Appendix A1 of									
	ProPECC PN 1/94. The detailed design of the									
	sand/silt traps should be undertaken by the									
	contractor prior to the commencement of									
	construction ion.									
	• Construction works should be programmed to									
	minimize surface excavation works during the rainy									
	seasons (April to September). All exposed earth									
	areas should be completed and vegetated as soon as									
	possible after earthworks have been completed. If									
	excavation of soil cannot be avoided during the									
	rainy season, or at any time of year when rainstorms									
	are likely, exposed slope surfaces should be covered									
	by tarpaulin or other means.									
	• All drainage facilities and erosion and sediment									
	control structures should be regularly inspected and									
	maintained to ensure proper and efficient operation									
	at all times and particularly following rainstorms.									
	Deposited silt and grit should be removed regularly									
	and disposed of by spreading evenly over stable,									
	vegetated areas.									
	• Measures should be taken to minimise the ingress of site drainage into executions. If the execution of									
	transhes in wet periods is pecessary it should be									
	dug and healtfilled in short sect ions wherever									
	aug and backfilled in short sect ions wherever									
	foundation exceptions should be discharged into									
	storm drains via silt removal facilities									
	All open stockniles of construction ion materials									
	(for example aggregates sand and fill material) of									
	should be covered with tarpaulin or similar fabric									
	during rainstorms. Measures should be taken to									



FM&A	Recommended Mitigation Measures	Objectives of the Recommended Measures & Main Concern to Address	Who to	Logation of the	Implementation Status					
Ref.			implement the measures?	measure	Contract	Contract 2	Contract	Contract 4	Contract 5	
	 prevent the washing away of construction ion materials, soil, silt or debris into any drainage system. Manholes (including newly constructed ones) should always be adequately covered and temporarily sealed so as to prevent silt, construction ion materials or debris being washed into the drainage system and storm runoff being directed into foul sewers. Precautions to be taken at any time of year when rainstorms are likely, act ions to be taken when a rainstorm is imminent or forecasted, and act ions to be taken during or after rainstorms are summarized in Appendix A2 of <i>ProPECC PN 1/94</i>. Particular attention should be paid to the control of silty surface runoff during storm events. All vehicles and plant should be cleaned before leaving a construction ion site to ensure no earth, mud, debris and the like is deposited by them on roads. An adequately designed and sited wheel washing facilities should be provided at every construction ion site exit where practicable. Wash-water should have sand and silt settled out and removed at least on a weekly basis to ensure the continued efficiency of the process. The sect ion of access road leading to, and exiting from, the wheel-wash bay to the public road should be paved with sufficient back all toward the wheel-wash bay to prevent vehicle tracking of soil and silty water to public roads and rains. Oil interceptors should be provided in the drainage system downstream of any oil/fuel pollution sources. The oil interceptors should be provided for the oil interceptors to prevent flushing during heavy rain. Construction ion solid waste, debris and rubbish on site should be collected, handled and disposed of properly to avoid water quality impacts. 									



		Objectives of the	Who to	Location of the measure	Implementation Status					
EM&A	Performended Mitigation Massures	Recommended								
Ref.	Recommended witigation weasures	Measures & Main	measures?		Contract	Contract	Contract	Contract	Contract	
		Concern to Address			1	2	3	4	5	
	• All fuel tanks and storage areas should be provided									
	with locks and sited on sealed areas, within bun ds									
	of a capacity equal to 110% of the storage capacity									
	of the largest tank to prevent spilled fuel oils from									
	reaching water sensitive receivers nearby.									
	• Regular environmental audit on the construction site									
	should be carried out in order to prevent any									
	maipractices. Not ices should be posted at									
	discharge any service or westerwater into the rivers									
S666 and	Considered and sewage of wastewater into the rivers.	Handling of site	Contractor	All construction	V	V	V	V	V	
50.0.0 and	• Portable chemical toilets should be provided for	ranulling of site	Contractor	sites	v	v	v	v	v	
0.0.7	• Foldable chemical tonets should be provided for handling the construction sewage generated by the	sewage		5110.5						
	workforce Assume that the capacity of the chemical									
	toilets would be 0.4m3 and suck up twice a day									
	under normal practices, around 45 chemical toilets									
	would be required for the whole site at peak hour.									
	And it should be noted that under normal									
	construction periods, less chemical toilets would be									
	needed. In addition, the total number of the									
	chemical toilets would be subject to later detailed									
	design, the capacity of the chemical toilets, and									
	contractor's site practices. Nevertheless, a licensed									
	contractor should be employed to provide									
	appropriate and adequate portable toilets to cater									
	around 37.5 m3/day sewage and be responsible for									
	appropriate disposal and maintenance. Since									
	portable chemical toilets will be provided, no									
	adverse water quality impact from the workforce									
	sewage is anticipated.									
	• Notices should be posted at conspicuous locations									
	to remind the workers not to discharge any sewage									
	or wastewater into the nearby environment during									
	the construction ion phase of the Project . Regular									
	environmental audit on the construction ion site									
	should be conducted in order to provide an effective									
	control of any malpractices and achieve continual									
	improvement of environmental performance on site.									
	It is anticipated that sewage generation during the									
	construction phase of the Project would not cause									



EM&A	Recommended Mitigation Measures Objectives of the Recommended Mitigation Measures & Main Concern to Addre	Objectives of the Recommended	Who to implement the measures?	Location of the measure	Implementation Status					
Ref.		Measures & Main Concern to Address			Contract 1	Contract 2	Contract 3	Contract 4	Contract 5	
	water quality impact after undertaking all required measure									
S6.6.8 and 6.6.9	<u>Accidental Spillage</u> To prevent accidental spillage of chemicals, proper storage and handling facilities should be provided. All the tanks, containers and storage area should be bunded and the locations should be locked as far as possible from the sensitive watercourse and storm drains. The Contractor is required to register as a chemical waste producer if chemical wastes would be generated from the construction ion activities. Storage of chemical waste arising from the construction ion activities should be well managed with suitable labels an d warnings while disposal of those chemical wastes should be comply with the requirement states in Waste Disposal Ordinance (Cap 354) as well as Waste Disposal (Chemical Waste) (General) Regulations.	Prevention of accidental spillage	Contractor	All construction sites	@	V	V	V	V	
S6.6.11- S6.6.14	Groundwater from Contaminated Area The Contractor should apply for a discharge licence under the WPCO through the Regional Office of EPD for groundwater discharge. Prior to the excavation works within these potentially contaminated areas, the groundwater quality should be reviewed during the process of discharge license application. The compliancy to the TM-DSS and the existence of prohibited substance should be confirmed after further SI. If the review results indicated that the groundwater to be generated from the excavation works would be contaminated, the contaminated groundwater should be either properly treated in compliance with TMDSS or properly recharged into the ground. If wastewater treatment is deployed, the wastewater treatment unit shall deploy suitable treatment process (e.g. oil interceptor / activated carbon) to reduce the pollution level to an acceptable standard and remove any prohibited substances (e.g. Petroleum Carbon Ranges (PCRs)). All treated effluent from wastewater treatment plant shall meet the requirements as stated in TM-DSS and should be	Minimize contaminated groundwater impacts	Contractor	All construction sites	N/A	N/A	N/A	N/A	N/A	


EM&A		Objectives of the Recommended	Who to	Location of the	Implementation Status					
Ref.	Recommended Mitigation Measures	Measures & Main Concern to Address	implement the measures?	measure	Contract	Contract 2	Contract 3	Contract	Contract 5	
	discharged into the foul sewers.									
	If groundwater recharging wells are deployed, recharging wells should be installed as appropriate for recharging the contaminated groundwater back into the ground. The recharging wells should be selected at places where the groundwater quality will not be affected by the recharge operation as indicated in the Sect ion 2.3 of TM-DSS. The baseline groundwater quality shall be determined prior to the select ion of the recharge wells, and submit a working plan (including the laboratory analytical results showing the quality of groundwater at the proposed recharge location(s) as well as the pollutant levels of groundwater to be recharged shall not be higher than pollutant levels of ambient groundwater at the recharge well. Prior to recharge, any prohibited substances such as PCRs should be removed as necessary by installing the netrol intercenter.									
	Waste Management (Contr	action Phase)								
\$8.5.2	 <u>Good Site Practice</u> The following good site practices are recommended throughout the construction ion activities: nomination of an approved personnel, such as a site manager, to be responsible for the implementation of good site practices, arrangements for collect ion and effective disposal to an appropriate facility, of all wastes generated at the site; training of site personnel in site cleanliness, appropriate waste management procedures and concepts of waste reduction, reuse and recycling; provision of sufficient waste disposal points and regular collect ion for disposal; appropriate measures to minimize windblown litter and dust during transportation of waste by either covering trucks or by transporting wastes in enclosed containers; regular cleaning and maintenance programme for drainage systems, sumps and oil interceptors; 	Minimize waste generation during construction	Contractor	All construction sites	V	@	V	@	V	
S8.5.2 (6)	The contractor should submit a Waste Management Plan	Minimize waste	Contractor	All construction	V	V	V	女	V	

 $\label{eq:linear} $$ 1.230\z\bel{loss} $$ 0.16\TCS00864\CEDD\bel{loss} $$ 0.16\TCS00864\CED\bel{loss} $$ 0.16\TCS00864\CEDD\$

EM&A	Decomposed ad Midian diam Macanana	Objectives of the Recommended	Who to	Location of the		Imple	ementation S	Status	
Ref.	Recommended Mitugation Measures	Measures & Main Concern to Address	measures?	measure	Contract 1	Contract 2	Contract 3	Contract	Contract 5
	(WMP) as part of the Environmental Management Plan (EMP) in accordance with the <i>ETWB TC(W) No. 19/2005</i> for construction ion phase. The EMP should be submit ted to the Engineer for approval. Mitigation measures proposed in the EIA Report and the EM&A Manual should be adopted.	generation during construction		sites					
\$8.5.3	 <u>Waste Reduction Measures</u> <u>Waste reduction is best achieved at the planning and design phase, as well as by ensuring the implementation of good site practices. The following recommendations are proposed to achieve reduction:</u> segregate and store different types of waste in different containers, skip or stockpiles to enhance reuse or recycling o materials and their proper disposal; proper storage and site practices to minimize the potential for damage and contamination of construction ion materials; plan and stock construction ion materials carefully to minimize amount of waste generated and avoid unnecessary generation of waste; sort out demolition debris and excavated materials from demolition works to recover reusable/recyclable port ions (i.e. soil, broken concrete, metal etc.); provide training to workers on the importance of appropriate waste management procedures, including waste reduction, reuse and recycling. 	Reduce waste generation	Contractor	All construction sites where practicable	V	V	V	V	V
S8.5.5	 <u>Storage of Waste</u> The following recommendation should be implemented to minimize the impacts: waste such as soil should be handled and stored well to ensure secure containment; stockpiling area should be provided with covers and water spraying system to prevent materials from wind-blown or being washed away; different locations should be designated to stockpile each material to enhance reuse; 	Minimize waste impacts from storage	Contractor Contractor	All construction sites	V	V	V	V	V
S8.5.6	<u>Collection and Transportation of Waste</u> The following recommendation should be implemented to minimize the impacts:	Minimize waste impacts from storage	Contractor	All construction sites	V	@	V	@	@



EM&A		Objectives of the Recommended	Who to	Location of the	Implementation Status					
Ref.	Recommended Mitigation Measures	Measures & Main Concern to Address	implement the measures?	measure	Contract 1	Contract 2	Contract 3	Contract 4	Contract 5	
	 remove waste in timely manner; employ the trucks with cover or enclosed containers for waste transportation; obtain relevant waste disposal permits from the appropriate authorities; and disposal of waste should be done at licensed waste disposal facilities. 									
S8.5.8	 Excavated and C&D Material Wherever practicable, C&D materials should be segregated from other wastes to avoid contamination and ensure acceptability at public filling areas or reclamation sites. The following mitigation measures should be implemented in handling the excavated and C&D materials: maintain temporary stockpiles and reuse excavated fill material for backfilling; carry out on-site sorting; make provisions in the Contract documents to allow and promote the use of recycled aggregates where appropriate; implement a recording system for the amount of waste generated, recycled and disposed of for checking; The recommended C&D materials handling should include: On-site sorting of C&D materials Reuse of C&D materials Use of Standard Formwork and Planning of Construction Materials purchasing Provision of wheel wash facilities 	Minimize waste impacts from excavated and C&D materials	Contractor	All construction sites	V	V	V	V	V	
S8.5.15	<u>Contaminated Soil</u> As a precaution, it is recommended that standard good site practice should be implemented during the construction phase to minimize any potential exposure to contaminated soils or groundwater. The details of mitigation measures to minimize the potential environmental implications arising from the handling of contaminated materials refer to Land Contamination Section.	Remediate contaminated soil	Contractor	All construction sites where applicable	V	V	N/A	N/A	N/A	
S8.5.17	Chemical Waste	Control the chemical	Contractor	All construction	V	V	V	V	V	

EM 9. A		Objectives of the	Who to	Leasting of the	Implementation Status					
Ref.	Recommended Mitigation Measures	Measures & Main Concern to Address	implement the measures?	measure	Contract	Contract 2	Contract	Contract 4	Contract 5	
	• If chemical wastes are produced at the construction ion site, the Contractors should register with EPD as chemical waste producer. Chemical wastes should be stored in appropriate containers and collected by a licensed chemical waste Contractor. Chemical wastes (e.g. spent lubricant oil) should be recycled at an appropriate facility as far as possible, while the chemical waste that cannot be recycled should be disposed of at either the Chemical Waste Treatment Cent re, or another licensed facility, in accordance with the Waste Disposal (Chemical Waste) (General) Regulation.	waste and ensure proper storage, handling and disposal.		sites						
S8.5.18	 <u>General Waste</u> General refuse should be stored in enclosed bins separately from construction and chemical wastes. Recycling bins should also be placed to encourage recycling. Preferably enclosed and covered areas should be provided for general refuse collect ion and routine cleaning for these areas should also be implemented to keep areas clean. A reputable waste collector should be employed to remove general refuse on a daily basis. 	Minimize production of the general refuse and avoid odour, pest and litter impacts	Contractor	All construction sites	@	V	V	V	@	
\$8.5.19	 Sewage The WMP should document the locations and number of portable chemical toilets depending on the number of workers, land availability, site condition and activities. Regularly collect ion by licensed collectors should be arranged to minimize potential environmental impacts. 	Minimize production of sewage impacts	Contractor	All construction sites	V	V	V	V	V	
	Ecology (Contraction Phas	<u>e)</u>						-		
S. 10.7.2 to 10.7.6	Re-provision of Wooded Area for ecological function at the future Quarry Park.	Compensate for the loss of three woodland patches of a total area of about 1.13ha.	Contractor/ Detailed Design Consultant (qualified botanist / horticulturist / Certified Arborist to supervise the planting).	Northern part of the proposed Quarry Park.	N/A	N/A	N/A	N/A	N/A	



		Objectives of the	e Marca		Implementation Status						
EM&A		Recommended	Who to	Location of the							
Ref.	Recommended Mitigation Measures	Measures & Main	implement the measures?	measure	Contract	Contract	Contract	Contract	Contract		
		Concern to Address			1	2	3	4	5		
.10.7.10	Construction phase in situ mitigation measures to	Minimize impacts on	Contractor	All construction	V	N/A	V	V	N/A		
	minimize impacts on hydrological condition and water	Hydrological		sites							
	quality of hillside watercourses include:	condition and water									
	• Temporary sewerage and drainage will be designed	quality of hillside									
	and installed to collect wastewater and prevent it	watercourses.									
	from entering nearby watercourses;										
	• Proper locations well away from nearby										
	watercourses will be used for temporary storage of										
	materials (i.e. equipment, fill materials, chemicals										
	and fuel) and temporary stockpile of construction										
	debris and spoil, and these will be identified before										
	To provent muddy water entering nearby										
	• 10 prevent muddy water entering hearby										
	watercourses, work sites close to hearby										
	sandbags or silt curtains with lead adge at bot tom										
	and properly supported props. Other protective										
	measures will also be taken to ensure that no										
	nollution or siltation occurs to the water gathering										
	grounds of the works site:										
	• Stockpiling of construction materials, if necessary.										
	will be properly covered and located away from										
	nearby watercourses:										
	• Erection of temporary geotextile silt fences will be										
	carried out around earth-moving works to trap any										
	sediments and prevent them from entering										
	watercourses;										
	• Construction debris and spoil will be covered and/or										
	properly disposed as soon as possible to avoid being										
	washed into nearby watercourses;										
	• Exposed soil will be covered as quickly as possible										
	following format ion works, followed, where										
	appropriate, by covering with biodegradable										
	geotextile blanket for erosion control purposes;										
	• Where appropriate, earth-bunding will be carried out of areas where soils have been disturbed or where vegetation has been cleared, to ensure that										
	surface runoff will not move soils off-site;										
	• Construction ion effluent, site run-off and sewage										
	will be probably collected and/or treated.										
	Wastewater from any construction ion site will be										



		Objectives of the	Whete		Implementation Status					
EM&A	Recommended Mitigation Measures	Recommended	implement the	Location of the						
Ref.		Measures & Main Concern to Address	measures?	measure	Contract 1	Contract 2	Contract 3	Contract 4	Contract 5	
S.10.7.11	 minimised via the following in descending order: reuse, recycling and treatment; Proper locations for discharge out lets of wastewater treatment facilities well away from sensitive receivers will be identified and used; Silt traps will be installed at points where drainage from the site enters local watercourses; Appropriate sanitary facilities for on-site workers will be provided; The site boundary will be clearly marked and any works beyond the boundary strictly prohibited, and Regular water monitoring and site audit will be carried out at suitable points. If the monitoring and audit results show that pollution occurs, adequate measures including temporary cessation of works will be considered. 	Minimize impacts on	Contractor	All construction	N/A	N/A	N/A	N/A	N/A	
	 construction phase and the plan will include, but not be limited to, the following: Potential emergency situations; Chemicals or hazardous materials used on-site (and their location); Emergency response team; Emergency response procedures; List of emergency telephone hot lines; Locations and types of emergency response equipment, and Training plan and testing for effectiveness. 	Hydrological condition and water quality of hillside watercourses.		sites						
	Landscape and visual (Con	traction Phase)								
S11.14.23, Table 11.9, CM1 [4]	All existing trees to be retained shall be carefully protected during construction.	Avoid disturbance and protection of the existing trees	Detailed Design Consultant /	The whole project area where applicable	V	V	@	V	@	
S11.14.23, Table 11.9, CM2 [3]	Tree Transplantation - Should removal of trees be unavoidable due to construction impacts, trees will be transplanted or felled. Detailed transplanting proposal will be submit ted to relevant government departments for approval in accordance with LAO GN No. 7/2007, ETWB TCW No. 29/2004 and 10/2013. Final locations of transplanted trees shall be agreed prior to commencement of the work.	Minimize landscape impact and retention of landscape resources	Detailed Design Consultant /	Onsite where possible. Otherwise consider offsite locations	*	N/A	N/A	V	V	

		Objectives of the			Implementation Status					
EM&A	Recommended Mitigation Measures	Recommended	Who to implement the	Location of the						
Kei.		Concern to Address	measures?	measure	Contract	Contract	Contract	Contract	Contract	
		Concern to municip			1	2	3	4	5	
S11.14.23,	Control of operation night -time glare with well-planned	Minimize glare	Contractor/	The whole	V	V	@	V	N/A	
Table 11.9,	lighting operation system to minimize potential glare	impact to	CEDD	project area						
CM3 [4]	impact to adjacent VSRs	adjacent VSRs		where						
				applicable						
S11.14.23,	Erection of decorative screen hoarding.	Minimize visual	Contractor/	The whole	N/A	N/A	N/A	N/A	N/A	
Table		impact	CEDD	project area						
11.9, CM				where						
[4]				applicable						
S11.14.23,	Minimise disturbance and limitation of run-off -	Minimize visual	Contractor/	The whole	V	V	V	V	N/A	
Table	temporary structures and construction works should be	impact	CEDD	project area						
11.9, CM5	planned with care to minimize disturbance to adjacent			where						
[2]	landscape, vegetation, natural stream habitats.			applicable						

Legend: V = implemented; x = not implemented; @ = partially implemented; * = pending to be implemented; N/A = not applicable

Appendix M

Complaint Log

Appendix M1 Cumulative Complaint and Summons/ prosecution

Reporting Month	Number of Complaints in	Number of Summons/
	Reporting Month	Prosecution in Reporting Month
March 2017	1	0
April 2017	0	0
May 2017	0	0
June 2017	2	0
July 2017	3	0
August 2017	3	0
September 2017	4	0
October 2017	2	0
November 2017	3	0
December 2017	3	0
January 2018	1	0
February 2018	4	0
March 2018	0	0
April 2018	2	0
May 2018	1	0
June 2018	1	0
July 2018	0	0
August 2018	1	0
September 2018	1	0
October 2018	1	0
November 2018	3	0
December 2018	2	0
January 2019	2	0
February 2019	3	0
March 2019	1	0
April 2019	0	0
May 2019	0	0
June 2019	1	0
July 2019	1	0
August 2019	1	0
September 2019	0	0
October 2019	1	0
November 2019	4	0
December 2019	0	0
January 2020	0	0
February 2020	0	0
March 2020	4	0
April 2020	1	0
May 2020	1	0
June 2020	1	0
July 2020	0	0
August 2020	0	0
September 2020	0	0
October 2020	0	0
November 2020	1	0
December 2020	2	0
January 2021	1	0
February 2021	0	0
March 2021	2	0

April 2021	1	0
May 2021	0	0
June 2021	1	0
July 2021	1	0
August 2021	0	0
September 2021	2	0
October 2021	0	0
November 2021	0	0
December 2021	0	0
January 2022	0	0
February 2022	0	0
Overall Total	70	0

Appendix M2 C

Complaint Log

1	23-Mar- 17	8-Jun- 17	On Tat Estate	Reside nt of On Tat Estate	Cons tructi on noise	SPRO hotline	NA	A resident living in On Tat House reported that some night works with noise and flashing caused nuisance to nearby resident after 11:00 pm on 23 March 2017.	According the incident report conducted by the CWSTVJV, demobilization of crawler crane was undertaken on 23 March 2017 11pm and it is TD requirement to carry out demobilization of heavy machine at nighttime. It is considered this complaint was a single incident and would not be happened again in future.	no comment by IEC on 11 Oct 2017	TCS00864/ 16/300/F00 87
2	28-Jul-1 7	28-Jul- 17	38/F of Yin Tat House (賢達 樓), On Tat Estate	Reside nt of On Tat Estate	Cons tructi on noise	SPRO hotline	NA	Mr. Hsu received a complaint from a resident living in the flat on 38/F of Yin Tat House (賢達 樓), On Tat Estate. The resident complained about the noise level of our works during daytime.	Noise monitoring by Contractor was conducted in Yin Tat House, On Tat Estate, at around 2 pm on 28-Jul-2017. Another noise monitoring was carried out by ET (AUES) and representatives of AECOM and JV in the presence of the complainant in her flat at 10 am on 1-Aug-2017 and was witnessed by Mr. Hsu. No exceedance of noise was recorded. The complainant was satisfied about the monitoring results.	no comment by IEC on 9 Aug 2017	TCS00864/ 16/300/F00 60
3	29-Aug- 17	29-Au g-17	Shing Tat House 24/F	Reside nt of On Tat Estate	Cons tructi on noise	SPRO hotline	NA	Mr. Hsu Yau Wai (Tel no.9519 5663) reported that he received complaint from a resident (Ms Cheng) living at Shing Tat House 24/F Room 22 about the noise generated from our site this week. The noise heard was mainly rock breaking noise from our site.	Noise monitoring was carried out by ET (AUES) and representatives of AECOM and JV in the presence of the complainant in her flat at 3pm on 30-Aug-2017. No exceedance of noise was recorded. The complainant was satisfied about the monitoring results.	no comment by IEC on 8 Sep 2017	TCS00864/ 16/300/F00 81
4	21-Jun- 17	29-Au g-17	Tat Yan House, Po Tat Estate	Reside nt of Po Tat Estate	Cons tructi on noise	EPD	EPD (ref.N0 8/RE/0 00193 73-17)	day time construciton noise of breakers (8am to 6pm)	Since these two complaints were forwarded by CEDD to ET on 31 August 2017 which way after the complaint dates. Investigation would be conducted based on the site	no comment by IEC on 3 Nov 2017	TCS00864/ 16/300/F00 93



5	22-Jun- 17	29-Au g-17	Tat Yan House, Po Tat Estate	Reside nt of Po Tat Estate	Dust & Cons tructi on noise	EPD	EPD (ref. N08/R E/0001 9428-1 7)	Day time construction noise of breakers (8AM to 6PM). Requested to delay the operating hour of breakers to 10AM or 11AM	information by the Contractor of Contract 1 - NE/2016/01 (CWSTVJV) as well as the observation during weekly site inspection carried out ET during June 2017. In our investigation, CWSTVJV has implemented noise mitigation measures to reduce the noise impact to the nearby resident and the working hour 08:00 to 18:00 did not breach any legal requirement. To eliminate the inconvenience caused to the nearby resident CWSTVJV was advised to further enhance the noise mitigation measures as appropriately.		TCS00864/ 16/300/F00 93
6	15-Jul-1 7	29-Au g-17	Tat Yi House, Po Tat Estate	Reside nt of Po Tat Estate	Cons tructi on noise	EPD	EPD (ref.N0 8/RE/0 00224 79-17)	Construction noise	CWSTVJV has implemented noise mitigation measures to reduce the noise impact to the nearby resident and the working hour 08:00 to 18:00 did not breach any legal requirement. To eliminate the inconvenience caused to the nearby resident, CWSTVJV was advised to further enhance the noise mitigation measures as appropriately.	no comment by IEC on 3 Nov 2017	TCS00864/ 16/300/F00 94
7	28-Jul-1 7	29-Au g-17	Anderso n Road	unkno wn	Dust	EPD	EPD (ref.N0 8/RE/0 00239 86-17)	Poor control on dust emission at Anderson Road Construction Site	CWSTVJV has implemented dust mitigation measures to eliminate the inconvenience caused to the nearby resident and status of the implementation of dust mitigation measures was considered effective based on the site observation.	no comment by IEC on 15 Nov 2017	TCS00864/ 16/300/F00 97

8	2-Aug-1 7	29-Au g-17	Chun Tat House, On Tat Estate	Reside nt of On Tat Estate	Cons tructi on noise	EPD	EPD (ref.N0 8/RE/0 00245 57-17)	Day time construction noise of breakers (8AM to 6PM)	CWSTVJV has implemented noise mitigation measures to reduce the noise impact to the nearby resident. According to the impact noise monitoring result obtained in August 2017, there were no breaches of EM&A requirement. However, to eliminate the inconvenience caused to the nearby resident, CWSTVJV should further enhance the noise mitigation measures as appropriately. Since the works were carried out within the non-restricted hours, it is considered that the works under the project did not breach the Noise Control Ordinance.	no comment by IEC on 15 Nov 2017	TCS00864/ 16/300/F00 98
9	19-Sep- 17	19-Sep -17	Sau Mau Ping Estate Sau Nga House	Reside nt of Sau Mau Ping Estate	Cons tructi on noise	SPRO hotline	NA	The complainant is living at Sau Mau Ping Estate Sau Nga House (秀雅樓) 38/F. He complained about the noise nuisance recently from August to September especially during night time after 12:00 am, even in Saturdays and Sundays. The noise nuisance caused a great disturbance to him. He made a request to conduct investigation about the source of the noise during night time.	ET has conducted an ad-hoc noise measurement for Leq (30min) on the rooftop of 秀雅樓 and 秀義樓 in the afternoon of 22 September 2017. (Photo 1 & 2) During the course of noise measurement, construction activities such as excavation and breaking were conducted in the Quarry Site. The measurement results taken at both 秀雅樓 and 秀 義樓 were 63dB(A) which below the Limit Level under the EM&A Programme.	no comment by IEC on 18 Oct 2017	TCS00864/ 16/300/F00 88

]	0	21-Sep- 17	13-Oct -17	Sau Mau Ping Estate Sau Nga House and Sau Yee House	Reside nt of Sau Mau Ping Estate	Cons tructi on noise	EPD	EPD (ref.N0 8/RE/0 00310 74-17)	On 21 September 2017, the same complaint further reported that the noise can be heard at both Sau Yee House and Sau Nga House even in daytime and he strongly requested the Contractor to follow up the case immediately.	ET has conducted an ad-hoc noise measurement for Leq (30min) on the rooftop of 秀雅樓 and 秀義樓 in the afternoon of 22 September 2017. (Photo 1 & 2) During the course of noise measurement, construction activities such as excavation and breaking were conducted in the Quarry Site. The measurement results taken at both 秀雅樓 and 秀 義樓 were 63dB(A) which below the Limit Level under the EM&A Programme.		TCS00864/ 16/300/F00 88
]	.1	27-Sep- 17	13-Oct -17	Chun Tat House, On Tat Estate	Reside nt of On Tat Estate	Cons tructi on noise	EPD	EPD (ref.N0 8/RE/0 00294 89-17)	The complainant questioned why there were 6 to 7 breakers operating in the monring but only 1 operating in the afternoon. He requested to shift the operation of the breakers to afternoon.	CWSTVJV has implemented noise mitigation measures to reduce the noise impact to the nearby resident. According to the impact noise monitoring result obtained in September and October 2017, there		TCS00864/ 16/300/F01 06
1	2	3-Oct-1 7	13-Oct -17	Chun Tat House, On Tat Estate	Reside nt of On Tat Estate	Cons tructi on noise	EPD	EPD (ref. N08/R E/0003 2407-1 7)	Day time construction noise, the complainant requested using less breaker at one time, erecting taller noise barrier to cover the equipment. In addition, the complainant would like to know the construction schedule whether there will be more breaking activities in near future	were no breaches of EM&A requirement. However, to eliminate the inconvenience caused to the nearby resident, CWSTVJV should properly maintain the noise mitigation measures as appropriate. Since the works were carried out within the non-restricted hours, it is considered that the works under the project did not breach the Noise Control Ordinance.	no comment by IEC on 30 Nov 2017	TCS00864/ 16/300/F01 06
1	.3	25-Oct- 17	26-Oct -17	Tat Kwai House, Po Tat Estate	Reside nt of Po Tat Estate	Dust	EPD	NA	投訴安達臣道地盤的泥車落 泥,令他達貴樓的住所受到大塵 影響,要求跟進及回覆	Investigation revealed that CWSTVJV has implemented dust mitigation measures to eliminate the inconvenience caused to the nearby resident. Nevertheless, based on the observation during site inspection on 31 October 2017, CWSTVJV was	no comment by IEC on 15 Nov 2017	TCS00864/ 16/300/F01 00



									a n d	advised to enhance the dust mitigation measures particularly during dry season.		
	14	6-Nov-1 7	7-Nov- 17	Chun Tat House, On Tat Estate	Reside nt of On Tat Estate	Nois e	EPD	NA	安達邨俊達樓居民投訴石礦場 地盤又再於早上 07:45 開始傳出 機器不停揼石的噪音(幾乎每日 在 08:00-19:00 進行工程),已持 續一年,他全家人受到滋擾。	Ad-hoc noise measurement was conducted by ET at rooftop of Chun Tat House in the morning of 20 November 2017 and measurement result was below the Limit Level under the EM&A Programme. CWSTVJV has implemented noise mitigation measures to reduce the noise impact to the nearby resident. Since the works were carried out within the non-restricted hours, it is considered that the works under the project did not breach the Noise Control Ordinance.	no comment by IEC on 30 Nov 2017	TCS00864/ 16/300/F01 09
-	15	13-Nov- 17	14-No v-17	Chi Tai House, On Tai Estate	Mr. Lam Wai	light pollu tion and noise	SPRO hotline	NA	1. 智泰樓面向安達臣地盤方 向,有照射燈深夜時分仍然常 開,影響居民正常睡眠質素,照 成一定的精神壓力。 2. 隔音布未固定,大風吹過發出 極大的聲浪	To ease the concern by the complaint, CWSTVJV has adjusted the lights to the orientation pointing the ground and that to minimise the nuisance. For the maintenance of noise barrier, CWSTVJV has immediately fixed the noise barrier nearest to On Tai Estate and prolonged the cover area of the noise barrier to reduce the noise impact to the public.	no comment by IEC on 24 Nov 2017	TCS00864/ 16/300/F01 04

16	1-Nov-1 7	14-No v-17	Shing Tat House, On Tat Estate	Reside nt of Po Tat Estate	Nois e	EPD	NA	居住於安達邨誠達樓高層的投 訴人投訴由早上八時半至下午 六時聽到揼鐵噪音。	As advised by the Contractor, the works that most likely induced the iron hammering noise to Shing Tat House shall be the rock breaking works to the hard rock of the Southeastern side of the Underground Stormwater Retention Tank. CWSTVJV had already deployed the acoustic mat as noise barrier at the site boundary near Shing Tat House. To enhance the noise mitigation measures, CWSTVJV deployed an acoustic mat as noise barrier for the breaking work in order to reduce construction noise affecting the upper floor of On Tat Estate Since the works were carried out within the non-restricted hours, it is considered that the works under the project did not breach the Noise Control Ordinance.	no comment by IEC on 13 Dec 2017	TCS00864/ 16/300/F01 10
17	25-Aug- 17	26-Oct -17	Sau Yee House, Sau Mau Ping Estate	Reside nt of Sau Mau Ping Estate	Cons tructi on Nois e	EPD	EPD (ref.N0 8/RE/0 00277 38-17)	Night time construction noise of hammering (around 12AM)	As advised by CWSTVJV, there was a CNP (GW-RE0763-17) in force for the subject site for operation of generator and electric submersible water pump for the wastewater treatment plant and it is considered that abovementioned PMEs should not generate significant noise. Moreover, it is confirmed by CWSTVJV and checked against the site diary that no construction activities were carried out after 19:00 at the subject site. Therefore, the complaint about noise nuisance during night time should not be related to the Project.	no comment by IEC on 14 Dec 2017	TCS00864/ 16/300/F01 14

1	8	12-Sep- 17	26-Oct -17	Chun Tat House, On Tat Estate	Reside nt of On Tat Estate	Cons tructi on Nois e	EPD	EPD (ref. N08/R E/0002 9489-1 7)	Day time construction noise of breakers (8AM to 5PM)	Noise mitigation measures were implemented to reduce the noise impact to the nearby resident. According to the impact noise monitoring result in September 2017, there were no breaches of EM&A requirement. Since the works were carried out within the non-restricted hours, it is considered that the works under the project did not breach the Noise Control Ordinance.	no comment by IEC on 10 Jan 2018	TCS00864/ 16/300/F01 17
1	.9	15-Dec- 17	21-Dec -17	Sau Yee House	Reside nt of Sau Mau Ping Estate	Cons tructi on Nois e	EPD	NA	Resident of Sau Yee House complained suspected construction noise from Anderson Construction Site at restricted hour (7pm to 7am).	It is confirmed by CWSTVJV and checked against the site diary that no construction activities were carried out after 19:00 at the subject site. Therefore, the complaint about noise nuisance during night time should not be related to the Project.	no comment by IEC on 10 Jan 2018	TCS00864/ 16/300/F01 18
2	20	20-Dec- 17	21-Dec -17	On Tat Estate	Reside nt of On Tat Estate	Dust	EPD	NA	Resident of On Tat Estate complained that the traffic of construction vehicles generated dust problem and arouse air pollution to On Tat Estate. 投訴 安達臣道信和地盤水車已經壞 了十多天, 一直無灑水,四周 非常大塵。 投訴人住於安達 邨,投訴安達臣道石礦場有大地 盤,地盤大車工作時間不停出入 揚起沙塵,吹到安達邨,影響空 氣環境,要求部門到場視察。	CWSTVJV has implemented dust mitigation measures to eliminate the inconvenience caused to the nearby resident. It is considered that the complaint was an isolated case due to malfunction of water tanker and CWSTVJV has promptly rectified the deficiency. As advised by CWSTVJV, another water tanker will be deployed in mid-January 2018 to enhance the dust suppression measures throughout the construction site.	no comment by IEC on 25 Jan 2018	TCS00864/ 16/300/F01 21

CEDD Contract No. NTE/07/2016
Environmental Team for Development of Anderson Road Quarry Site – Site Formation and Associated Infrastructure Works
Monthly Environmental Monitoring & Audit Report (February 2022)

21	28-Dec- 17	10-Jan -18	Sau Yee House	Reside nt of Sau Mau Ping Estate	Cons tructi on Nois e	CE's office	NA	日間及凌晨均聽到轟隆聲的噪 音及震動,懷疑是由附近工程引 起* Thomas 先生表示居於秀茂 坪邨秀義樓,指附近的安達臣道 一個由土木工程拓展署管轄的 石礦場不時於非允許時段(即晚 上七時後至翌日早上)發出疑似 打地基的轟轟聲巨響,最近一次 就是今早(28/12)凌晨五時多再 次聽到石礦場傳來聲響,將 Thomas 先生吵醒,懷疑有人刻 意在無人監管下施工,更表示曾 向環保署及土木工程署作出投 訪,但環保署表示巡查後無發現 在非允許時段有工程進行,而土 木工程署則表示晚上七時後不 會再進行工程。Thomas 指石礦 揭經常在晚上八至十二時,或凌 晨時份發出巨響,對附近居民已 造成很大的滋擾,要求相關部門 儘快作出跟進及回覆。	no comment by IEC on 8 Feb 2018	TCS00864/ 16/300/F01 29
22	15-Jan- 18	15-Jan -18	Chun Tat House	Reside nt of Chun Tat House of On Tat Estate, 40/F	Cons tructi on Nois e	SPRO mobile	NA	CWSTVJV has implemented noise mitigation measures to reduce the noise of breaking rock for a long time and strongly requested to know exactly when will be the completion date of the breaking rock part of works opposite to Chun Tat House. She said we should do more on the mitigation measures because our site is very close to the residents nearby.	no comment by IEC on 8 Feb 2018	TCS00864/ 16/300/F01 30

AUES



									project did not breach the Noise Control Ordinance.		
23	1-Feb-1 8	2-Feb- 18	Chi Tai House of On Tai Estate	Reside nt of On Tai Estate (referr ed by Mr. Lam Wai)	Cons tructi on Nois e	SPRO hotline	NA	"智泰對出,白天噪音過大,可否 加裝隔音板?高層受影響"	the Environmental Team has conducted an ad-hoc noise measurement for Leq(30min) at the corridor of 22/F of Chi Tai House on 2 February 2018 facing the construction site. The measurement noise result was 65dB(A) which below the Limit Level under the EM&A Programme. In our investigation, CWSTVJV has implemented noise mitigation measures to reduce the noise impact to the nearby resident. According to the impact noise monitoring result obtained in January 2018, there were no breaches of EM&A requirement.	no comment by IEC on 22 Feb 2018	TCS00864/ 16/300/F01 37
24	1-Feb-1 8	2-Feb- 18	Shing Tat House of On Tat Estate	Reside nt of Shing Tat House (referr ed by Mr. Hsu Yau Wai)	Cons tructi on Nois e	SPRO hotline	NA	Mr. Hsu reported that some disturbing noise was heard after 6:00 pm from the site near Shing Tat House of On Tat Estate.	AECOM has liaised with Mr. Hsu on 2 February 2018 for the complaint matter and he reported to AECOM that the noise was generated until 7:00 pm on 1 February 2018. 3. As advised by Contractor of Contract 1, breaking works at USRT area which opposite to Shing Tat House was only carried out from 8:00 to 18:00. However, rock breaking at System A was extended to 19:00 on 1 February 2018. As noise mitigation measures, noise barriers were erected for the works area. Further to the complaint case, CWSTVJV would seek for other quiet work method	no comment by IEC on 28 Feb 2018	TCS00864/ 16/300/F01 40

									such as using drilling machine to reduce noise level and speed up the rock breaking process, so that to reduce the noise intensity level and the duration of exposure.		
25	28-Feb- 18	28-Feb -18	Shing Tat House of On Tat Estate	Reside nt of Shing Tat House	Cons tructi on Nois e	EPD	NA	安達邨誠達樓居民,投訴人是返 夜班,一年半以來長期受對出地 盤日間揼石仔噪音滋擾,由於單 位與地盤太近,堅持環保署跟進 及回覆如何處理及減低噪音,他 亦要求知道何日完工.	Breaking works at Underground Stormwater Retention Tank area which opposite to Shing Tat House was carried out from 8:00 to 18:00. The Contractor has implemented noise mitigation measures to reduce the noise impact to the nearby resident. It was advised that the rock breaking works shall tentatively be completed by end of April and it is believe that the noise impact should be minimized. Since the works were carried out within the non-restricted hours and noise monitoring noise were within acceptable level, it is considered that the works under the project did not breach the Noise Control Ordinance.	no comment by IEC on 19 Mar 2018	TCS00864/ 16/300/F01 43

24	6 11-Apr- 18	12-Apr -18	Him Tat House of On Tat Estate	Reside nt of Him Tat House	Cons tructi on Nois e	SPRO mobile	NA	Mr. Hui Yau Wai reported that the noise irritation was becoming more severe recently and asked about the completion date of the works close to Him Tat House. The resident suspected that the noise comes from piling works nearby.	In our investigation, since construction noise was generating from other construction site next to Him Tat House, it is considered that the complaint is due to cumulative noise generated by both construction sites. However, CWSTVJV should properly provide the noise mitigation measures at works area in System B to minimize the noise impact to the resident nearby. As advised by CWSTVJV on 20 April 2018, noise barrier was being erected at works area in System B as noise mitigation measures. According to the site photo, it is considered that the coverage of noise barrier is not sufficient and CWSTVJV should enhance the measure as far as practicable. The implementation of noise mitigation measures will be kept in view in subsequent site inspection.	no comment by IEC on 7 May 2018	TCS00864/ 16/300/F01 60b
2'	7 25-Apr- 18	7-May -18	Junction of Hiu Kwong Street and Hiu Ming Street	A school but name of school not disclos ed	Cons tructi on Nois e	EPD	NA	This case is considered as an enquir	ry and no investigation is required und	er the EM&A Prog	ramme.
2	8 18-May -18	24-Ma y-18	Anderso n Road Quarry Site	Undisc losed	Cons tructi on Nois e	EPD	NA	投訴人指安達臣道石礦場地盤 (NE/2016/01)在入夜 19:00 後仍 見到有長臂喉工程車在運作,及 持續產生大噪音及閃燈,非常擾 民。	As advised by CWSTVJV and confirmed by RE/AECOM, there were no construction activities carried out after 19:00 and concreting was completed before 19:00. It is concluded that the retracting process	no comment by IEC on 30 July 2018	TCS00864/ 16/300/F01 74b

 $\label{eq:linear} $$ 1.230\z\bel{loss} $$ 1.230\z$



										is not a general construction work using Powered Mechanical Equipment and complaint was an isolated case due to misunderstanding of the site operation. To prevent similar incidents in future, CWSTVJV has recommended several mitigation measures.		
2	29 2 1	25-Jun- 8	19-Jul- 18	Pedestri an Connecti vely E8 under Contract 3	Kwun Tong DC membe r Ms. So Lai-ch un	Wast e Mana geme nt	CEDD	NA	A public complaint was referred from CEDD on 4 July 2018 regarding accumulation of dead leaves and branches found at slope (GLA-TNK 2458) near Hiu Yuk Path on 25 June 2018. The complainant requested the relevant department to clear the leaves and branch asap	CW-CMGC-JV has immediately clear the dead leaves and maintain the site cleanliness. Since the construction work has not yet commenced and the dead leaves and overgrown branches were not related project works, it is considered that the complaint is not valid the project.	no comment by IEC on 24 Sep 2018	TCS00864/ 16/300/F01 89b
3	50 ² ₁	22-Aug- 8	29-Au g-18	Hong Wah Court	Reside nt of Hong Wah Court	Cons tructi on Nois e	1823 Hotlin e	NA	吳先生於 2018 年 8 月 22 日致電 1823 熱線投訴,指馬游塘區堆填 區往將軍澳方向行車入口因配 合項目需要而進行移除山坡工 程,但其鑽地鑿石的噪音嚴重影 響藍田康雅苑*居民,要求有關 部門跟進。*註:投訴人於 2018 年 8 月 27 日更正指受影響屋苑 應為藍田康華苑。	to reduce the inconvenience caused to the nearby resident, Kwan On should properly maintain the noise mitigation measures as appropriate, such as maintain good site practice including intermittent use of machine and plant and Sequencing operation of construction plant equipment. Since the works were carried out within the non-restricted hours, it is considered that the works under the project did not breach the Noise Control Ordinance.	no comment by IEC on 7 Sep 2018	TCS00864/ 16/300/F01 96a

31	28-Aug- 18	31-Jul- 18	Anderso n Road Quarry Site	Undisc losed	Cons tructi on Nois e	EPD	NA	安達邨誠達樓後面地盤,2月26 日晩,晩上7時後,還在落石屎, 相片拍攝時間大概晚上9時半, 一直至晚上十一時五十分還有 工程車在地盤行駛。影響居民休 息。	no comment by IEC on 10 Oct 2018	TCS00864/ 16/300/F01 97a
32	6-Sep-1 8	7-Sep- 18	Tsui Yeung House	Reside nt of Tsui Yeung House	Cons tructi on Nois e	Verbal	NA	Mr. CHENG Keung-fung complained that the contractor has rock excavation beyond the normal hours. Keung-fung completed by end of December 2018 and the mitigation measures will implemented continuously during slope construction work and the slope construction will be carried out within the working hours at Portion 2. Since the works were carried out within the non-restricted hours, it is considered that the works under the project did not breach the Noise Control Ordinance.	no comment by IEC on 22 Oct 2018	TCS00864/ 16/300/F02 01
33	24-Oct- 18	25-Oct -18	E3	Kwun Tong DC membe r Ms. So Lai-ch	Cons tructi on Nois e	Whats app Messa ge	NA	KTDC member, Ms. Ann So, complaining the noise of the breaker at E3As advised by the Contractor, the acoustic material wrapped on the 2018 and replacement of new acoustic materials has been installed on the breaker immediately on 25 October 2018. The rock breaking	no comment by IEC on 23 Nov 2018	TCS00864/ 16/300/F02 09a

 $\label{eq:linear} $$ 1.230\z\bel{loss} $$ 1.230\z$



								•			
				un					works shall tentatively be completed to the road level in the middle of November 2018 and the mitigation measures will implemented continuously during slope		
									construction work and the stope construction will be carried out within the working hours at Portion 2. It is considered the complaint was an isolate case.		
34	12-Nov- 18	13-No v-18	Anderso n Road Quarry Site	Reside nt of Ching Tat House(referre dby Mr. Hui Yau Wai)	Cons tructi on Nois e	SPRO Hotlin e	NA	Mr. Hui reported that he received complaint from a resident living in Ching Tat House about noise nuisance recently. Mr. Hui asked if project team can arrange some noise monitoring to check the noise level at the concerned flat or the same level at Ching Tat House.	The SPRO contacted Mr. Hiu and explained to him about the purpose and benefits of the tunnel to the residents nearby and the expected date of completion of the tunnel will be earlier than 2020. Moreover, the noise mitigation measures had implemented to reduce the noise level effectively and the work progress will be closely updated to nearby stakeholders to enhance communication. Mr. Hiu satisfied with the reply from SPRO and he agreed that the proposed noise monitoring in Ching Tat House was not needed. Since the works were conducted within approved normal hours with implementation of noise mitigation measures, there were no breaches of legislative requirement.	no comment by IEC on 12 Dec 2018	TCS00864/ 16/300/F02 22a

35	14-Nov- 18	14-No v-18	Anderso n Road Quarry Site	Undisc losed	Light and Nois e	EPD	NA		CWSTVJV immediately adjusted the ingle and brightness of the lighting to ninimize the nuisance to the resident hearby. In response to the complaint, CWSTVJV immediate carried out remedial action to ninimize the nuisance to the public. t was considered that complaint for noise generated by machine moving was an isolated case. CWSTVJV was reminded to closely monitor the plant use and sequence of night work and do not to violate CNP conditions.	no comment by IEC on 3 Jan 2019	TCS00864/ 16/300/F02 23a
36	13-Nov- 18	14-No v-18	Anderso n Road Quarry Site	Undisc losed	Nois e and dust	1823	NA	Complainant requested to postpone the starting time of and also to solve the problem of construction noise and dust.	n our investigation, acoustic barrier and site hoarding were in place along he works area. No noticeable noise and dust impact was observed during he site inspection. As advised by CWSTVJV, the normal working hour of the construction site is 8am to 6pm and there were no violation of the elevant regulations. The senior public relation officer contacted the complainant Ms. Ma on 26 November 2018 to explain the site ituation and she was satisfied with he reply. Investigation Report has been completed by ET without comment from IEC.	no comment by IEC on 18 Feb 2019	TCS00864/ 16/300/F02 24



37	9-Dec-1 8	12-Dec -18	Anderso n Road Quarry Site	Undisc losed	Cons tructi on noise	1823	2-4927 90730 5	In our investigation based on the 1823 has referred a case to CEDD on 10 December 2018, which the complainant complained that construction noise was generated from project site on Sunday and was affecting the resident at Hau Tat House, On Tat Estate. The complainant requested follow up action from related department as soon as possible. In our investigation based on the information provided by CWSTVJV, there was no site activities undertaken at site access road as concerned by the complainant. The construction work carried out on Sunday was fully compliance with the CNP requirement. In response to the complaint, CWSTVJV was reminded to closely monitor the plant use and sequence of night work and do not to violate CNP conditions.	no comment by IEC on 10 Jan 2019	TCS00864/ 16/300/F02 30a
38	19-Dec- 18	27-Dec -18	Anderso n Road Quarry Site	Undisc losed	Cons tructi on noise	1823	2-4948 07412 7	Joint site inspection was carried out on 3 January 2019 the status of implemented mitigation measures provided by CWSTVJV was inspected. It was observed that noise barriers near the round-about at On Sau Road were not enough, and construction noise generated from the project site was affecting the resident at Ming Tai House, On Tai Estate. The complainant requested follow up actions from related department as soon as possible. Joint site inspection was carried out on 3 January 2019 the status of implemented mitigation measures provided by CWSTVJV was inspected. It was observed that noise mitigation measures including temporary noise barrier, acoustic mat and wrapped by acoustic materials are implemented on site. However, CWSTVJV was advised to extend the coverage of noise barrier as far as practicable and fully enclose the concerned works area which has been completed on 15 January 2019. Since the works were carried out within the non-restricted hours, it is considered that the works under the project did not breach the Noise Control Ordinance.	no comment by IEC on 31 Jan 2019	TCS00864/ 16/300/F02 37a
39	24-Jan- 19	29-Jan -19	Anderso n Road Quarry Site	Undisc losed	waste water	Referr ed from DSD	NA	DSD has referred a case to CEDD In our investigation, the concerned on 24 January 2019 regarding catchpit and U-channel mainly suspended illegal discharge of cementitious slurry from Road as well as the discharge from construction site of Development of ARQ Site to nearby Public Stormwater Drainage System.	no comment by IEC on 29 Mar 2019	TCS00864/ 16/300/F02 48a

 $\label{eq:linear} $$ 1.230\z\bel{loss} $$ 016\TCS00864\CEDD\bel{loss} $$ 00\EM\&A\ Report\ Submission\Monthly\ EM\&A\ Report\2022\February\R0535v2.docx $$ 0.16\TCS00864\ CEDD\bel{loss} $$ 00\EM\&A\ Report\ Submission\Monthly\ EM\&A\ Report\2022\February\R0535v2.docx $$ 0.16\TCS00864\ CEDD\bel{loss} $$ 00\EM\&A\ Report\ Submission\Monthly\ EM\&A\ Report\2022\February\R0535v2.docx $$ 0.16\TCS00864\ CEDD\bel{loss} $$ 00\EM\&A\ Report\ Submission\Monthly\ EM\&A\ Report\ Submission\ Submissio$



									accumulated over time particularly by rainstorm as well as routine discharge from construction site. As remedial action, CWSTVJV immediately clean the affected area where accessible. Nevertheless, in order to protection the watercourse at downstream of the construction site, CWSTVJV has some enhancement measures.		
40	30-Jan- 19	30-Jan -19	Anderso n Road Quarry Site	Undisc losed	noise	SPRO hotline	NA	A public complaint was received by SPRO hotline on 30 January 2019 regarding the construction noise near Ma Yau Tong Village and requested to add noise barrier as soon as possible.	In our investigation, CWSTVJV had provided the noise mitigation measures to minimize the noise impact to the resident nearby. The impact monitoring result obtained at Ma Yau Tong Village revealed that the construction noise were within acceptable level. Since the works were conducted within approved normal hours with implementation of noise and dust mitigation measures, there were no breaches of legislative requirement.	no comment by IEC on 15 Mar 2019	TCS00864/ 16/300/F02 49a
41	15-Feb- 19	25-Feb -19	Anderso n Road Quarry Site	Undisc losed	noise	1823	2-4948 07412 7	1823 has referred a case to CEDD on 15 February 2019, which the complainant complained about the construction noise generated from the CEDD site near 法源寺 (Ma Yau Tong Village). The complainant requested for the details of works and the completion date, the complainant also requested CEDD to use other construction methods in order to re	In response to the complainant, CWSTVJV has proposed alterative quiet work method to alleviate the noise impact to the public. They will schedule the noisy activities to be carried out after 10am as far as practicable to minimize the impact to resident nearby, given that not affecting the site progress. Moreover, the coverage of acoustic barriers will be extended in view of the works programme.	no comment by IEC on 29 Mar 2019	TCS00864/ 16/300/F02 51a

42	21-Feb- 19	25-Feb -19	Anderso n Road Quarry Site	Undisc losed	noise	EPD	NA	The resident from Sau Hong House complained that the noise from the Anderson Road Quarry construction site has gotten worse. In addition, sometimes even after midnight there are noise coming from the site. With the echo produces from the environment, this is not helping at all. Really a big disturbance to the residence in the area. The complainant suspecting the sound proof measure has lessen as time goes. Follow action is requested.	In our investigation, CWSTVJV has implemented noise mitigation measures to reduce the noise impact to the nearby resident. However, to eliminate the inconvenience caused to the nearby resident, CWSTVJV should properly maintain the noise mitigation measures as appropriate, such as maintain good site practices such as intermittent use of machine and plant and Sequencing operation of construction plant equipment. Since the works were carried out within the non-restricted hours, it is considered that the works under the project did not breach the Noise Control Ordinance.erway by ET.	no comment by IEC on 28 Mar 2019	TCS00864/ 16/300/F02 50
43	21-Feb- 19	26-Feb -19	Anderso n Road Quarry Site	Undisc losed	noise	receive d by DEVB and referre d to CEDD	NA	A public complaint was received by DEVB and referred to CEDD on 25 February 2019 regarding on the noise generated from the construction works of the Anderson Road Quarry Site affecting a local resident residing at the Anderson Road Squatter Area	Additional acoustic mat has been erected in front of the Squatter Area to minimize the noise impact. Noise mitigation measures such as acoustic barriers erected along the works area and breaker head wrapped with acoustic material were implemented continually. Alterative quiet work method was adopted such as drilling the hard rock before the breaking work to reduce the breaking duration. In our investigation, CWSTVJV had enhanced the noise mitigation measures to ease the complainant's concerns. CWSTVJV will continually implement the noise mitigation measures to reduce to noise impact to the public.	no comment by IEC on 29 Mar 2019	TCS00864/ 16/300/F02 52a

14	1-Mar-1 9	26-Feb -19	E3 of Contract 2	Undisc losed	noise	CEDD	NA	The representative of the engineering team explained to Mr. Cheng about the project's details and concerned site was being constructed for the future pedestrian connection A complaint is forwarded by CEDD which was received by KTDC member Mr CHENG Keung Fung from the residents of Tsui Yeung House(翠楊樓) about the noise nuisance generated and the working time up to 7:00 pm from the rock excavation of E3 lift tower. Follow up action is requested. The representative of the engineering team explained to Mr. Cheng about the noise nuisance generated and engineering team. In our investigation, Kwan On has implemented noise mitigation measures to reduce the noise impact to the nearby resident. Since the works were carried out within the non-restricted hours, it is considered that the works under the project did not breach the Noise Control Ordinance.	no comment by IEC on 6 May 2019	TCS00864/ 16/300/F02 64
45	16-Jun- 19	18-Jun -19	Anderso n Road Quarry Site	Undisc losed	noise	EPD	NA	EPD referred a case to CEDD on 17 June 2019 regarding the construction noise heard at On Tat Estate on Sunday. The Contractor explained that general cleaning by water jet was carried out in the construction site on the concerned day. Since the work did not involve the use of Powered Mechanical Equipment (PME), it would not violate the noise control ordinance. The Investigation report is underway by ET.	no comment by IEC on 21 August 2019	TCS00864/ 16/300/F03 01a

46	12-Jul-1 9	15-Jul- 19	Anderso n Road Quarry Site	Undisc losed	dust	EPD	NA	In our investigation, CWSTVJV has implemented dust mitigation measures to eliminate the inconvenience caused to the nearby resident and status of implementation of dust mitigation measures was considered effective based on the site observation. Moreover, there was received by EPD regarding the dust impact to the residents at Po Tat Estate and On Tat Estate due to the dust emission at Anderson Road Quarry site. Hong Kong and the dust impact was considered not significant in addition to the dust mitigation measures implemented provided by the Contractor. Nevertheless, the ET will closely monitor the environmental performance and dust mitigation measures in subsequent site inspection. The IR is under reviewed by IEC.	no comment by IEC on 12 August 2019	TCS00864/ 16/300/F02 92b
47	6-Aug-1 9	14-Au g-19	Work Area Portion 2 E3 (Slope of Hiu Ming Street opposite of Tsui Yeung House)	翠(1物服辦處) 解 化 一	Nois e	1823	NA	In our investigation, Kwan On has A public complaint was received by 1823 on 6 August 2019 relating to the noise generated from construction work at the lift tower site (Slope E3) at Hui Ming Street from the residents of Tsui Yeung House. The complainant expressed that the construction works has been undertaken for 2 years and generated construction noise from 8am every day, which causing serious nuisance to the nearby residents. In our investigation, Kwan On has implemented noise mitigation measures to reduce the noise impact to the nearby resident. Nevertheless, since the construction site is close to the residential area, adequate noise mitigation measures shall be provided to reduce to noise that the complaint was valid to the contract. As the works were carried out within the non-restricted hours, it contract did not breach the Noise Control Ordinance.	no comment by IEC on 16 Sep 2019	TCS00864/ 16/300/F03 10a

CEDD Contract No. NTE/07/2016
Environmental Team for Development of Anderson Road Quarry Site – Site Formation and Associated Infrastructure Works
Monthly Environmental Monitoring & Audit Report (February 2022)



2	18	15-Oct- 19	18-Oct -19	Work Area Portion 6 (Tseung Kwan O Tunnel Bus-Bus Intercha nge Pedestri an Connecti vity Facilitie s E12)	Mr. Ng	Nois e	1823	NA	A public complaint was received by 1823 on 15 October 2019 relating to the noise generated from construction work at Tseung Interchange Pedestrian Connectivity Facilities E12. The complainant expressed that the construction noise was generated from breaking work at 8:20 am without noise mitigation measure, which causing nuisance to the nearby residents. In our investigation, Kwan On has implemented noise mitigation without noise mitigation measure, which causing nuisance to the nearby residents. In our investigation, Kwan On has implemented noise mitigation measures interchange Pedestrian construction noise was generated from breaking work at 8:20 am without noise mitigation measure, which causing nuisance to the nearby residents. In our investigation, Kwan On has implemented noise mitigation measure, which causing nuisance to the nearby residents. In our investigation measures as far as practicable as recommended in the EM&A Programme.	no comment by IEC on 13 Nov 2019	TCS00864/ 16/300/F03 26a
2	19	5-Nov-1 9	11-No v-19	Work Area Portion 2&3 (lift tower construc tion work at Hiu Kwong Street)	NA	Nois e	EPD	NA	In our investigation, Kwan On has implemented noise mitigation measures to reduce the noise impact to the nearby resident. Nevertheless, since the construction site is close to the residential area, adequate noise mitigation measures by EPD relating to the noise generated from breaking work of lift tower construction work at Hiu Kwong Street (Portion 2&3). Kwong Street (Portion 2&3).	no comment by IEC on 27 Dec 2019	TCS00864/ 16/300/F03 32a



50	7-Nov-1 9	11-No v-19	Work Area Portion 6	Mr. Cheng	Nois e	EPD	NA	寶達邨居民鄭先生, 表示將軍澳 隧道出口工程, 日間噪音嚴重, 8:30-17:00, 幾部幾同時開動, 而 且無防音欄, 之前是有, 現要求 環保署向對方反映改善	In our investigation, Kwan On has implemented noise mitigation measures to reduce the noise impact to the nearby resident. Nevertheless, since the construction site is close to the residential area, adequate noise mitigation measures shall be provided to reduce to noise nuisance to the public. As the works were carried out within the non-restricted hours, it is considered that the works under the contract did not breach the Noise Control Ordinance. Kwan On was reminded to implement the mitigation measures as far as practicable as recommended in the EM&A Programme.	no comment by IEC on 27 Dec 2019	TCS00864/ 16/300/F03 33a
51	10-Nov- 19	12-No v-19	Underpa ss	Undisc losed	Nois e	EPD	NA	On 10 November 2019 投訴人為馬游塘村居民,自本年 初寶林路開展掘隧道工程,每天 噪音不斷,由8至6,由於欠缺 遮擋,聲音直向4至22號村屋, 將來通車,相信噪音不只8-6, 現懇請環保署為本村居民正式 評估,並向政府提出村民困擾, 考慮盡快設置隔音屏。 On 11 November 2019 寶琳路近馬游塘村開掘隧道的 工程地盤每日8am-6pm發出噪 音,欠缺遮擋,聲音影響馬游塘 村4-22號村屋。希望政府部門 1.調查地盤有否違規 2.實施減音措施以減低對附近居 民的滋擾	In our investigation, CWSTVJV had implemented the noise mitigation measures to reduce to noise impact to the public. Since the works were conducted within approved normal hours with implementation of noise mitigation measures, there were no violation of legislative requirement. For the complainant's concern on the operation noise after commencement of the project, it is out of the scope of the EM&A programme and the relevant department will follow up the concern.	no comment by IEC on 30 Dec 2019	TCS00864/ 16/300/F03 37



52	11-Nov- 19	20-No v-19	Construc tion site near on Tai Estate Ancillar y Facilitie s Building on On Sau Road	Mr. Wong (reside nt of Yung Tai House of On Tai Estate)	Nois e	1823	ref. 2-5976 30318 3	黄先生投訴安秀道安泰邨服務 設施大樓附近掘路工程已持續 期年還未完成,並投訴其經常發 出噪音滋擾,要求部門跟進。On 22 November 2019, the project hotline received a call from the same complainant reported on the noise nuisance near On Sau Road and On Yan Street. He suggested to speed up the noise making works by intensely concentrate the excavation works during day time. No intermittence is suggested in order to speed up the works and to avoid waste of manpower.	no comment by IEC on 27 Dec 2019	TCS00864/ 16/300/F03 38a
53	5-Mar-2 0	6-Mar- 20	Tunnel work of Anderso n Road Quarry Site (the Underpa ss)	Reside nt of On Tat Estate	Nois e	EPD	NA	本人是安達邨居民,隧道工程在 安達臣的工程,施工至今嘈音間 中改善,最近又有嘈音出現,仲 係重低音,希望能加裝隔音設 備,工程不知何時將嘈音減至最 低。1. A public complaint was received by EPD on 5 March 2020 regarding the construction noise generated from the tunnel work of the subject site. The complainant mentioned that the noise from construction was improved before but it became	no comment by IEC on 1 Apr 2020	TCS00864/ 16/300/F03 57a

CEDD Contract No. NTE/07/2016
Environmental Team for Development of Anderson Road Quarry Site – Site Formation and Associated Infrastructure Works
Monthly Environmental Monitoring & Audit Report (February 2022)



54	4-Mar-2 0	17-Ma r-20	Near Hiu Ming Street Playgrou nd (E8)	Undisc losed	Nois e	1823	ref. 3-6283 23717 1	投訴人投訴有關秀茂坪邨秀安 樓附近有兩個地盤 , 地盤由星 期一至五,每天早上約 9AM-5 PM 持續不斷發出強烈的嘈音, 投訴人表示地盤是在曉明街藍 球場旁邊的位置(投訴人未能告 知確實街號),因此要求部門盡 快回覆及告知有關情況。 A public complaint was received by 1823 on 4 March 2020 regarding the construction noise. The complainant mentioned that there were two construction sites near Hiu Ming Street Playground generated construction noise continuously during 9AM to 5PM on weekdays.	a our investigation, CW-CMGCJV ad implemented the noise mitigation easures for the works at upper action of E8 near Hiu Yuk Path and o noise impact was observed and nticipated in Hiu Ming Street based in the site activities and our spection record. It is considered at the complaint is likely related to nother construction site located near iu Ming Street Playground and not sused by the works under the roject. Since the works were onducted within approved normal ours with implementation of noise itigation measures, there were no olation of legislative requirement.	no comment by IEC on 15 Apr 2020	TCS00864/ 16/300/F03 59a
55	23-Mar- 20	23-Ma r-20	Near Lin Tak Road (E11)	Undisc losed	Wate r Quali ty	Project hotline	NA	藍田居民梁先生反映在將軍澳 道往連德道天橋的大彎位,其中 有一個車輛出入口每日早上八 時左右不時有泥水從地盤流出 路面,估計泥水是清洗工程車輛 所致,令梁先生的車輛每次駛經 時被濺濕及弄污,請問有何措施 改善問題? A public complaint was received by project hotline on 23 March 2020 regarding overflow of muddy water from the construction site. The complainant mentioned that muddy water came out from site entrance, which spotted on his car, at 8am every morning.	our investigation, the wheel ashing facilities at site exit of E11 one of the dust quality mitigation easures conducted by W-CMGCJV and corresponding easure was implemented to prevent verflow of wastewater out of the te. In our recent site inspection, o outflow of muddy water from the te was observed and the condition concerned Lin Tak Road was tisfactory. It is considered that the omplaint was unlikely due to the roject.	no comment by IEC on 15 Apr 2020	TCS00864/ 16/300/F03 60a

56	17-Mar- 20	19-Ma r-20	Anderso n Road Quarry Site	Reside nt of Yan Tat House	Nois e	Project hotline	NA	In our investigation, CW-CMGCJV has implemented noise mitigation measures to reduce the noise impact and nuisance to the public. However, to eliminate the inconvenience caused to the nearby residents, CW-CMGCJV was advised to further adopt good practices on mitigating construction noise to reduce the noise impact to the nearby residents. 5. Since the works were carried out within the non-restricted hours, it is considered that the works the Anderson Road Quarry Site. The complainant mentioned that the construction noise generated from the Anderson Road Quarry Site had been continued for two years.	no comment by IEC on 11 May 2020	TCS00864/ 16/300/F03 61a
57	1-Apr-2 0	20-Apr -20	Work Area Portion 2	Undisc losed	Nois e	1823	NA	 觀塘秀茂坪紀念公園傍及曉明 街的地盤,共兩個地盤,是地政 總署管轄的。投訴人表示已被工 程噪音滋擾了兩年多;另外投訴 人得知完工時間要到 2021 年, 投訴人不明白為何工程頭尾要 3 年多時間.要求地政總署直接以 電郵回覆工程長的原因及有沒 有措施解決地盤發出的噪音。A public complaint was received by 1823 on 1 April 2020 and subsequently transmitted to Environmental Team (ET) on 20 April 2020, regarding the noise nuisance generated from the In our investigation, Kwan On has implemented noise mitigation measures to reduce the noise impact to the nearby resident. Nevertheless, since the construction site is close to the residential area, adequate noise mitigation measures shall be provided to reduce to noise nuisance to the public. It is concluded that the complaint was valid to the contract. However, as the works were carried out within the non-restricted hours, it is considered that the works under the contract did not breach the Noise Control Ordinance. Kwan On was reminded to implement the mitigation measures 	no comment by IEC on 7 May 2020	TCS00864/ 16/300/F03 66a



								construction site in Hui Ming as far as practicable as recommended Street. The complainant concerned about the slow progress and implementation of noise mitigation measures to alleviate the noise impact arising from the construction work.		
58	11-May -20	12-Ma y-20	Work Area Portion 2	Undisc losed	Nois e	Project hotline	NA	陳先生住於翠楊樓 17 樓,投訴 對面鑽石工程產生噪音對母親 健康構成影響,現查詢完工日 期、噪音監控標準及措施。 A public complaint was received by Project Hotline on 11 May 2020 regarding the noise generated from rock breaking work from a construction site opposite to Tsui Yeung House, which affecting his mother 's health. The complainant enquired about the completion date of construction work, construction noise level standard and implementation of noise mitigation measures on site.	no comment by IEC on 28 May 2020	TCS00864/ 16/300/F03 70a


59	18-Jun- 20	23-Jun -20	Anderso n Road Quarry Site, System B	Undisc losed	Nois e	EPD	NA	A public complaint was received by EPD on 18 June 2020 regarding the noise generated from rock breaking by machinery before 7pm from construction site near Hau Tat House. The complainant understood that the Contractor could carry out construction works, other than percussive piling, before 7pm under the CNP and hoped that the Contractor could arrange the noisy construction works to be carried out before 6pm. According to the information provided by the complainant, it is suspected complaint location would be Anderson Road Quarry Site, System B.	no comment by IEC on 17 July 2020	TCS00864/ 16/300/F03 91a
59 #	23-Jul-2 0	24-Jul- 20	Anderso n Road Quarry Site near On Tat Estate	Undisc losed	Nois e	EPD	NA	A public complaint was received by EPD on 23 July 2020 regarding the construction noise generated from the use of PME at Anderson Road Quarry Site near On Tat Estate at 6:30am (restricted hours). He/ she requested relevant department to follow up. In our investigation, CWSTVJV had restricted the use of PME before 7am. There was no construction work and use of PME during the restricted hours. Since the works were conducted within approved normal hours with implementation of noise mitigation measures, there were no violation of legislative requirement. Nevertheless, as the construction site is close to the residential area, CWSTVJV was reminded to implement the mitigation measures as far as practicable as recommended in the EM&A Programme	no comment by IEC on 25 August 2020	TCS00864/ 16/300/F04 01

AUE	S
-----	---

60	14-Nov- 20	18-No v-20	Near Hiu Ming Street Playgrou nd (E8)	Undisc losed	Nois e	1823	NA	A public complaint was received by 1823 on 14 November 2020 regarding the construction noise. The complainant mentioned that there was piling works at Hiu Ming Street Playground, generating huge noise during 9AM to 10AM on 14 November 2020. He/she requested relevant department to follow up	In our investigation, there was no noise impact was observed and anticipated in Hiu Ming Street based on the site activities and our inspection record. Since the works were conducted within approved normal hours with implementation of noise mitigation measures, there were no violation of legislative requirement	no comment by IEC on 4 January 2021	TCS00864/ 16/300/F04 24
61	4-Dec-2 0	7-Dec- 20	Opposite to On Tai Estate – lower portion of Road L4	Undisc losed	Dust	EPD	NA	A public complaint was received by EPD on 4 December 2020 regarding the dust impact. The complainant mentioned that the construction site opposite to On Tai Estate had dust emission problem due to lack of water spraying. He/she requested relevant department to follow up	In our investigation, CWSTVJV has implemented dust mitigation measures to eliminate the inconvenience caused to the nearby resident. In view of the potential traffic dust impact and implementation of dust mitigation measures, it is considered that the complaint was not valid to the Project	no comment by IEC on 4 January 2021	TCS00864/ 16/300/F04 34
62	3-Dec-2 0	7-Dec- 20	Ma Yau Tong Village (East Portal)	Undisc losed	Nois e and dust	1823 & EPD	3-6574 14101 7	A public complaint was received by 1823 and EPD on 14 November 2020 regarding the construction dust and noise impact arising from the project. There were acoustic mats erected on the slope of East Portal, however, the complainant enquired about effectiveness of the noise barriers with dozens of 15 cm "X"-shaped cuts. Moreover, there was lack of water sprinkling on the site and fugitive dust was blowing to the village	In our investigation, CWSTVJV had provided the dust and noise mitigation measures to minimize the dust and noise impact to the resident nearby. To response the concern from the complainant, as enhancement noise measure, the Contractor extended the noise barrier to encircle noisy activity. Since the works were conducted within approved normal hours with implementation of noise and dust mitigation measures, there were no breaches of legislative requirement	no comment by IEC on 4 January 2021	TCS00864/ 16/300/F04 35

63	7-Jan-2 1	7-Jan- 21	System B	Reside nt of Yan Tat House	Nois e	Project hotline	NA	A public complaint was referred by district Councillor Mr. HSU Yau-wai and received by project hotline on 7 January 2021 regarding the construction noise. The complainant mentioned that the construction site next to SKH St. John's Tsang Shiu Tim Primary School generated noise problem and she requested relevant department to follow up.	In our investigation, the Contractor has implemented noise mitigation measures to reduce the noise impact and nuisance to the public.6. Since the works were carried out within the non-restricted hours, it is considered that the works under the contract did not breach the Noise Control Ordinance. Nevertheless, as the construction site is close to the residential area, the Contractor was reminded to implement the mitigation measures as far as practicable as recommended in the EM&A Programme.	no comment by IEC on 19 July 2021	TCS00864/ 16/300/F04 41
64	18-Mar- 21	18-Ma r-21	Anderso n Road Quarry Site (betwee n On Tat Estate and On Tai Estate)	Undisc losed	Nois e	1823 & EPD	NA	A public complaint was received by 1823 and referred by EPD on 18 March 2021 regarding the construction noise generated from construction works at Anderson Road Quarry Site between On Tat Estate and On Tai Estate. The complainant expressed that construction works of the site started from 6:45am everyday which causing noise disturbance to the nearby resident and he/ she requested relevant department to follow up	In our investigation, CWSTVJV had restricted the use of PME before 7am. There was no construction work and use of PME during the restricted hours and there should not be any non-compliance of Noise Control Ordinance. Nevertheless, as the construction site is close to the residential area, CWSTVJV was reminded to implement the mitigation measures as far as practicable as recommended in the EM&A Programme	no comment by IEC on 1 April 2021	TCS00864/ 16/300/F04 54
65	1-Apr-2 1	1-Apr- 21	Construc tion site near SKH St. John's Tsang Shiu Tim Primary	Undisc losed	Nois e	EPD	NA	A complaint was received by EPD and referred to CEDD on 1 April 2021 regarding the construction noise. The complainant mentioned that piling work was conducted at construction site near SKH St. John's Tsang Shiu Tim Primary School in recent week which generated noise problem.	In our investigation, the Contractor has implemented noise mitigation measures to reduce the noise impact and nuisance to the public. Since the works were carried out within the non-restricted hours, it is considered that the works under the contract did not breach the Noise Control Ordinance. Moreover, the	no comment by IEC on 19 July 2021	TCS00864/ 16/300/F04 58a

 $\label{eq:linear} $$ 1.230\z\bel{loss} $$ 1.230\z$

CEDD Contract No. NTE/07/2016
Environmental Team for Development of Anderson Road Quarry Site – Site Formation and Associated Infrastructure Works
Monthly Environmental Monitoring & Audit Report (February 2022)



			School (System B under Contract 3)					Moreover, there were no noise mitigation measures provided in the construction site	Contractor has adopted noise mitigation measures to minimise noise impact to the public. Since the construction site is close to the residential area, the Contractor was reminded to implement the mitigation measures as far as practicable as recommended in the EM&A Programme		
66	28-Mar- 21	30-Ma r-21	Anderso n Road Quarry Site (betwee n On Tat Estate and On Tai Estate)	Reside nt of Tai Fung House of On Tai Estate	Nois e	EPD	K13/R E/0000 7086-2 1	A public complaint was received by EPD on 28 March 2021 regarding the construction noise generated from construction works at Anderson Road Quarry Site until 9pm on Monday to Saturday. Moreover, the complaint concerned about the construction noise heard on 28 March 2021 which was a Sunday.	In our investigation, CWSTVJV had followed that CNP for work during restricted hour and there should not be any non-compliance of Noise Control Ordinance. Nevertheless, some site areas had been handed over to other contract and construction noise generated from others is not controlled by the project. As a reminder, CWSTVJV should implement the mitigation measures as far as practicable as recommended in the EM&A Programme.	no comment by IEC on 22 April 2021	TCS00864/ 16/300/F04 59
67	11-Jun- 21	11-Jun -21	Anderso n Road Quarry Site	Reside nt of Chi Tat House, On Tai Estate	Nois e	EPD	EPD Ref.: 13208- 21	A public complaint was received by EPD on 11 June 2021 and complained about noise nuisance from multiple construction sites on Anderson Road Quarry Site. The complainant stated that there were noise nuisances from different construction sites from 0800 am to 1800 pm from Monday to Saturday without adequate noise mitigation measures. On 17 June 2021, the complainant added that the noise was generated from rock breaking works in front of Chi Tai House (not from the housing sites near	6. In our investigation, CWSTVJV had implemented the noise mitigation measures to reduce to noise impact to the public. In response to the complaint, CWSTVJV had immediately installed a layer of acoustic barrier at boundary of concern works area. Since the works were conducted within approved normal hours with implementation of noise mitigation measures, there were no violation of legislative requirement.	no comment by IEC on 19 July 2021	TCS00864/ 16/300/F04 78a

\\192.168.1.230\z\Jobs\2016\TCS00864 (CEDD)\600\EM&A Report Submission\Monthly EM&A Report\2022\February\R0535v2.docx



									the Tai Sheung Tok slope) and no mitigation measure was implemented for the rock breaking works.			
e	58	20&21/J une/21	23-Jul- 21	Anderso n Road Quarry Site	DSD	Wate r Quali ty	EPD	EPD Ref.: 13208- 21	EPD received complaints from DSD on 20 and 21 July 2021 concerning about discharge of muddy water as found on Po Lam Road and at the drainage facility near Tin Hau temple.	In our investigation, CWSTVJV had implemented the water quality mitigation measures to minimise the impact arising from the construction site. In view of the site condition and inclement weather condition on the complaint days, it is considered that the complaints raised by DSD were unlikely due to the C1 Project. Nevertheless, CWSTVJV was advised to closely monitor the discharge quality to avoid non-compliance of water quality happened in the construction site. Moreover, to cope with the adverse weather condition in wet season, CWSTVJV should regularly review the drainage plan as needed.	no comment by IEC on 6 August 2021	TCS00864/ 16/300/F04 85b
e	59	14&16/ Sep/21	15-Sep - 21	Anderso n Road Quarry Site	DSD	Wate r Quali ty	EPD	NA	EPD received complaints from DSD on 14 Sep 2021 and 16 Sep 2021 concerning about discharge of muddy water as found at the catchpit SCH4003250 near Po Lam Road and catchpit SSH4001400 near Po Tat Tin Hau Temple.	In our investigation, CWSTVJV had implemented the water quality mitigation measures to minimise the impact arising from the construction site. However, there were incidents of seepage of silty water at Q2 and Q3 and rectified actions were undertaken immediately. Having investigated, the incidents were considered very short term and would not generate large amount of muddy water. In view of the inclement weather condition and there were other major sources, it is considered that the complaints raised by DSD were not fully contributed byC1 Project.	no comment by IEC on 6 October 2021	



								Nevertheless, CWSTVJV was advised to closely monitor the discharge quality to avoid non-compliance of water quality happened in the construction site. Moreover, to cope with the adverse weather condition in wet season, CWSTVJV should regularly review the drainage plan as needed.		
70	23/Sep/ 21	29-Sep -21	Anderso n Road Quarry Site	CEDD & EPD	Nois e	CEDD &EPD	A public complaint was referred by 1823 to both CEDD and EPD on 23 September2021. The complainant stated that the construction works at Anderson Road Quarry Site started before 7am, which generated construction noise and affecting the upper floor resident of On Tat Estate. EPD have contacted the complainant and clarify that the concerned about construction dust and daytime construction noise after 7am.	Our investigation revealed that there was no construction works under the Project undertaken during the concerned period by the complainant, and there were other concurrent contracts on Anderson Road Quarry Site and the contribution noise may be related to others. Therefore, it is considered that the noise complaint was unlikely to be related to the works under the Project. Nevertheless, CWSTVJV was reminded to properly maintain the noise mitigation measures as far as practicable considering the construction site is relatively close to residential area.	No comment by IEC on 15 November 2021	



Appendix N

Implementation Status for Water Quality Mitigation Measures

Water Quality Mitigation Measure





